

C-56

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F.6/DFS/MS/GH/SZ/2022/ 261

Dated: 07/06/2022

FIRE SAFETY CERTIFICATE

Certified that M/s. **Hotel Southern Residency located at 18/5, Arya Samaj Road, Karol Bagh, New Delhi- 110005**, comprised of basement, ground plus three upper floors. was granted Fire Safety Certificate vide this department letter No. F.6/DFS/MS/GH/SZ/2019/2090 dated 31.10.2019, for ground floor as office, first floor as reception, store & 07 guest rooms, second & third floor each having 07 guest rooms & 01 store respectively (total 21 guest rooms). The guest house was re-inspected by the officer concerned of this department on 27.05.2022 in presence of Sh. B. Surya Rao (G.M) and found that the guest house management have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class residential (guest house) **for ground floor (office), first floor (reception & 07 guest rooms), second floor & third floor each having 07 guest rooms (total 21 guest rooms only)**, with effect from 07/06/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 07/06/2022 at New Delhi by.


(Sunil Chaudhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Following Fire Safety Directives must be adhered to: -

1. No occupancy used above third floor and basement are separate from guest house shall be strictly adhered by Owner/Occupier.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing department shall always be permitted and followed.
8. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

2/24

INSPECTION REPORT

1. Name & address of the building : M/s. Southern Guest House, 18/2, Arya Samaj Road, Karol Bagh, New Delhi- 110005.
2. Type of Occupancy : Residential
3. Building Composition : comprised of basement , ground plus three upper floors
4. Type of Case : Renewal
5. Details of previous NOC : F.6/DFS/MS/GH/SZ/2019/1087 dated 22.05.2019
6. Fire Safety directives letter No : Nil
7. Date of inspection : 27.05.2022
8. Name of the Inspecting Officers : Vedpal Chhikara, DO (SW) & P.V. Rathee, ADO (SRD)
9. Name and designation of officers from the building side : Sh. B. Surya Rao (Manager)
9. Year of Construction : Before 2007
10. Applicant's letter No. : Online Application Id 2022042908838 dated 30.04.2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Fire safety requirements as per FSC dated 22.05.2019	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	09 mts	MR
	• Gate width	N/A	Directly accessible from road	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	01	01	MR being old case
	• Basements	02	02	MR MR being old case
	b. Width of staircases	-	-	-
	• Upper Floors	1.25 mts	1.25 mts	MR being old case
	• Basements	1.25 mts	1.50 & 1.25 mts	MR being old case
	c. Protection of exits	-	-	-
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	1.0 mts	1.40 mts	MR
	h. Door Size	1.0 mts	78 cm *200 cms	MR being old case
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	Exhaust fan provided	MR
	• Upper floors	12 a/c per hour	Natural ventilation	MR
5	Fire Extinguishers			
	• Total numbers	03 at each floor	Provided	MR
	• Types	CO ₂ , ABC	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			

		Required	Provided	
	Total numbers on each floor	01	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	Carbon Monoxide	Provided	MR
	Location of Main Panel	Required	Provided near reception	MR
	Location of Repeater Panel	N/A	N/A	N/A
	Alternate source of power	Required	Provided	MR
	Hooters' Location	N/A	N/A	N/A
8	MOEFA			
9	Public Address System.			
		Required	Provided	MR
10	Automatic Sprinkler System.			
	Basement	Required	Provided	MR
	Upper Floor	N/A	N/A	N/A
	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-comer	N/A	N/A	N/A
	Number of hydrants per floor	N/A	N/A	N/A
	Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	Total number of hydrants	N/A	N/A	N/A
	Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	Ground Level	---	---	---
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	Terrace level	-----	-----	-----
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the pump	40 mts	40 mts	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
	14	Captive Water Storage for fire fighting.		
	Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	Overhead Tank capacity	Old case	Provided (5000 lts)	MR being old case
15	Exit Signage.			
		Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N/A	N/A	N/A
	Pressurization of Lift lobby	N/A	N/A	N/A
	Communication In lift Car	N/A	Provided	N/A

W

W

N-26

7	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter No. F.6/DFS/MS/GH/SZ/2019/1087 dated 22.05.2019, renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

DFA is put up for approval & signature please.

[Handwritten Signature] 27/5/22

Signature of the Inspecting Officer
Name- Vedpal Chhikara
Divisional Officer (SW)

[Handwritten Signature] 27/5/22

Signature of the Inspecting Officer
Name- P.V. Rathee Divisional
Asstt. Div. Officer (S.Rd)

Dy CFO (S/Z) *[Handwritten Signature]* F.T.

ADDG (P.A.)

F.T. Letter is put-up for sign please,

Dy CFO (S/Z) *[Handwritten Signature]*

[Handwritten Signature] 1/6/22

M.S. Cell

FSC uploaded on MHA Portal
9/6/22 *[Handwritten Signature]*