

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F6/DFS/MS/EH/2022/NDZ/152

Dated: 01/06/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s Jubilant Food Works Ltd. (Domino's Pizza) located at Ground Floor, Shop no. G-40, Vikas Cine Mall, Shahdara, Delhi-110032 owned / occupied by M/s Jubilant Food Works Ltd., have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 26/04/2022 in the presence of Sh. Param Kumar (Manager) and found that the building / premises is fit for the occupancy class "Assembly" (Group-D) / Eating House with effect from 01/06/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 01/06/2022 at New Delhi by.


(ATUL GARG)
DIRECTOR.

Copy to :-

1. Addl. Commissioner of Police, Lic.Unit, 1st Floor, Police Station Defence Colony, New Delhi.
2. Sh. Param Kumar (Manager), M/s Jubilant Food works ltd (Domino's Pizza) located at Shop no. G-40, Vikas Cine Mall, Shahdara, Delhi-110032.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

411 INSPECTION REPORT

1. Name & address of the building: **M/s Jubilant Food Works Ltd. (Domino's Pizza), Ground Floor, Shop No-G 40, Vikas Cine Mall, Shahdara, Delhi-110032.**
2. Type of Occupancy : **Assembly (E/H)**
3. Type of Case : **New**
4. Details of previous NOC : **Nil**
5. Fire Safety directives Letter No. : **NBC (Part-IV)**
6. Date of inspection : **26/04/2022**
7. Name of the Inspecting Officer : **ADO (Shd.) & D.O. (East)**
8. Name and designation of Officer from the building side : **Sh. Param Kumar (Manager)**
9. Year of Construction : **2006**

10. Applicant's letter received through MHA portal ID-2022033104763 dated 01/04/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	6 mtr	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	1.50 mtr x 2	1.50mtr x 2	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	2	4	M/R
	• Types	ISI marked ABC/CO ₂	Provided	M/R
	• IS marking	Required	Provided	M/R

2

6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Common with Mall	MR
	• Length of hose reel hose	30 Mtr.	Common with Mall	MR
	• Nozzle diameter	5 mm	Common with Mall	MR
7.	Automatic fire detection and alarming system <i>(Required for Building)</i>			
	• Type of detector	Required	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Ground Floor	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down- comer	150 mm	Common with Mall	MR
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	Common with Mall	MR
	➤ Head of the pump	40 MTR	Common with Mall	MR
	➤ Power supply	Required	Common with Mall	MR
	➤ Auto starting of pump	Required	Common with Mall	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	20,000 Ltr.	Common with Mall	MR

15	Exit Signage	N/A	N/A	N/A
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.



Deepak
02/05/2022
Signature of the Inspecting Officer
Name : Deepak Kumar
Designation : A.D.O. (Shahdara)

Ashok
04/05/22
Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : D.O. (East Division)

Recd on 19/5/22

Dy. CEO (NDZ)
[Signature]
20/5/22
CFO
[Signature]
23/5/2022
Director
[Signature]
24/5/2022

[Signature]
25/05/22
As approved F.S. is put up for signature of
[Signature]
25/5/22
Director
[Signature]
24/5/22
Escalated on 25/5/22