

C-13

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/EH/2022/NDZ/ 154

Dated: 3/06/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s KFC Restaurant (A unit of Sapphire Foods India Pvt. Ltd.), located at UGF-A 12, Main Road, Swami Dayanand Marg, East Krishna Nagar, Delhi-110051, building comprised of Basement, Stilt, Ground & Three upper floors **But restaurant running on Upper Ground Floor only**, owned / occupied by A unit of Sapphire Foods India Pvt. Ltd., have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 25/05/2022 in the presence of Sh. Shyam Manohar (Manager) and found that the building / premises is fit for the occupancy class "Assembly" (Group-D) / **Eating House** with effect from 03/06/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 03/06/2022 **at New Delhi by.**

(ATUL GARG)
DIRECTOR.

Copy to :-

1. Addl. Commissioner of Police (Lic), 1st Floor, Police Station, Defence Colony, New Delhi-110024.
2. Sh. Madhur Sharma (Dy. Manager, Legal), M/s KFC Restaurant (A unit of Sapphire Foods India Pvt. Ltd.), UGF-A 12, Main Road, Swami Dayanand Marg, East Krishna Nagar, Delhi-110051.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: **M/s KFC Restaurant (A unit of Sapphire Foods India Pvt. Ltd.), UGF-A 12, Main Road, Swami Dayanand Marg, East Krishna Nagar, Delhi-110051.**
2. Type of Occupancy : **Assembly (Group-D) (Eating House)**
3. Building Comprised of : **Basement, Stilt, Ground + Three upper floors. (But restaurant running on Upper Ground Floor only).**
4. Type of Case : **New**
5. Details of previous NOC : **Nil**
6. Fire Safety directives Letter No. : **NBC Part-IV**
7. Date of inspection : **25/05/2022**
8. Name of the Inspecting Officer : **D.O. (E.D.) & A.D.O. (Shah.)**
9. Name and designation of Officer
from the building side : **Sh. Shyam Manohar (Manager)**
10. Year of Construction : **2015**
11. Applicant's letter received through email ID- **madhur.sharma@sapphirefoods.in** dated **11/04/2022**

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC - IV Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6m	Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1.50 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour	N/A	NA
	• Upper floors	12 a/c per hour	NA	NA
5.	Fire Extinguishers			
	• Total numbers	2	4	M/R
	• Types	ABC, CO ₂ & WCO ₂	ABC, CO ₂ , Water CO ₂	M/R
	• ISI marking	Required	Provided	M/R

4/9.

6.	First Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30 Mtr.	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	100mm	Provided	MR
	• Number of hydrants per floor	1	Provided	MR
	• Hose Box	1	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	20,000 Ltrs.	Provided	MR

✓

15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	NA		

Note:- Shortcomings issued by this department vide letter No. F6/DFS/MS/EH/2021/NDZ/5013 dated 17/11/2021 have been complied.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
Name : Deepak Kumar
Designation : A.D.O. (Shah.)

Signature of the Inspecting Officer
Name : A.K. Jaiswal
Designation : D.O. (East)



Dy. C.F.O. (NDZ)

[Signature]
30/5/22

[Signature]
31/5/2022
Director

[Signature]
17/6/22

DOCEP

P.F.O.