

423

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No F 6/DFS/MS/2022/School/WZ/ 620

Dated: 07/06/2022

**FIRE SAFETY CERTIFICATE**

Certified that the **S.D. Indraprastha Modern School** located at **Plot No. 447, Village, Begampur. Opp. Rohini Sec-22, Delhi-110086**, comprised of **Ground + 02 upper floors (School is running at Ground & First floor only)** owned/occupied by **S.D. Indraprastha Modern School** was granted FSC by this department vide letter **No. F.6/DFS/MS/2017/500 dated 03.04.2017**. The premises was re-inspected by the officer concerned of this department on **13.05.2022** in the presence of **Miss. Kashish Yadav (HOS)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from 07/06/2022 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 07/06/2022 at New Delhi

  
**(Dhrampal Bhardwaj)**  
**Dy.Chief Fire Officer**  
**Tel:-01123414250**

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, S.D. Indraprastha Modern School located at Plot No. 447, Village, Begampur. Opp. Rohini Sec-22, Delhi-110086.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [http://www.delhi.gov.in/wps/wcm/connect/doi\\_t\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/) [http://www.delhi.gov.in/wps/wcm/connect/doi\\_t\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms)

**INSPECTION REPORT**

1. Name & address of the building : S.D. Indraprastha Modern School located at Plot No. 447, Village, Begampur. Opp. Rohini Sec-22, Delhi-110086
2. Type of Occupancy : Educational
3. Type of Case : Renewal (Gr. + 02 floors) **school is running Gr.+01 upper floors**
4. Details of Previous NOC : F.6/DFS/MS/2017/500 dated 03.04.2017
5. Fire Safety directives letter No : Director of Educational Circular dated 01.03.2011
6. Date of inspection : 13.05.2022
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers  
From the building side : Miss. Kashish Yadav (HOS)
9. Year of Construction : 2016
10. Applicant's letter No. : OD No. 546 dated 19.04.2022.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Director of Educational Circular dated 01.03.2011	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>Road width</li> </ul>	Accessible	Accessible	MR
	<ul style="list-style-type: none"> <li>Gate width</li> </ul>	Accessible	4.5m	MR
	<ul style="list-style-type: none"> <li>Width of internal road</li> </ul>	NA	NA	NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> </ul>	02	02	MR
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	NA	NA	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	1.5m	1.70m & 1.10m	MR
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	NA	NA	NA
	c. Protection of exits			
	Fire check door			
	<ul style="list-style-type: none"> <li>Pressurization</li> </ul>	NA	NA	NA
		NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0m	1.0m	MR
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Sealing of electrical shafts</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Fire Rating of shaft door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Water Curtain</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Fire Dampers</li> </ul>	NA	NA	NA
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	30 a/c per hour	NA	NA
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	12 a/c per hour	Natural ventilated	MR
5.	<b>Fire Extinguishers</b>			


	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	06nos.	07nos.	MR
		ABC/CO2	ABC-7	MR
		ISI marked	Yes	MR
6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
7.	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	<b>MOEFA</b>	NA	NA	NA
9.	<b>Public Address System</b>	NA	NA	NA
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground &amp; Upper Floors</li> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/Manual Stopping</li> <li>➤ Pump House Access</li> </ul> </li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> <li>Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>			
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	<b>Captive Water Storage for fire fighting</b>			




	<ul style="list-style-type: none"> <li>Underground tank capacity               <ul style="list-style-type: none"> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15.	Exit Signage.	NA	NA	NA
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> <li>Detector System Panel</li> <li>Flow Switch Panel</li> <li>PA System Panel</li> <li>Battery backup</li> <li>Building Floor Plans</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.


Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in **Director of Education Circular**, the FSC issued vide letter no. F.6/DFS/MS/2017/500 dated 03.04.2017 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

  
 Signature of the Inspecting Officer  
 Name           Ajay Kumar Sharma  
 Designation   ADO(Rohini)

DO (NW)

  
25/05/2022


Dy CRO (W2)


  
29/5/2022

ADO Rohini

FI letter is put up for kind perusal and signature please.

W87  26/05/2022

  
26/5/2022

  
1/6/22