

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI



No. F6/DFS/MS/EH/WZ/2022/ 162

Dated: 07/06/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s. **Standard Snacks and Restaurant** located at **B 10/12, Rajouri Garden, New Delhi- 110027** running at Ground Floor only in a building comprised of Ground plus one upper floor, Owned/Occupied by M/s. **Standard Snacks & Restaurant** was inspected by the officer concerned of this department on 20/05/2022 in the presence of Ms. Indu Sharma (Owner/Partner) and found that the owner have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Assembly" Group D (**Ground Floor Only**) with effect from 07/06/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Conditions Mentioned Below.

Issued on 07/06/2022 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

07/06/2022

Copy to: -

1. The Owner/Occupier M/s. **Standard Snacks and Restaurant** Located at **B 10/12, Rajouri Garden, New Delhi- 110027. (Online ID – 2022050509512 dated 05/05/2022)**
2. The DHO, West Zone, SDMC, Shivaji Enclave, Raja Garden, New Delhi-110027. **Email Id : - (dhowest zone@gmail.com).**
3. The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi. **addlcp.lic-dl@nic.in**

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. **The NOC is valid for Ground floor only.**

INSPECTION REPORT

1. Name & address of the building: M/s. Standard Snacks & Restaurant located at B 10 12, Rajouri Garden, New Delhi-110027.
 2. Type of Occupancy : Assembly
 3. Type of Case : New
 4. Details of previous NOC : NIL
 5. Fire Safety directives letter No : NIL
 6. Date of inspection : 20/05/2022
 7. Name of the Inspecting Officers : Sarabjeet Singh ADO (MN)
 8. Name and designation of officers from the building side : Sh. Indu Sharma
 9. Year of Construction : 1965 (As Per MHA Portal)
 10. Applicant's letter No. : Online application no. 2022050509512 dated 05/05/2022
- * The said restaurant is running at Ground floor of a building comprised of ground plus one Upper floor.**

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	12 mtr	Provided	MR
	• Gate width	4.5 mtr	Directly accessible from road	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	N/A	Rest. Running at GF	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floors	N/A	Rest. Running at GF	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	f. Width of Corridor	N/A	N/A	N/A
	g. Door Size	2 x 1.5 m	1 x 1.77mtr, 1 x 1.50 mtr	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	N/A	N/A	N/A
	• Upper floors	12 a/c per hour	Natural Ventilation	MR
5	Fire Extinguishers			
	• Total numbers	06 CO ₂ , ABC type ISI marked	Provided	MR
	• Types		Provided	MR
	• IS marking		Provided	MR

N. 6

6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 mts	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	20,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR

N-7

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	02 ABC type fire extinguishers are provided near elect. panel	N/A

The fire protection systems provided in the building were checked and found functional at the time of inspection. The Shortcomings issued by this department vide Letter no. F6/DFS/MS/WZ/EH/2022/265 Dated- 23/03/2022 have been complied.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

188/ADO/4N
23/05/2022

DO (West)

889
23/5/22

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

D.O. (WEST)/524
DATED... 27/05/2022

27/05/2022

DO (WZ)

28/6/2022

CP
3/6/2022

Director

23/06/2022

DO (West)

ADO (MN)

F.T. please

6/6