

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**

**NEW DELHI**

No. F6/DFS/MS/EH/WZ/2022/ 163

Dated: 07/06/2022

**FIRE SAFETY CERTIFICATE**

Certified that the M/s. **Standard Sweets and Restaurant** located at **B 10/12 A, Rajouri Garden, New Delhi- 110027** running at Ground Floor only in a building comprised of Ground Floor, Owned/Occupied by M/s. **Standard Sweets and Restaurant** was inspected by the officer concerned of this department on 25/05/2022 in the presence of Sh. Anirudh Kumar (Owner/Partner) and found that the owner have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Assembly" Group D (**Ground Floor Only**) with effect from 07/06/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Conditions Mentioned Below.

Issued on 07/06/2022 at New Delhi by.

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to: -

1. The Owner/Occupier M/s. **Standard Snacks and Restaurant** Located at **B 10/12 A, Rajouri Garden, New Delhi- 110027. (Online ID – 2022052110847 dated 21/05/2022)**
2. The DHO, West Zone, SDMC, Shivaji Enclave, Raja Garden, New Delhi-110027. Email Id : - (dhowest zone@gmail.com).
3. The Joint Commissioner of Police, Licensing Unit, 1<sup>st</sup> floor, Police Station, Defence Colony, New Delhi. [addlcp.lic-dl@nic.in](mailto:addlcp.lic-dl@nic.in)

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. **The NOC is valid for Ground floor only.**

N-12  
**INSPECTION REPORT**

1. Name & address of the building : M/s. Standard Sweets and Restaurant Located at B 10/ 12 A, Rajouri Garden, New Delhi-110027
2. Type of Occupancy : Assembly (Class-D)
3. Type of Case : New
4. Details of previous NOC: Letter No. : Nil
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 25/05/2022
7. Name of the Inspecting Officer : Sarabjeet Singh ADO (MN)
8. Name and designation of Officer  
From the building side : Mr. Anirudh Kumar (Owner/Partner)
9. Year of Construction
10. Applicant's application no. : 2022052110847 dated 21/05/2022

M/s. Standard Sweets & restaurant is running at Ground floor in a Building comprised of Ground Floor only.

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements/Gazzette Notification 24/02/2021	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	06 m 5 m NA	Provided On Road NA	MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>Upper floors</li> <li>Basements</li> </ul>	NA NA	NA NA	NA NA
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper floors</li> <li>Basements</li> </ul>	NA NA	NA NA	NA NA
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	NA NA	NA NA	NA NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1.5m each	1 x 1.77cms, 1x1.50cms	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	NA NA	NA NA	NA NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	4 nos. CO2 & WCO2 ISI marked	Provided Provided Provided	MR MR MR
6.	First - Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	1 30 m 5 mm	Provided Provided Provided	MR MR MR

25

7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOFEA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	1	Provided	MR
	• Hose Box	1	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level	NA	NA	NA
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	20, 000 litres	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

PM



N-14

The fire protection systems provided in the building were checked and found functional at the time of inspection. The Shortcomings issued by this department vide Letter no. F6/DFS/MS/WZ/2020/347 Dated- 07/04/2020, F6/DFS/MS/MN/2021/241 dated 24/05/2021 & F6/DFS/MS/MN/2022/EH/269 dated 28/03/2022 have been compiled.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

~~Do (west)~~

~~26/5/22~~

163/ABD/MN  
26/05/2022

Signature of the Inspecting Officer  
Name: - Sarabjeet Singh  
Designation: - A.D.O. (MN)

~~26/05/2022~~

D.O. (WEST) S.S.Y.  
DATED: 20/05/2022

~~Defo (WZ)~~

~~07/6/2022~~

~~Cafe~~

~~3/6/2022~~

~~Director~~  
~~6/06/2022~~

~~DO/W~~

F.T. please

~~6/6~~

~~ADD (MN)~~

Sir,

F.T. is put up for your perusal & sig. pls.

~~07/06/2022~~