

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001

No. F.6/DFS/MS/EH/2022/SZ/ 255

Dated: 10/06/2022

FIRE SAFETY CERTIFICATE

Certified that the **M/s Dolly Farms & Resorts Pvt Ltd. (Restaurant)** located at 439, Village Shahoopur, Fatehpur Beri, New Delhi 110074 comprised of Ground Floor only owned/occupied by Mr. Gursharan Singh Chhabra was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/EH/2018/SZ/111 dated 19/01/2018. The premises was re-inspected by the officer concerned of this department on 07/06/2022 in the presence of Mr. Paresh Tyagi and found that the said farm house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class - **D "Assembly Building (Restaurant)** with effect from 10/06/2022 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....10/06...../2022 at New Delhi by.

(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to:-

1. M/s Dolly Farms & Resorts Pvt Ltd. (Restaurant) located at 439, Village Shahoopur, Fatehpur Beri, New Delhi 110074.
2. The Dy. Health Officer, Public Health Department, SDMC, South Zone, Green Park, New Delhi 110016. (MHA Portal ID MHA Portal ID 2021121728806 Dated 18/12/2021)
3. The Joint CP (Lic/Branch) 1st Floor, P.S Defence Colony, New Delhi 110049

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

119

INSPECTION REPORT

1	Name & Address of the Building	M/s Dolly Farms & Resorts Pvt Ltd. (Restt) 439, Village Shahoorpur , Fatehpur Beri, New Delhi-74		
2	Type of Occupancy	Assembly Building Group 'D' (Restaurant)		
3	Building Comprised of	Ground floor only		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH/2018/SZ/111 dated 19/01/2018		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	07/06/2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Paresh Tyagi		
10	Year of construction	1994		
11	Applicant letter No.	MHA Portal ID 2021121728806 Dated 18/12/2021		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Required	9 mtr	MR
	• Gate width	Required	5 mtr	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	-NA-	-NA-	-NA-
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floor	-NA-	-NA-	-NA-
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	-NA-	-NA-	-NA-
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	2m	2 m & 1.5 m (02 Exit)	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4	Smoke Management system.			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
5	Fire Extinguishers.			
	• Total numbers	04Nos	04 Nos	MR
	• Types	ABC & CO2	ABC & CO2	MR
	• ISI Marking	Required	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	Required Hose-reel	01 nos	MR
	• Length of hose-reel hose.		30 m	MR
	• Nozzle Diameter		5 mm	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-

N/11

19	Fire Control Room.			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any.	No		-NA-

The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view the substantial satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to renew Fire Safety Certificate issued vide letter no. F6/DFS/MS/EH/2018/SZ/111 dated 19/01/2018 under rule 37 of the Delhi Fire Service Rules, 2010.

Accordingly, DFA is put up for approval and signature please.

Handwritten signature and date: 14/8/2022

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Designation: ADO (BCP)

~~DO (SD)~~

Handwritten signature and date: 07/06/22

Handwritten initials: F.T.

Handwritten signature and date: DCFO/SZ

Handwritten signature and date: 8/6

Handwritten signature: ADO (B/P)

As approved, F.T. letter is put up for your signature pl

Handwritten signature and date: 14/9/2022

Handwritten signature and date: DCFO/SZ

Handwritten signature: M.S. EU