

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/BNQT/WZ/2022/ 27

Dated: 03 / 06 / 2022

FIRE SAFETY CERTIFICATE

Certified that the M/s. MG Maharaja Palace Banquet, Located at Plot No. 45, 45 35, Punjabi Bagh West, New Delhi - 110026 is running at Ground & First floor with seven Guest rooms on Second floor in a Building comprised of Basement + Stilt + Ground + 02 Upper floor. Owned/Occupied by M/s. MG Maharaja Palace Banquet, was issued FSC vide letter no. F6/DFS/MS/2019/WZ/1150 dated 30/05/2019. The premises was inspected by the officer concerned of this department on 18-05-2022 in the presence of Sh. Mukesh Goel (Owner) and observed that all the fire prevention and fire safety arrangements provided in the premises/ building found in good working condition. The premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the said building is fit for occupancy class "Assembly" Group D with effect from 03/06/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 conditions mentioned Overleaf.

Issued on 03/06/2022 at New Delhi by.

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to: -

1. The owner/ Occupier, M/s. MG Maharaja Banquet, Plot No. 45, 45 35, Punjabi Bagh West, New Delhi - 110026.
2. The Dy. Health Officer, SDMC, West Zone, Vishal Enclave, Rajouri Garden, New Delhi - 110027. (dhwestzone@gmail.com)
3. The Joint Commissioner of Police. Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi. (addlcp.lic-dl@nic.in)

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The Stilt floor shall not be used for banquet purpose.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building		MG Maharaja Palace Banquets, Plot No. 45, Road No. 35, West Punjabi Bagh, New Delhi-110026.		
2. Type of Occupancy		Assembly (Banquet Hall)		
3. Type of Case		Renewal		
4. Details of previous NOC		F6/DFS/MS/2019/WZ/1150 dated 30/05/2019		
5. Fire Safety directives letter No		Nil		
6. Date of inspection		18/05/2022		
7. Name of the Inspecting Officers		Sarabjeet SinghADO(MN)		
8. Name and designation of officers from the building side		Sh. Mukesh Goel (Owner)		
9. Year of Construction		2014 (As per prev. Insp. Rep. dtd.- 30/05/2019)		
10. Applicant's letter No.		Online Application ID No. 2022042508250 dated 25/04/2022		
The said Banquet Hall is running at Ground floor & 1 st floor with Seven Guest rooms on second floor in a Building comprised of Basement + Stilt + Ground + 02 upper floors.				
S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC Requirement/ As per prev. Insp. Rep. dtd.-30/05/2019	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	9 m	Provided	MR
	• Gate width	On Main Road	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	Provided	MR
	• Basements	02	Provided	MR
	b. Width of staircases			
	• Upper Floors	1 X 2m,1 X 1m	2m & 1.5m Provided	MR
	• Basements	1 X 2m,1 X 1m	2m & 1.5m Provided	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NR	NR	NR
	e. No. of continuous staircases to terrace	02	Provided	MR
	f. Width of Corridor	NA	NA	NA
	g. Door Size	1 x 2m, 1x1m	Provided	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5	Fire Extinguishers			
	• Total numbers	15	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NR	Provided	NR
	• Location of Main Panel	NR	Provided	NR
	• Location of Repeater Panel	NR	Provided	NR
	• Alternate source of power	NR	Provided	NR
	• Hooters' Location	NR	Provided	NR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• Upper Floor	NR	Provided	MR
	• Sprinkler above false ceiling	NR	Provided	MR
11	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NR	NR	NR
	➤ Head of Main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey Pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR
	➤ Auto Starting/ Manual stopping	NR	NR	NR
	➤ Pump House Access	NR	NR	NR
	• Terrace level			
	➤ Discharge of pump	2 X 450lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NR	NR	NR
	➤ Draw-off connection	NR	NR	NR
	➤ Fire service inlet	NR	NR	NR
	➤ Access to tank	NR	NR	NR
	• Overhead Tank capacity	15,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR

N-41

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NR	NR	NR
	• Pressurization of Lift lobby	NR	NR	NR
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/2019/WZ/1150 dated 30/05/2019 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

156/ADO/MN
23/05/2022

(Signature)

(Signature)
23/5/22

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

D.O. (WEST)/508
DATED: 23/05/2022

(Signature) 23/05/2022
Defo (WZ)

(Signature) Sir, F.T is put up for your perusal & signature
Please. *(Signature)*
26/5/22

(Signature)
msc

Upwaded

(Signature)
09/06/2022