

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2022/SZ/622

Dated: 10/06/2022

FIRE SAFETY CERTIFICATE

Certified that the SantNirankari Public School, 20-B Block, Tilak Nagar, New Delhi-110018 comprised ground plus three upper floors owned/occupied by SantNirankari Public School was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/school/2019/SZ/1575 dated- 06/08/2019. The school building was re- inspected by the officer concerned of this department on 26/05/2022 in the presence of Smt. Leena Kapoor (HM) and found that school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules 2010 and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of **three years**, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on..... 10/06/2022 ..... at New Delhi.



(SUNIL CHAUDHARY)  
Dy. CHIEF FIRE OFFICER

O/C R<sub>11</sub>

Copy to:-

1. The Manager,  
SantNirankari Public School,  
20-B Block, Tilak Nagar, New Delhi-110018.
2. Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws whenever approved from concerned department.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/20

**INSPECTION REPORT**

1. Name & address of the building : Sant Nirankari Public School, 20-B Block, Tilak Nagar, New Delhi-18
2. Building comprised of : Ground plus three upper floors.
3. Type of Occupancy : Educational
4. Type of Case : ~~New~~ Renewal
5. Details of Previous NOC : F.6 DFS/MS/School/2019/SZ/1575 dated 06/08/19
6. Fire Safety directives letter No : UBBL/NBC
7. Date of inspection : 26/05/2022
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers  
From the building side : Smt. Leena Kapoor (HM)
10. Year of Construction : 2005 (GF & FF) & 2017 (SF & TF)
11. Applicant's letter No. : Nil dated 28/04/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements UBBL/NBC	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	06 m 4.5 m N/A	Provided Directly accessible from road N/A	M/R M/R N/A
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	02 No.'s N/A	04 No.'s N/A	M/R N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	1.50 m N/A	1.80 (2 No's), 1.20 & 1.10 m N/A	M/R N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	Two	Provided	M/R
	e. Width of Corridor	1.50 m	Provided	M/R
	f. Door Size	1.0 m on GF & FF 1.20 m on SF & TF	Provided	M/R
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	N/A Required	N/A Natural ventilation provided	N/A M/R
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• ISI marking</li> </ul>	03 no's/floor ABC/CO <sub>2</sub> type ISI marked	Provided Provided Provided	M/R M/R M/R

f-






U/22



16.	Provision of Lifts.	No Lift		
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A



The fire protection systems provided in the building were ~~test~~ checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the Rules the FSC was issued vide letter no. F.6/DFS/MS/school/2019/SZ/1575 Dated-06/08/2019 renewal under the Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

  
 Signature of Inspecting Officer  
 Name:- R.K. Yadav  
 Designation:- Asstt. Divisional Officer

Divisional Officer (South West)

  
 11/6/22 F.T.  
  
 Dyefo (S2)

ADD/SKB  
 FT helter & put up for signature please  
  
 Dyefo (S2)  
 M-5-Cell  
  
 8/6/22