

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001




No.F6/DFS/MS/School/NDZ/2022/ 625

Dated:- 10 /06/2022

**FIRE SAFETY CERTIFICATE**

Certified that the **Shankar Public School** located at **Main Road Mandawali, Delhi-92** building comprised of **Ground + 02 Upper floor, School running at Ground + 01 upper floor** owned/occupied by Shankar Public School has already been issued Fire Safety Certificate vide letter No. **F6/DFS/MS/School/2018/NDZ/1486 dated 25/06/2018**. The premises was re-inspected by the officer concerned of this department on 02/06/2022 in the presence of the Mr. Alok Chaudhary (Owner) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the **Circular No. 262-362 dated 17/01/2005** and found that the building is fit for occupancy of class **Group B "Educational Building," for Ground + 01 upper floors only** with effect from -----  
10/06/2022 renewed for a period of three years, subject to conditions printed below.

Issued on ...10/06/2022..... at New Delhi by.

  
**(Dr. S.K. Tomar)**  
Dy. Chief Fire Officer  
Delhi Fire Service  
ok  
MD

Copy to:-

1. The Director of Education,  
Government of N.C.T. Delhi,  
Old Sectt. Delhi – 110054.
2. The Principal,  
Shankar Public School,  
Main Road Mandawali, Delhi-92.

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

**INSPECTION REPORT**

- |  |   |
|--|---|
| 1. Name & address of the building                            | Shankar Public School at Main Road<br>Mandawali, Delhi-92                       |
| 2. Type of occupancy:-                                       | Educational Group-B<br>Gr. + 02 Upper floor (School running at G+01 floor only) |
| 3. Type of case:-  | Renewal   |
| 4. Details of previous FSC:-                                 | F6/DFS/MS/School/2018/NDZ/1486 dated 22/06/2018                                 |
| 5. Fire safety directives No.-                               | Circular No. 262-362 dated 17/01/2005   |
| 6. Date of inspection:-                                      | 02/06/2022  |
| 7. Name of the inspecting officer:-                          | Sh. Manoj Kumar Sharma (ADO/CC)   |
| 8. Name & designation of officer<br>From the building side:- | Mr. Alok Chaudhary ( Owner )  |
| 9. Year of construction:-                                    | 1994  |
| 10. Applicant's letter No:-                                  | nil dated 06/05/2022  |

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement circular 1.3.11	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06mtr.	06 mtr.	MR ✓
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 nos.	02 nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.25 m & 1.10 m	1.25 m & 1.10 m	MR ✓
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	1.5 mtr.	1.5 mtr.	MR ✓
	F. Door size	1.0 mtr.	1.0 mtr.	MR ✓
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	04 Nos.	04 Nos.	MR ✓

	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	ISI marked	ISI marked	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01 no.	01 no.	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	220 LPM	450 LPM	MR /
	b) Head of pump	40 mtr	40 mtr	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A

MAD

	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	2500 ltrs.	2500 ltrs.	MR ✓
15.	Exit Signage.	N/A	N/A	N/A
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/2018/NDZ/1486 dated 22/06/2018, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.


Signature of the Inspecting Officer

*M.K. Sharma*  
3/6

Name :- M.K. Sharma  
Designation :- ADO (LN)

D.O (ED) *[Signature]*  
31/6/2022

Dy CPO (NDZ)  
*[Signature]*  
8/6/22



*[Signature]*  
F.T. letter is put up for org. pl

*[Signature]*  
*[Signature]*  
9/6/22

*[Signature]*  
08/6

ms