

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No. F6/DFS/MS/NDZ/2022/ 218

Dated:-14.06.2022

FIRE SAFETY CERTIFICATE

Certified that the **M/S Shankar Automobile Petrol Pump , at Bhai Veer Singh Marg, Gole Market, New Delhi** comprised of ground and mezzanine floor owned/occupied by **M/S Shankar Automobile** was earlier granted FSC by this department vide letter No.F6/DFS/MS/2011/145 dated 02/06/2011. Now, the premises was re-inspected by the officer concerned of this department on 02/06/22 in the presence of Mr. Aditya Chugh and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Hazardous (Group J)** with effect fromfor period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.



(Dr. S.K.Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Sh. Ramesh Kumar, Dir (Health license /MOH Room No 1002 Palika Kendra, New Delhi
2. The Manager, M/S Shankar Automobile (Petrol pump), at Bhai Veer Singh Marg, Gole Market, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. This FSC is valid only for petrol filling station.
2. All the fire safety arrangements provided in the building shall be maintained in good working condition.
3. "No Smoking" and "Not to use Mobile Phone" sign board should be displayed in such a manner as to be easily readable by all persons.
4. All the petroleum rules and comments of the Chief Inspector of Explosive should strictly adhered to and no trade Susceptible to Cause Ignition Petroleum vapors by generating heat, mechanical/electric spark should be allowed within the premises and its vicinity.
5. The working employed at the petrol pump must be taught the correct method of operation and maintenance of record of the extinguishers be ensured.
6. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
7. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/19

INSPECTION REPORT

1. Name & address of the building M/S Shanker Automobile petrol pump Bhai Veer Singh Marg. Gole Market New Delhi
2. Type of occupancy:- Hazardous Group J
3. Type of case:- Ground + Mezzanine floor
4. Details of previous FSC:- Renewal
F6/DFS/MS/2011/145 dated 02/06/2011
5. Fire safety directives No.- N/A
6. Date of inspection:- 02/06/22
7. Name of the inspecting officer:- Sh.Ravinder Singh (ADO/CC)
8. Name & designation of officer From the building side:- Mr. Aditya Chugh
9. Year of construction:-
10. Applicant's letter No:- e-mail -shankarauto@hotmail.com dated 09/05/2022.

Old Case

| S.No. | Minimum Standards on fire Prevention and fire safety U/R 33 | Requirement /Existing arrangements | Provided at site | Remarks MR/NMR |
|---|---|--|---------------------------------------|----------------|
| 1. Access to Building | | | | |
| | 1) Road width | 06 mtr. | 15 mtr. | MR |
| | 2) Gate width | Accessible | Accessible Directly | MR |
| | 3) Width of internal road | N/A | N/A | N/A |
| 2. Number, Width Type & Arrangement of Exits | | | | |
| A. Number of staircases | | | | |
| | 1. Upper floors | 01 nos | 01 nos | MR |
| | 2. Basements | N/A | N/A | N/A |
| B. Width of staircase | | | | |
| | 1. Upper floors | 1.0m | 1.0 m | MR (old case) |
| | 2. Basements | N/A | N/A | N/A |
| C. Protection of exits | | | | |
| | 1. Fire check door | N/A | N/A | N/A |
| | 2. Pressurization | N/A | N/A | N/A |
| D. No. of continuous staircase to terrace | | | | |
| | | N/A | N/A | N/A |
| E. Width of corridor | | | | |
| | | N/A | N/A | N/A |
| F. Door size | | | | |
| | | N/A | N/A | N/A |
| 3. Compartmentation | | | | |
| | 1) Fire check door | N/A | N/A | N/A |
| | 2) Sealing of electrical shafts | N/A | N/A | N/A |
| | 3) Fire rating of shaft door | N/A | N/A | N/A |
| | 4) Water curtain | N/A | N/A | N/A |
| | 5) Fire Dampers | N/A | N/A | N/A |
| 4. Smoke Management System | | | | |
| | 1) Basements | N/A | N/A | N/A |
| | 2) Upper floors | N/A | N/A | N/A |
| 5. Fire Extinguishers | | | | |
| | 1) Total numbers | 10 Nos. | Provided | MR |
| | 2) Types | ABC, CO ₂ , mech. foam ext. | ABC, CO ₂ , mech foam ext. | MR |
| | 3) ISI marking | Required | Provided | MR |
| 6. First-Aid Hose Reel | | | | |
| | 1) Total number of each floor | N/A | N/A | N/A |

M/20

| | | | | |
|------------|---|----------------------|--------------------------|-----|
| | 2) Length of hose reel hose | N/A | N/A | N/A |
| | 3) Nozzle diameter | N/A | N/A | N/A |
| 7. | Automatic Fire Detection & Alarming System | | | |
| | 1) Type of detectors | N/A | N/A | N/A |
| | 2) Location of main panel | N/A | N/A | N/A |
| | 3) Location of repeater panel | N/A | N/A | N/A |
| | 4) Alternate source of power | N/A | N/A | N/A |
| | 5) Hooter's Location | N/A | N/A | N/A |
| 8. | MOEFA | N/A | N/A | N/A |
| 9. | Public Address System | N/A | N/A | N/A |
| 10. | Automatic Sprinkler System | | | |
| | 1) Basement | N/A | N/A | N/A |
| | 2) Upper floors | N/A | N/A | N/A |
| | 3) Sprinkler above false ceiling | N/A | N/A | N/A |
| 11. | Internal Hydrants | | | |
| | 1) Size of riser/down-comer | N/A | N/A | N/A |
| | 2) Number of hydrants per floor | N/A | N/A | N/A |
| | 3) Hose box | N/A | N/A | N/A |
| 12. | Yard Hydrants | | | |
| | 1) Total number of hydrants | N/A | N/A | N/A |
| | 2) Hose box | N/A | N/A | N/A |
| 13. | Pumping Arrangement | | | |
| | 1) Ground level | N/A | N/A | N/A |
| | a) Discharge of main pump | Bosting arrangements | provided | MR |
| | b) Head of main pump | N/A | N/A | N/A |
| | c) Number of main pump | N/A | N/A | N/A |
| | d) Jockey pump out put | N/A | N/A | N/A |
| | e) Jockey pump head | N/A | N/A | N/A |
| | f) Stand by pump output | N/A | N/A | N/A |
| | g) Stand by pump head | N/A | N/A | N/A |
| | h) Auto starting/Manual stopping | N/A | N/A | N/A |
| | 2) Terrace level | | | |
| | a) Discharge of pump | N/A | N/A | N/A |
| | b) Head of pump | N/A | N/A | N/A |
| | c) Power supply | N/A | N/A | N/A |
| | d) Auto starting of pump | N/A | N/A | N/A |
| 14. | Captive Water Storage for Fire Fighting | | | |
| | 1) Under ground tank capacity | 10,000 & 7,000 liter | Provided | MR |
| | a) Draw-off connection | N/A | N/A | N/A |
| | b) Fire service inlet | N/A | N/A | N/A |
| | c) Access to tank | N/A | N/A | N/A |
| | d) Over head tank capacity | N/A | N/A | N/A |
| 15. | No Smoking Signage English & Hindi | Required | Provided English & Hindi | MR |



N/21

| | | | | |
|-----|--|-----|-----|-----|
| 16. | Provision of Lifts. | | | |
| | a) Pressurization of lift shaft | N/A | N/A | N/A |
| | b) Pressurization of lift lobby | N/A | N/A | N/A |
| | c) Communication in lift car | N/A | N/A | N/A |
| | d) Fireman's switch | N/A | N/A | N/A |
| | e) Lift signage | N/A | N/A | N/A |
| 17. | Stand by Power Supply | N/A | N/A | N/A |
| 18. | Refuge Area | N/A | N/A | N/A |
| | Total area location | N/A | N/A | N/A |
| 19. | Fire Control Room | N/A | N/A | N/A |
| | a) Detector system panel | N/A | N/A | N/A |
| | b) Flow switch panel | N/A | N/A | N/A |
| | c) PA system panel | N/A | N/A | N/A |
| | d) Battery backup | N/A | N/A | N/A |
| | e) Building floor plan | N/A | N/A | N/A |
| 20. | Special Fire Protection System for Protection of special Risk, if any: Provided Fire buckers with sand. | | | MR |

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, we may renew the FSC issued F6/DFS/MS/2011/145 dated 02.06.2011. Accordingly reply letter is prepared and put up for kind perusal and signature please.

Signature of the Inspecting Officer

[Handwritten Signature]
3/6/22

Name: - Ravinder Singh
Designation: - ADO (CC)

DO/CD *[Handwritten Signature]*
3/6/22

Dyefo (CC) *[Handwritten Signature]*
3/6/22

ADO (CC)

As approved prospectus for new raised and repairs work done

Dyefo (CC) *[Handwritten Signature]*
6/6/22

MS

