

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/NDZ/ Audi/ 2022/ 260

Dated : 14/06/2022

FIRE SAFETY CERTIFICATE

Certified that the **Auditorium at Lady Hardinge Medical College, New Delhi** comprised of **Basement + Ground + 01 Upper floors** was earlier granted FSC by this department vide letter No. F6/DFS/MS/2017/Hospital/1689 dated 20.11.2017. **Now**, the premises was re-inspected by the officer concerned of this department on 31/05/22 in the presence of Sh. Rajkumar (A E) , Sh. Ranjeet (J E), CPWD and found that the said building has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Building Group D** with effect from 14/06/2022 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 14/06/2022 at New Delhi by.



(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Director, Lady Harding Medical College & Associated Hospital, New Delhi.
2. The Chief Architect, NDMC, Palika Kendra, New Delhi.
3. The Executive Engineer, CPWD Lady Hardinge Medical College & Associated Hospital, New Delhi

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. Any inflammable for interior decoration shall strictly be prohibited.

INSPECTION REPORT

1. Name & address of the building : Auditorium at Lady Hardinge Medical College, New Delhi
2. Type of occupancy : Assembly Building (**Auditorium**)
Basement + Ground + 01 Upper floors
3. Type of case:- : Renewal
4. Details of previous NOC : F6/DFS/MS/2017/Hospital/1689 dated 20/11/2017.
5. Fire safety directives No. : N/A
6. Date of inspection:- : 31/05/2021
7. Name of the inspecting officer : Sh. Ravinder Singh ADO/CC,
Sh. Rajinder Atwal DO/CD
8. Name & designation of officer
From the building side : Sh. Rajkumar (A.E) & Sh Ranjeet , JE
9. Year of construction : 1986
10. Applicant's letter No : e- mail < director-lhmc@gov.in dated 17.05.2022

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	09 mtr.	09 mtr.	MR
	2) Gate width	06 mtr.	06 mtr.	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 No.	02 No.	MR
	2. Basements	02 No.	03 No.	MR
	B. Width of staircase			
	1. Upper floors	1.0 mtr.	1.14 mtr. each	MR(old case)
	2. Basements	1.0 mtr.	02 Nos. 1.14 mtr. & 01 Nos. 1.20 mtr.	MR(old case)
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	2.0 mtr.	2.0 mtr.	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	Exhaust fan	MR
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	10 Nos.	12 Nos.	MR
	2) Types	ABC & CO2	ABC, CO2 &	MR

	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	02	02	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors/ beam & smoke	Required	Provided	MR
	2) Location of main panel	Gr. Floor	Provided	MR
	3) Location of repeater panel	Required	Provided	MR
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors (stage)	N/A	Provided	N/A
	3) Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	1) Size of riser/down-comer	150 MM	150 MM	MR
	2) Number of hydrants per floor	02	02	MR
	3) Hose box each floor	02	02	MR
12.	Yard Hydrants			
	1) Total number of hydrants	02	02	MR
	2) Hose box	02	02	MR
13.	Pumping Arrangement	Common fire pump of main	Building	
	1) Ground level			
	a) Discharge of main pump	2850 LPM	2850 LPM	MR
	b) Head of main pump	90 mtr.	90 mtr.	MR
	c) Number of main pump	02	02	MR
	d) Jockey pump out put	200 LPM	200 LPM	MR
	e) Jockey pump head	80 mtr.	80 mtr.	MR
	f) Stand by pump output	2850 LPM	2850 LPM	MR
	g) Stand by pump head	90 mtr.	90 mtr.	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting (U/G tank Common)			
	1) Under ground tank capacity	1,00,000 ltr.	2,00,000 ltr.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR

N/10

	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			NA

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, if agreed, The FSC issue vide letter no. F6/DFS/MS/2017/Hospital/1689 dated 20.11.2017 may be renewed, accordingly renewal of fire Safety Certificate under rule 37 of the Delhi Fire Service Rules 2010 / is recommended for approval please.

Signature of the Inspecting Officer

Rajinder Singh 3/6/22

Name :- Rajinder Singh
Designation :- DO (CD)

Signature of the Inspecting Officer

Ravinder Singh 3/6/22

Name :- Ravinder Singh
Designation :- ADO (CC)



Dy. C.F.O. (MS)

QSTomer 6/6/22

ADO (CC) AS requested in part for Rule renewal and signature please

Dy. C.F.O. (MS) *QSTomer* 8/6/22

PAS

[Signature]