

46

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/EH/2022/SZ/160

Dated. 06/06/2022

FIRE SAFETY CERTIFICATE

Certified that **M/s Aerocity Social** (A Unit of Impresario Entertainment and Hospitality Pvt Ltd) located at **Shop No 060708, Ground Floor, Woldmark-1, Assest Area No 8, Hospitality District, IGI Airport Delhi 110037** in the building comprised of 03 Tire Basement, Mezzanine, Ground plus 06 upper floor owned/occupied by A Unit of Impresario Entertainment and Hospitality Pvt Ltd have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of this department on 30/05/2022 on in the presence of Mr. Ajay Sharma and that the premise is fit for occupancy class **Group-D Assembly Building** (Restaurant running at 03 Floor only) with effect from 06 / 06 / 2022 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 06 / 06 / 2022 at New Delhi by


(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Dy. Health Officer, Public Health Department, South Zone, Najafgarh Zone, Najafgarh, Delhi-110043 (MHA Portal No. 202204208354 dated 26/04/2022)
2. M/s Aerocity Social (A Unit of Impresario Entertainment and Hospitality Pvt Ltd) Shop No 060708, Ground Floor, Woldmark-1, Assest Area No 8, Hospitality District, IGI Airport Delhi 110037

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	M/s Aerocity Social (A Unit of Impresario Entertainment and Hospitality Pvt Ltd) located at Shop No 060708, Ground Floor, Woldmark-1, Assest Area No 8, Hospitality District , IGI Airport Delhi 110037		
2	Type of Occupancy	Group-D Assembly Building. (Restaurant at GF only)		
3	Building Comprised of	03 tier Basements, Mezzanine, Ground + 06 Floors		
4	Type of Case	New Case		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	F6/DFS/MS/Mixed/SZ/2020/533 dated 21/12/2020 World Mark-1		
7	Date of Inspection	30/05/2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Ajay Sharma		
10	Year of construction	2015		
11	Applicant letter No.	MHA Portal ID No 202204208354 dated 26/04/2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	UBBL/NBC-2016 Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building. (World Mark-1- F6/DFS/MS/Mixed/SZ/2020/533 dated 21/12/2020)			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Restt. within World Mark-3	Provided by Mall N/A N/A	MR N/A N/A
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase	Provided & Maintained by World Mark-1		
	➤ Upper floors.	Restt within Mall	As above	MR
	➤ Basement floor.	N/A	N/A	N/A
	b) Width of Staircase	Provided & Maintained by World Mark-1		
	➤ Upper floors	Restt within Mall	As above	MR
	➤ Basement floor	N/A	N/A	N/A
	c) Protection of exits	Provided & Maintained by World Mark-1		
	➤ Fire check door	Restt within Mall	As above	MR
	➤ Pressurization	Restt within Mall	As above	MR
	d) No. of continuous staircase to terrace	Restt within Mall	-NA-	MR
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	1.50 mtr each	1.50 m & 1.50 m	MR
3	Compartmentation.	Provided & Maintained by World Mark-1		
	• Fire check door.	Restt within Mall	As above	MR
	• Sealing of electrical shafts.	Restt within Mall	As above	MR
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.	Provided & Maintained by World Mark-1		
	• Basement	30 ACPH	N/A	N/A
	• Upper floors	12 ACPH	Exhaust Fans Provided	MR
5	Fire Extinguishers.			
	• Total numbers	Required	06 Nos	MR
	• Types	ABC/CO ₂	ABC & CO ₂	MR
	• ISI Marking	Required	Provided	MR
6	First Aid Hose Reels.	Provided & Maintained by World Mark-1		
	• Total numbers on each floor.	One near Restt	As above	MR
	• Length of hose-reel hose.	30m	As above	MR
	• Nozzle Diameter	5mm	As above	MR
7	Automatic fire detection & alarming system	Provided & Maintained by World Mark-1		
	• Type of detectors	Required	Smoke & heat	MR
	• Location of Main Panel	Required	As above	MR
	• Location of Repeater Panel	Required	As above	MR
	• Alternate source of power	Required	As above	MR

N/5

	• Hooter's location	Required	As above	MR
8	MOEFA	Required	Provided	MR
9	Public Address System	N/A	As above	MR
10	Automatic Sprinkler System	Provided & Maintained by World Mark-1		
	• Basement	Required	As above	MR
	• Ground floor.	Required	As above	MR
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants.	Provided & Maintained by World Mark-1		
	• Size of Riser/Down-comer	Required	As above	MR
	• Number of Hydrant per floor	One near Restt	As above	MR
	• Hose box.	One near Restt	As above	MR
12	Yard Hydrants.	Provided & Maintained by World Mark-1		
	• Total number of hydrants.	N/A	As above	N/A
	• Hose box.	N/A	As above	N/A
13	Pumping arrangements.	Provided & Maintained by World Mark-1		
	• Ground Level	Common pumping arrangements for entire complex		
	➤ Discharge of main pump.	N/A	2280 LPM	N/A
	➤ Head of main pump.	N/A	105m	N/A
	➤ Number of main pumps.	N/A	02 Nos.	N/A
	➤ Jockey Pump output.	N/A	2 x 180 LPM	N/A
	➤ Jockey Pump head.	N/A	105m	N/A
	➤ Standby Pump output.	N/A	2850 LPM	N/A
	➤ Standby Pump head.	N/A	105m	N/A
	➤ Auto Starting/Manual Stopping.	N/A	Provided	N/A
	➤ Pump house access.	N/A	Provided	N/A
	• Terrace Level			
	➤ Discharge of pump.	9000 LPM	As above	MR
	➤ Head of pump.	40 m	As above	MR
	➤ Power supply.	Required	As above	MR
	➤ Auto starting of pump.	Required	As above	MR
14	Captive water storage for fire fighting.	Provided & Maintained by World Mark-1		
	• Underground tank capacity.	N/A	1,00,000 Ltrs	N/A
	➤ Draw-off connection.	N/A	Provided	N/A
	➤ Fire Service Inlet.	N/A	Provided	N/A
	➤ Access to tank.	N/A	Provided	N/A
	• Overhead tank capacity.	20,000 ltrs	20,000 Ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	Provided & Maintained by World Mark-1		
	• Pressurization of lift shaft.	N/A	As above	N/A
	• Pressurization of lift lobby.	N/A	As above	N/A
	• Communication in lift car.	N/A	As above	N/A
	• Fireman's switch.	N/A	As above	N/A
	• Lift signage.	N/A	As above	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room.	Provided & Maintained by World Mark-1		
	• Detector system panel.	N/A	As above	N/A
	• Flow switch panel.	N/A	As above	N/A
	• PA system panel.	N/A	As above	N/A
	• Battery backup.	N/A	As above	N/A
	• Building floor plan.	N/A	As above	N/A
20	Special Fire Protection System for the	N/A	NA	N/A

N/G

Protection of special Risk, if any.

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010

14/3/2022

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Designation: ADO (BCP)

DO (SD) - on leave

By 14/3/22

14/3/22

G.O.

14/3/2022

Director

14/3/2022

Pls

14/3/22

F.t. letter is put up for signature please

14/3/22

Director 14/3/22

mm

uploaded

06/06/2022