

C/36

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2022 | BNOT. | 28

Dated: 13/6/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s Amora Banquet Hall located at **Ground & 1st Floor** Khasra No. 72/6/1, Plot No.2, Data Ram Marg, Palam Extension, New Delhi in a building comprised of Basement + Ground + 3 Upper Floors owned/ occupied by **M/s Amora Banquet Hall** have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 25-02-2022 in the presence of Sh. Vijender Solanki (Owner) and found that the said building that the premises is fit for occupancy class "Assembly" Group D (**At ground & 1st Floor only**) with effect from 13/06/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 13/06/2022 at New Delhi by.


Ajul Garg
Director
Delhi Fire Service

Copy to:

1. Sh. Vijender Solanki, M/s Amora Banquet Hall located at Ground & 1st Floor Khasra No. 72/6/1, Plot No.2, Data Ram Marg, Palam Extension, New Delhi.
2. Deputy Health Officer, Health Department, SDMC, Dhansa stand, Najafgarh, New Delhi – 110043

Following fire safety directives must be adhered to:-

1. **The kitchen at terrace shall not be reconstructed/ repaired again in future.**
2. **The Banquet shall be run at Ground floor & First floor only.**
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

2112

Re inspection to see the compliance of shortcomings communicated vide letter dated 17/12/2020

INSPECTION REPORT

1. Name & address of the building: M/s Amora Banquet Hall located at Ground & 1st Floor Khasra No. 72/6/1, Plot No.2, Data Ram Marg, Palam Extension, New Delhi.
2. Type of Occupancy : **Assembly (At Ground + 1st Floor)**
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives L. No : F-6/MS/BP/2020/BNQT/2497 dated- 14/10/2020
6. Date of inspection : 25/02/2022
7. Name of the Inspecting Officer : DO / SW & ADO (DWK)
8. Name and designation of Officer
 - a. from the building side : Sh. Vijender Solanki (Owner)
9. Year of Construction : 2019
10. Applicant's letter No. : Email Dated 03/06/2022

Plot Area = 843.88 m²
Covered Area = 705m²
(At each Floor)

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 m	18 m Provided	MR
	• Gate width	5 m	On Road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2 Provided	MR
	• Basements	2	2 Provided	MR
	b. Width of staircases			
	• Upper floors	2m, 1.5m	2m & 150cm	MR
	• Basements	2m, 1.5m	3m & 150cm	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	NA	147cm	NA
	f. Door Size	2m, 1.5m	GF=2m & 2.4m FF= 2m & 1.5m	MR

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	Required at Basement	Provided	MR
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	Required	Provided	MR
	<ul style="list-style-type: none"> • Upper floors 	Required	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	15 nos.	Provided	MR
	<ul style="list-style-type: none"> • Types 	ABC & CO2	Provided	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	01	Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	Required	Provided	MR
	<ul style="list-style-type: none"> • Location of Main Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> • Location of Repeater Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> • Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> • Hooters' Location 	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	Required	Provided	MR
	<ul style="list-style-type: none"> • Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	150 mm	Provided	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	1	Provided	MR
	<ul style="list-style-type: none"> • Hose Box 	1	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	01 Provided	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	01 Provided	NA

13. Pumping Arrangements			
<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	2280 lpm	Provided	MR
	70m	Provided	MR
	1	Provided	MR
	180lpm	Provided	MR
	70m	Provided	MR
	2280lpm	Provided	MR
	NA	Provided	MR
	Required	Provided	MR
	Required	Provided	MR
	900 lpm	Provided	MR
	40 m	Provided	MR
	Required	Provided	MR
	Required	Provided	MR
14. Captive water Storage for fire fighting			
<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	200000 L	Provided	MR
	Required	Provided	MR
	Required	Provided	MR
	Required	Provided	MR
	10,000 ltrs	Provided	MR
15. Exit Signage	Required	Provided	MR
16. Provision of Lifts (Lift Shall run from Ground to uppers Floors)			
<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
	NA	NA	NA
	Required	Provided	MR
	Required	Provided	MR
	Required	Provided	MR
17. Standby power supply	Required	Provided	MR
18. Refuge Area			
<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
	NA	NA	NA
19. Fire control room			
<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA

N/15

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules 2010.

Note: - The temporary kitchen seen at terrace has been damaged. Partially removed as shown in photos. (Placed at c/s to c/172)

9/6/22
 Sign. of the Inspecting Officer
 Name Sh. Ved Pal
 Designation DCSU

10/6/22
 Sign. of the Inspecting Officer
 Name Uday Vir Singh
 Designation AD/DSP

Dyefo (SZ) [Signature]
 [Signature] 9/6

C.F.O. 1- In Photos, I could not understand either it is kitchen or some other occupancy. whereas you are saying it is damaged kitchen.
 2. You re-examine/inspect and put up clearly FSC as per law.

Dy CFO (SZ) [Signature]
 9/6/2022

DO (SW)

Sir
 It was used as a kitchen but now it has been completely vacated and wall also removed. Resubmitted

Please [Signature] 10/6/22
 Dyefo (SZ) [Signature]