

924

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/School/2022/ 644

Dated: 14/06/2022

FIRE SAFETY CERTIFICATE

Certified that the building of INFANT JESUS School Located at Qutab Vihar Phase-1 Near Dwarka Sector-19B New Delhi-110071, comprised of G + 1UF owned/occupied by INFANT JESUS School was issued Fire Safety Certificate vide this department vide letter no. F.6/DFS/MS/School/2019/SZ/260 Dated 01/02/2019. The premises was re inspected by the officer concerned of this department on 24/05/2022 in the presence of Fr. Jomy John (School Representative) and found that premises have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular 3298-3398 Dated 01/03/2011 and that the building is fit for occupancy class B "Educational building" with effect from 14/06/2022 for a period of three years.

Issued on ...14/06/2022 at New Delhi by.



(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service.

Copy to:

1. INFANT JESUS School Located at Qutab Vihar Phase-1 Near Dwarka Sector-19B New Delhi-110071.
2. Directorate of Education Old Secretariat Delhi - 110054.

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: INFANT JESUS School Located at Qutab Vihar Phase-I Near Dwarka Sector-19B New Delhi-110071
2. Type of Occupancy : Educational (G + IUF)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/2019/SZ/260 Dated 01/02/2019
5. Fire Safety directives Letter No. : Circular. No 3298-3398 Dated 01/03/2011
6. Date of inspection : 24/05/2022
7. Name of the Inspecting Officer : Udai vir singh ADO (DWK)
8. Name and designation of Officer

| |
|--------------------------|
| No. of Students= 840 |
| No. of class rooms=35 |
| Plot area=10117 sqmtr |
| Covered area= 4047 sqmtr |

from the building side : Fr. Jomy John (School Representative)

9. Year of Construction : GF 2014 & 1st floor 2017
10. Applicant's letter No. : IJS/FIRE/2022-23/1 Dated - 08/04/2022

| S No | Minimum standards on fire prevention and fire safety U/R 33 | As per N/5 | Provided at site | Remarks MR/NMR |
|------|---|-----------------------|-------------------------------|---------------------|
| 1. | Access of building | | | |
| | • Road width | 06 mtrs | Provided | MR |
| | • Gate width | 4.5 | Directly accessible from road | MR |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | 02 Nos. | 02 Nos. | MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper floors | 1.5 mtr | 3 m Each & 1 Ramp | MR (being old case) |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No of continuous staircase to terrace | 01 Nos. | 01 Nos. | MR |
| | e. Width Of Corridor | 150cm | 260cm | MR |
| | f. Door Size | 01 mtr & 120cm | Provided | MR |
| 3. | Compartmentation | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4. | Smoke managements System | | | |
| | • Basements | NA | NA | NA |
| | • Upper floors | NA | NA | NA |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 4 nos.each floor | Provided | MR |
| | • Types | ABC & CO ₂ | Provided | MR |
| | • IS marking | ISI marked | ISI marked | MR |

2/10

| | | | | |
|-----|--|----------|----------|----|
| 6. | First- Aid Hose Reels | | | |
| | • Total numbers on each floor | NA | NA | NA |
| | • Length of hose reel hose | NA | NA | NA |
| | • Nozzle diameter | NA | NA | NA |
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detectors | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |
| 8. | MOEFA | NA | NA | NA |
| 9. | Public Address System | NA | NA | NA |
| 10. | Automatic Sprinkler System | | | |
| | • Basements | NA | NA | NA |
| | • Upper Floor | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11. | Internal Hydrants: | | | |
| | • Size of riser/down- comer | NA | NA | NA |
| | • Number of hydrants per floor | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 13. | Pumping Arrangements: | | | |
| | • Ground Level | | | |
| | • Discharge of main pump | NA | NA | NA |
| | ➤ Head of main pump | NA | NA | NA |
| | ➤ Number of main pumps | NA | NA | NA |
| | ➤ Jockey pump out put | NA | NA | NA |
| | ➤ Jockey pump head | NA | NA | NA |
| | ➤ Standby Pump out put | NA | NA | NA |
| | ➤ Standby Pump Head | NA | NA | NA |
| | ➤ Auto Starting/Manual stopping | NA | NA | NA |
| | ➤ Pump House Access | NA | NA | NA |
| | • Terrace level | | | |
| | ➤ Discharge of pump | NA | NA | NA |
| | ➤ Head of the pump | NA | NA | NA |
| | ➤ Power supply | NA | NA | NA |
| | ➤ Auto starting of pump | NA | NA | NA |
| 14. | Captive water Storage for fire fighting: | | | |
| | • Under ground tank capacity | NA | NA | NA |
| | ➤ Draw off connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | NA | NA | NA |
| 15. | Exit Signage | Required | Provided | MR |
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | NA | NA | NA |
| | ➤ Pressurization of lift lobby | NA | NA | NA |
| | ➤ Communication in lift Car | NA | NA | NA |
| | ➤ Fireman's Grounding Switch | NA | NA | NA |
| | ➤ Lift Signage | NA | NA | NA |
| 17. | Standby power supply | NA | NA | NA |

n/11

| | | | | |
|-----|--|----------|--|----|
| 18. | Refuge Area | | | |
| | ➤ Total area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19. | Fire control room | | | |
| | ➤ Detector system panel | NA | NA | NA |
| | ➤ Flow Switch Panel | NA | NA | NA |
| | ➤ PA System Panel | NA | NA | NA |
| | ➤ Battery backup | NA | NA | NA |
| | ➤ Building Floor Plans | NA | NA | NA |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | Required | ABC fire extinguisher provided near electric meter | MR |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F/6/DFS/MS/School/2019/SZ/260 Dated 01/02/2019 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Name *Uday Vir Singh*

Designation *ADDO/DWJ*

Dolsto
ADDO
11/6/22
Dycho (SZ) *F. 7*

ADDO/DWJ

Sio AP letter is put up for sig b/c

ADDO
11/6/22

Dycho/SZ

M.S. cell