

C-42

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110001

No.F6/DFS/MS/School/2022/SZ/ 648

Dated: 15/06/2022

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Girls Sr. Sec. School**, Ghumanhera, New Delhi-110073, Comprised of ground plus one upper floor only and MP Hall, owned/occupied by Govt. Girls Sr. Sec. School have complied with the fire prevention and fire safety requirements in accordance with the Rules 33 of the Delhi Fire Service Rules 2010 and verified by the officer concerned of this department on 27/05/2022 in the presence of Smt. Sunita (Vice-Principal) and found that the school building (**Ground plus one upper floor only except MP Hall**) is fit for occupancy class B 'Educational Building' for with effect from 15/06/2022 for a period of **three years** in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 15/06/2022 at New Delhi by


(Atul Garg)
Director
Delhi Fire Service
94-1

Copy to:-

1. The Principal, Govt. Girls Sr. Sec. School, Ghumanhera, New Delhi-110073.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat, New Delhi-54.

Following fire safety directives must be adhered to:-

1. This certificate is not valid for occupancy of Multipurpose Hall.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. There shall not be more than 45 children in the classrooms having single door.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
10. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/19

INSPECTION REPORT

1. Name & address of the building : Govt. Girls Sr. Sec. School, Ghumanhera, New Delhi-110073
 2. Building comprised of : Ground plus one upper floor and MP Hall
 3. Type of Occupancy : Educational
 4. Type of Case : New
 5. Details of Previous NOC : N/A
 6. Fire Safety directives letter No : DFS Act & Rules 2010
 7. Date of inspection : 27/05/2022
 8. Name of Inspecting Officer : A.D.O. R.K.Yadav
 9. Name and designation of officers
 From the building side : Smt. Sunita (Vice-Principal)
 10. Year of Construction : 2016-17
 11. Applicant's letter No. : SV/GH/2022/3303 dated 12/05/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible 06 m 4.5 m N/A	06 m Provided N/A	MR MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	03 No.'s N/A	03 No.'s N/A	MR N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	1.50 m N/A	1.50 m N/A	MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace			
		02 No.'s	02 No.'s	MR
		1.50 m	2.25 m	MR
	e. Width of Corridor			
		1.0 m in CR & 2.0 m in MP Hall	.98 to 1.0 m (Double door) in CR & 1.80 m (02 no.'s) in MP Hall	MR in CR & NMR in MP Hall
	f. Door Size			
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	N/A Required	N/A Natural ventilation provided	N/A M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	20 no.'s ABC/CO ₂ type ISI marked	Provided Provided Provided	MR MR MR

N/20

(for MP Hall)

6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers Length of hose reel hose Nozzle diameter 	One 30 m 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level (for MP Hall) <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A 450 LPM 30 mtrs. Required Required	N/A Provided Provided Provided Provided	N/A MR MR MR MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity (for MP Hall) 	N/A N/A N/A N/A 5,000 ltrs.	N/A N/A N/A N/A 10,000 ltrs	N/A N/A N/A N/A MR
15.	Exit Signage. (In MP Hall)	Required	Provided	MR

10

N/21

		No Lift		
16.	Provision of Lifts.	N/A	N/A	N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply			
18.	Refuge Area.	N/A	N/A	N/A
	➤ Total Area ➤ Location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection. The shortcomings issued vide letter no.F.6/DFS/MS/School/2019/SZ/5672 dated 19/09/2019 has been rectified except door width of MP Hall.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety as required under the Rule 35 of the Delhi Fire Service Rules 2010 it is recommended to grant Fire Safety Certificate, *except MP Hall.*

R.K. Yadav
 Signature of Inspecting Officer
 Name:- R.K.Yadav
 Designation:- Asstt. Divisional Officer

Divisional Officer (South West)

1/16/22
Dy. Insp (S/S)
h
2/6
CFO
3/6/2022
Director
3/06/22

ASW
6/6
 ADD (JNK/BR)