

C-64

FORM 'H'  
 FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
 [Refer sub - rule (1) of rule 35]  
 GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
 HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
 NEW DELHI

No.F6/DFS/MS/School/2022/ SWZ | 643

Dated: 14/06 /2022

**FIRE SAFETY CERTIFICATE**

Certified that the Building Venkateshwar International School, Located at Sector 10, Dwarka, New Delhi 110075 comprised of Basement + Ground + 3 Upper Floors, was issued FSC vide Letter No. F6/DFS/MS/School/2017/SZ/94 Dated 16/01/2018. The premises was re inspected by the officers concerned of this department on 03/06/2022 in the presence of Dr. Manisha Sharma (Principal) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance Directorate of Education GNCT of Delhi Circular Dated 01/03/2011 and that the school building is fit for occupancy class-B "Educational"( At **Ground & 03 Upper Floors only**) with effect from 14/06/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 14/06/2022 at New Delhi by.

(Sunil Chaudhary)  
Dy. Chief Fire Officer  
Delhi Fire Service

14/06/22

Copy to:

1. The Principal Venkateshwar International School, Located at Sector 10, Dwarka, New Delhi 110075.
2. Directorate of Education Old Secretariat Delhi – 110054.

**Following fire safety directives must be adhered to:-**

1. The temporary rooms at terrace shall not be reconstructed/ repaired again & reoccupy in future.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. **Basement shall be used strictly as per building bye laws**
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

1123  
**INSPECTION REPORT**

1. Name & address of the building: Venkateshwar International School, Located at Sector 10, Dwarka, New Delhi 110075.
2. Type of Occupancy : Educational (Basement + Ground+ 3 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2017/SZ/94 Dated 16/01/2018
5. Fire Safety directives Letter No. : NBC/Directorate of Education/F16/Estate/CC/Fire Safety/2011/3298-3398 Dated 01/03/2011
6. Date of inspection : 03/06/2022
7. Name of the Inspecting Officer : DO / SW & ADO (DWK)
8. Name and designation of Officer  
from the building side : Dr. Manisha Sharma (Principal)
9. Year of Construction : 2001
10. Applicant's letter No. : Email Dated 09/05/2022

No. of Students=3000+
No. of class rooms=97
Plot area= 16187 sq mtr
Covered area=6000 sqm
No of labs = 08

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/11	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	20 mtr	MR
	• Gate width	4.5 mtr	2X 5.5 mtr	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	4 Nos.	4 Nos.	MR
	• Basements	02 Nos.	02 Nos.	MR
	b. Width of staircases			
	• Upper floors	1.5 m	Provided (Old case)	MR(Being old case)
	• Basements	1.5 mtr & 01 mtr	1.5 mtr & 1.25 mtr	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02 Nos.	02 Nos.	MR
	e. Width Of Corridor	1.25m	1.5 mtr to 3 mtr	MR
	f. Door Size	01 mtr	1. mtr to 1.10 mtr	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c charge	Raised basement	MR
	• Upper floors	12 a/c charge	Natural ventilation	MR

*(Signature)*





14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> <li>Under ground tank capacity</li> </ul>	Old case	50,000 ltr	MR
	<ul style="list-style-type: none"> <li>➤ Draw off connection</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>	15,000 ltrs	20,000 ltr	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Pressurization of lift lobby</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Communication in lift Car</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Fireman's Grounding Switch</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Lift Signage</li> </ul>	Required	Provided	MR
17.	Standby power supply	Required	DG set 160 & 125 KVA	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> <li>➤ Total area</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Location</li> </ul>	NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> <li>➤ Detector system panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Flow Switch Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ PA System Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Battery backup</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Building Floor Plans</li> </ul>	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2, Fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F6/DFS/MS/School/2017/SZ/94 Dated 16/01/2018 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note:- The temporary rooms seen at terrace has been damaged/ partially removed & electric supply has been disconnected!

Sign. of the Inspecting Officer  
 Name *Sh. Veer Pal*  
 Designation *D/S*

Sign. of the Inspecting Officer  
 Name *H. V. Singh*  
 Designation *AD/D/2*

*Dyego (\$2) F.T.*

*AD/D/2*

*Site of letter is put up for info plz*

*Dyego/SL*

*M. S. Cell*

*AD/D/2*