


FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No.F.6/DFS/MS/BNQT/2022/NDZ/ 29

Dated: 20/06/2022

FIRE SAFETY CERTIFICATE

Certified that the Amar Palace (Banquet Hall) located at 512, Jheel Khuranja, Geeta Colony Chowk, Delhi-110051 in a building comprised of Ground Floor, 1st Floor & 2nd Floor (SPS / Temporary structure) only but Banquet Hall is running on ground & 1st Floor owned / occupied by Amar Place was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2017/NDZ/321 dated 08/03/2017. The premises was re-inspected by the officer concerned of Fire Service on 13/06/2022 in the presence of Sh. Parminder Singh and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class Assembly (Banquet Hall) with effect from 20/06/2022 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 20/06/2022 at New Delhi by

(Atul Garg)
DIRECTOR

Copy to :-

1. Mr. Parminder Singh, Amar Palace (Banquet Hall) located at 512, Jheel Khuranja, Geeta Colony Chowk, Delhi-110051.
2. Joint Commissioner of Police(Lic.), 1st Floor, PS Defence Colony, New Delhi-110049.

Conditions for the validity of Fire Safety Certificate:

1. **Fire Safety Certificate is valid for Ground & 1st Floor only.**
2. All the means of escape / entry / exit shall be kept free from any obstruction.
3. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
4. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
5. All the staff members must know the correct method of operation of fire fighting system.
6. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.

N/23
INSPECTION REPORT

1. Name & address of the building: Amar Palace (Banquet Hall), 512, Jheel Khuranja, Geeta Colony Chowk, Delhi-110051.
2. Building Comprised of : Ground Floor, 1st Floor & 2nd Floor (SPS / Temporary structure) but Banquet Hall is running on Ground & 1st Floor only)
3. Type of Occupancy : Assembly (Banquet Hall)
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/2017/NDZ/321 dated 08/03/2017
6. Fire Safety directives Letter No. : F6/DFS/MS/BP/2013/878 dated 01/03/2013
7. Date of inspection : 13/06/2022
8. Name of the Inspecting Officer : A.K. Jaiswal, D.O. (East)
9. Name and designation of Officer from the building side : Sh. Parminder Singh
10. Year of Construction : 2013
11. Applicant's letter No. : Nil dated 12/05/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 m	17 m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.5 m	1.5 m each	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	2m x 2	2.2 m & 2 m	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	4	6	M/R
	• Types	ABC/CO ₂	Provided	M/R
	• ISI marking	Required	Provided	M/R

AKJ

N/24

6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30 Mtr.	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Ground Floor	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down- comer	100mm	Provided	MR
	• Number of hydrants per floor	1	Provided	MR
	• Hose Box	1	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	15,000 ltr	Provided	MR

25


15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:- 1. Building comprised of Ground Floor, 1st Floor & 2nd Floor (SPS shed / Temporary structure) which is existing since 2001 as per the self assessment property tax for (2008-2009) attached at C/58. 2nd floor was earlier used as residence and now being used as storage.

2. Fire Safety Certificate has already been issued for Ground floor & 1st Floor only.
3. Owner / Occupier has submitted an undertaking that he will not use 2nd floor for banquet purpose (attached at C/62).

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. MCB and Conduit Metal Wiring has also been provided.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/2017/NDZ/321 dated 08/03/2017 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.



DY CPO (NDZ) Addition/alteration Com.

[Signature]
13/6/22

CFO *[Signature]*
14/6/2022

Director *[Signature]*
14/06/2022

DO (CFO)

[Signature]

[Signature]
15/6/22

P.T.O.

[Signature]
13/06/22
Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : D.O. (East Division)