

E38

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No. F6/DFS/MS/EH/WZ/2022/183

Dated: 20/06/2022

**FIRE SAFETY CERTIFICATE**


Certified that the M/s. Deck of Spices (A Unit of M/s Saburi Ventures) running at Ground floor in a building comprised of Basement, Ground plus three upper floors, located at I-5 & 6, Kailash Park, Kirti Nagar, New Delhi 110015, was granted fire safety certificate by this department vide letter no F.6/DFS/MS/EH/2021/25 dated 03.02.2021 (for Ground floor only). The premises was re-inspected by the officer concerned of this department on 14.06.2022 in the presence of Sh. Daruk Gupta (owner) and found that the owner have added first floor and now the restaurant is running at Ground & First floor and complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D (Restaurant) **(For Ground & First floor only)** with effect from 20/06/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Conditions printed overleaf.

Issued on 20/06/2022 at New Delhi by.

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to:

1. The owner/occupier, M/s. Deck of Spices (A Unit of M/s Saburi Ventures) Ground & First floor, I-5 & 6, Kailash Park, Kirti Nagar, New Delhi 110015 (**Reference: - ID No. 2020112708693 dated: - 05/05/2022**)
2. The Dy. Health Officer, West Zone, SDMC, Public Health Department, Vishal Enclave, New Delhi. ([dhowestzone@gmail.com](mailto:dhowestzone@gmail.com))
3. The Joint Commissioner of Police, Licensing Unit, 1<sup>st</sup> floor, Police Station, Defence Colony, New Delhi. ([addlep.lic-dl@nic.in](mailto:addlep.lic-dl@nic.in))

  
18/6/22

Following Fire Safety Directives must be adhered to: -

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate through MHA portal (<https://www.delehlhlic.gov.in>) along with a copy of this certificate, six months prior to its expiry.
8. This FSC is valid for Ground & First Floor (Restaurant) only.

**INSPECTION REPORT**

1. Name & address of the building: M/s. Deck of Spices (A unit of M/s. Saburi Ventures), GF-FF, 1-5 & 6, Kailash Park, Kirti Nagar, New Delhi
2. Type of Occupancy : Assembly
3. Type of Case : New Case- Addition of first floor
4. Details of previous NOC : F.6/DFS/MS/EH/2021/25 dt 03.02.2021- for GF only
5. Fire Safety directives Letter No. : N/A
6. Date of inspection : 14.06.2022
7. Name of the Inspecting Officer : Sarabjeet Singh, ADO (Moti Nagar)
8. Name and designation of Officer  
From the building side : Sh. Daruk Gupta, Owner
9. Year of Construction : 1999 (as uploaded on MHA portal)
10. Applicant's email date : Online ID- 202012708693

M/s. Deck of Spices is running on ground floor & first floor in a building comprised of basement, ground plus three upper floors.

| S No | Minimum standards on fire prevention and fire safety U/R 33 | Requirements as per Rule 35 (6) of DFS Act- 2007 | Provided at site | Remarks MR/NMR |
|------|---|--|------------------|----------------|
| 1.   | Access of building  |  |                  |                |
|      | • Road width  | 06 mtrs  | Provided         | MR             |
|      | • Gate width  | 4.5 mtrs   | Provided         | MR             |
|      | • Width of internal road                                    | NA   | NA               | NA             |
| 2.   | Number, width, Type & Arrangements of exits:                |  |                  |                |
|      | a. Number of staircases                                     |  |                  |                |
|      | • Upper floors  | 02   | 02               | MR             |
|      | • Basements   | NA   | NA               | NA             |
|      | b. Width of staircases                                      |  |                  |                |
|      | • Upper floors  | 1.5 mts each                                     | Provided         | MR             |
|      | • Basements   | NA   | NA               | NA             |
|      | c. Protection of exits                                      |  |                  |                |
|      | • Fire check door   | NA   | NA               | NA             |
|      | • Pressurization  | NA   | NA               | NA             |
|      | d. No of continuous staircase to terrace                    | 02   | Provided         | MR             |
|      | e. Width Of Corridor  | NA   | NA               | NA             |
|      | f. Door Size  | 02 x 1.5 mts                                     | Provided         | MR             |
| 3.   | Compartmentation  |  |                  |                |
|      | • Fire check door   | NA   | NA               | NA             |
|      | • Sealing of electrical shafts                              | NA   | NA               | NA             |
|      | • Fire Rating of shaft door                                 | NA   | NA               | NA             |
|      | • Water Curtain   | NA   | NA               | NA             |
|      | • Fire Dampers  | NA   | NA               | NA             |
| 4.   | Smoke managements System:                                   |  |                  |                |
|      | • Basements   | 30 a/c per hour                                  | NA               | NA             |
|      | • Upper floors  | 12 a/c per hour                                  | Provided         | MR             |

|     |   |   |  |  |
|-----|---|---|--|--|
| 5.  | Fire Extinguishers  |   |  |  |
|     | <ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>  | 12 nos.<br>ABC & CO <sub>2</sub><br>ISI marked  | Provided<br>Provided<br>Provided   | MR<br>MR<br>MR   |
| 6.  | First – Aid Hose Reels:   |   |  |  |
|     | <ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>  | 01<br>30 m<br>5 mm  | Provided<br>Provided<br>Provided   | MR<br>MR<br>MR   |
| 7.  | Automatic fire detection and alarming system:   |   |  |  |
|     | <ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>   | NA<br>NA<br>NA<br>NA<br>NA  | NA<br>NA<br>NA<br>NA<br>NA   | NA<br>NA<br>NA<br>NA<br>NA   |
| 8.  | MOEFA   | Required  | Provided   | MR   |
| 9.  | Public Address System   | NA  | NA   | NA   |
| 10. | Automatic Sprinkler System:   |   |  |  |
|     | <ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>   | NA<br>NA<br>NA  | NA<br>NA<br>NA   | NA<br>NA<br>NA   |
| 11. | Internal Hydrants:  |   |  |  |
|     | <ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>   | 100 mm<br>01<br>01  | Provided<br>Provided<br>Provided   | MR<br>MR<br>MR   |
| 12. | Yard Hydrants   |   |  |  |
|     | <ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>  | NA<br>NA  | NA<br>NA   | NA<br>NA   |
| 13. | Pumping Arrangements:   |   |  |  |
|     | <ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main Pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Staring/Manual stopping</li> <li>Pump House Access</li> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul> | NA<br>NA<br>NA<br>NA<br>NA<br>NA<br>NA<br>NA<br>NA<br>NA<br>450 LPM<br>40 m<br>Required<br>Required | NA<br>NA<br>NA<br>NA<br>NA<br>NA<br>NA<br>NA<br>NA<br>NA<br>Provided<br>Provided<br>Provided<br>Provided | NA<br>NA<br>NA<br>NA<br>NA<br>NA<br>NA<br>NA<br>NA<br>NA<br>NA<br>MR<br>MR<br>MR<br>MR |
| 14. | Captive water Storage for firefighting:   |   |  |  |
|     | <ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>  | NA<br>NA<br>NA<br>NA<br>20,000 Its  | NA<br>NA<br>NA<br>NA<br>Provided   | NA<br>NA<br>NA<br>NA<br>MR   |
| 15. | Exit Signage  | Required  | Provided   | MR   |
| 16. | Provision of Lifts  |   |  |  |



|    |  |          |   |    |
|----|--|----------|---|----|
|    | • Pressurization of Lift Shaft   | NA       | NA  | NA |
|    | • Pressurization of lift lobby   | NA       | NA  | NA |
|    | • Communication in lift Car  | NA       | NA  | NA |
|    | • Fireman's Grounding Switch   | NA       | NA  | NA |
|    | • Lift Signage   | NA       | NA  | NA |
| 17 | Standby power supply   | Required | Provided                                      | MR |
| 18 | Refuge Area  |          |   |    |
|    | • Total area   | NA       | NA  | NA |
|    | • Location   | NA       | NA  | NA |
| 19 | Fire control room  |          |   |    |
|    | • Detector system panel  | NA       | NA  | NA |
|    | • Flow Switch Panel  | NA       | NA  | NA |
|    | • PA System Panel  | NA       | NA  | NA |
|    | • Battery backup   | NA       | NA  | NA |
|    | • Building Floor Plans   | NA       | NA  | NA |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | Required | 02 ABC type fire extinguishers found provided | NA |

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, it is recommended to grant fire safety certificate under Delhi Fire Service Act- 2007 & Rules- 2010.

DFA is put up for approval & signature please.

~~DO (must)~~

~~Signature~~  
15/06/2022

Signature of the Inspecting Officer  
Name: Sarabjeet Singh  
Designation: ADO (Moti Nagar)

DO (must) 569  
DATE: 15/6/2022

Signature  
15/6/2022

DCFB (12)

Signature  
16/6/2022

CFD

Signature  
16/6/2022

Director  
Signature  
17/06/2022

Signature  
ADO (M.N.)

Signature  
18/6/2022