

491

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/2022/ 290

Dated: 20/06/2022

FIRE SAFETY CERTIFICATE

Certified that the **Hotel Vardhmaan Inn** located at **1519 to 1523, Part of GF,FF,SF,TF& above, Gali no-27, SK Dass Road, Naiwala, Karol Bagh, New Delhi**, comprised of Ground + 03 upper floor, Ground (reception + shop + 02 guest rooms), 1st floor (06 guest rooms), 2nd floor (07 guest rooms), 3rd floor (07 guest rooms) and terrace pantry for staff & temporary shed, total 22 guest rooms was earlier granted FSC by this department vide letter No.F6/DFS/MS/GH/NDZ/2018/1641 dated 13/07/18 (in the name of Vardhmaan at 1521/27) . Now, the premise was re-inspected by the officer concerned of this department on 25/05/22 in the presence of Sh. Sanjeev Kumar Punj and found that the said guest house building **having an undertaking submitted by owner dated 06.08.2021 regarding not to use pantry, kitchen, at terrace floor for any purpose**, has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential, Sub Division-Ground (reception), 1st floor (06 guest rooms), 2nd floor (07 guest rooms), 3rd floor (07 guest rooms) total 20 guest rooms up to third floor only** with effect from 20/06/2022 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 20/06/2022 at New Delhi by.


16/6/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Commissioner, MCD, Civic Centre, New Delhi. to ensure the occupancy as detailed above & deviation if any.
2. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi.
Online id 2022052909758 dated.09.05.2022 &email id<punjsanjeevkumar@gmail.com>dated 16.05.22
3. The Manager,
Hotel Vardhmaan Inn 1519 to 1523, Part of GF,FF,SF,TF Gali no-27, SK Dass Road, Naiwala, Karol Bagh, New Delhi.

Condition for the validity of Fire Safety Certificate

1. This FSC shall stand null and void if numbers of lodgers are found more than 10 at any one floor.
2. FSC issued earlier vide letter no. FS/MS/GH/NDZ/2021/312 dated 13.08.2021 shall stand null and void.
3. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
4. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
5. The trained fire fighting staff should be available round the clock.
6. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
7. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
9. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
10. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
11. Any flammable material for interior decoration is prohibited.

11/27
INSPECTION REPORT

1. Name & address of the building Hotel Vardhmaan Inn 1519 to 1523, Part of GF,FF,SF,TF& above, Gali no-27, SK Dass Road, Naiwala, Karol Bagh, New Delhi.
2. Type of occupancy:- Residential, Sub Division-A-I
Gr. + 03 Upper floors (total 20 Guest rooms)
Ground (reception + shop + other portion), 1st floor (06 guest rooms), 2nd floor (07 guest rooms), 3rd floor (07 guest rooms) and terrace pantry for staff & temporary shed having an undertaking submitted by dated 06.08.2021 not to use pantry, kitchen at terrace for any purpose
3. Type of case:- Renewal
4. Details of previous FSC:- No. F6/DFS/MS/GH/NDZ/2018/1641 dated 13/07/18.
5. Fire safety directives No.- N/A
6. Date of inspection:- 25/05/22
7. Name of the inspecting officer:- Sh. Ravinder Singh ADO/CC)
8. Name & designation of officer
From the building side:- Sh. Sanjeev Kumar Punj
Before 2005
9. Year of construction:- Before 2005
10. Applicant's letter No:- Online id 2022052909758 dated.09.05.2022 & email id<punjsanjeevkumar@gmail.com>dated 16.05.22 & undertaking dated 03.06.22

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	Accessible	12 mtr.	N/A
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 Nos.	01 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	105 cms	105 cms	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No of continuous staircase to terrace	01	01	MR
	E. Width of corridor	1.0 mtr.	1.43 mtr.	MR
	F. Door size	1.0 mtr.	81 cm x 207 cm	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	Required	provided	MR

5.	Fire Extinguishers			
	1) Total numbers	02 at each floor	Provided	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01	Provided	MR
	2) Length of hose reel hose	30 mtr.	Provided	MR
	3) Nozzle diameter	05 mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors CO Type	Required	provided	MR
	2) Location of main panel	Ground floor	provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	provided	MR
	5) Hooter's Location	Each floor	provided	MR
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	30 mtr.	30 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A

2/27

	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	5000 ltr.	4000 ltr.	MR Old case
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection. Further FSC issued earlier vide letter no. FS/MS/GH/NDZ/2021/312 dated 13.08.2021 shall stand null and void.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/GH/NDZ/2018/1641 dated 13/07/18, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended for approval up to third floor.

Signature of the Inspecting Officer

[Signature]
 Name :- Ravinder Singh
 Designation :- ADO (CC)

[Signature]
 Do/cd
 7/6/22

[Signature]
 Dy.CFS (AD2)

Pl speak. No of rooms applied.

[Signature]
 8/6/22

[Signature]
 1. Spoken on 14/6/22.
 2. Resubmitted please.

[Signature]
 Dy.CFS (AD2)

[Signature]
 14/6/22

ADO (CC)

