

916

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F6/DFS/MS/2022/EH/ 184

Dated: 21/06/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s MY SKY (A Unit of MNGV Venture LLP) located at **Second Floor Plot No. B-51, G.T. Karnal Road, Industrial Area, Delhi-110033** in a building comprised of basement, ground and 02 upper floors owned/occupied by M/s MY SKY (A Unit of MNGV Venture LLP) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on **13.06.2022** in the presence of **Mr. Gaurav Mendiratta (Partner)** and that the building/ premise is fit for occupancy Class **Assembly (Restaurant)** at **second floor only** with effect from - 21/06/2022 for a period of **03 (Three) years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 21/06/2022 at New Delhi by

(Atul Garg)
 Director

Ph-011-23414000

Conditions for the validity of Fire Safety Certificate:

- 1 This Fire Safety Certificate is valid only for restaurant at second floor for assembly occupancy only. In case of any violation, this FSC will be treated as null & void.
- 2 All the means of escape/entry/exit shall be kept free from any obstruction.
- 3 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 4 All the staff members must know the correct method of operation of firefighting system.
- 5 The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
- 6 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 7 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : M/s MY SKY (A Unit of MNGV Venture LLP) at Plot No.B-51, Second floor
G.T. Karnal Road, Industrial Area, Delhi-110033.
2. Type of Occupancy : Restaurant (Assembly)
3. Composition of building : (Basement, Ground + 02 upper floors), basement, ground & first floor other property
and **Restaurant running at second floor only**
4. Type of Case : New Case
5. Details of previous NOC : Nil
6. Fire Safety directives letter No : Nil
7. Date of inspection : 13.06.2022
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Mr. Gaurav Mendiratta (Partner)
10. Year of Construction : 2020
11. Applicant's letter No. : Online MHA Portal I D No. 2022041106601 Dated: 07.05.2022
12. Covered area : 265sqm

	Minimum Standards on fire prevention and fire safety U/R 33	UBBL/NBC-2016 requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06	12m approx...	MR
		4.5m	4.5m	MR
		NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	02 NA	02 NA	MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	1.5m NA	1.80m & 1.50m NA	MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA NA	NA NA	NA NA
	d. No. of continuous staircases to terrace	02	02	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.5m	1.80m & 1.50m	MR
	3	Compartmentation.		
<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	NA	NA	NA	
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	12 a/c per hour	NA	NA
		12 a/c per hour	Natural Ventilation	MR
5	Fire Extinguishers			

	<ul style="list-style-type: none"> Total numbers Types ISI marking 	06nos	08nos	MR
		ABC/Co2	ABC-08	MR
		Yes	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	Required	Provided	MR
		30m	Provided	MR
		5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Required	Provided	MR
		Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		Required	Provided	MR
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100mm	Provided	MR
		01	Provided	MR
		01	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		180lpm	Provided	MR
		40m	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450lpm	450lpm	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR

14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		20,000ltr Required	Provided	MR
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
Required		Provided	MR	
17	Standby power supply			
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
		N/A	N/A	N/A
➤ Location				
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
NA		NA	NA	
20	Special Fire Protection Systems for Protection of special Risks, if any:			

Note:-

(a) The total covered area of the second floor Restaurant is 265sqm (Approx) including seating area, toilet area, kitchen area,

(b) As per the NBC Part IV, the number of occupants comes out to be approx 147 person's i.e. (265/1.8=147)

The fire protection systems provided in the building were tested/ checked and found some in working order at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Do (18/6)

By cfo, w3

18/06/2022

19/06/2022

Signature of the Inspecting Officer

Name: - C.L. Meena

Designation:- ADO/RN

cfo

Director

17/06/2022

19/06/22

Conf... P.T.O.