

425

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.


No.F.6/DFS/MS/School/2022/SZ/ 606

Dated: 01/06/2022

FIRE SAFETY CERTIFICATE

Certified that the building of Sarvodaya Kanya Vidyalaya No.1, Sagarpur, New Delhi - 110046, is having Six Blocks i.e. A & B block ground plus one & C,D & F block ground plus two upper floors & E block (MP Hall) ground floor only. Owned/occupied by Sarvodaya Kanya Vidyalaya No.1 was issued Fire Safety Certificate by this department vide letter No F.6/DFS/MS/2011/School/3501 dated 14.12.2011 for three blocks. The School building was re-inspected by the officer concerned of this department on 12/05/2022 in the presence of Smt. Shakuntla Panchal (Principal) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises (Except MP Hall) is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed as under.

Issued on.....01/06/2022..... at New Delhi.


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Principal,
Sarvodaya Kanya Vidyalaya No.1,
Sagarpur, New Delhi -110046.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/S

INSPECTION REPORT

- Name & address of the building : Sarvodaya Kanya Vidyalaya No.-1, Sagarpur, New Delhi-110046.
- Building comprised of : 6 blocks namely A & B Block (G+1), C, D & F Block (G+2), & E block is having ground floor only.
- 3. Type of Occupancy : Educational
- 4. Type of Case : New/Renewal
- 5. Details of Previous NOC : F.6/DFS/MS/School/2014/SZ/1585 dated 15.12.2014 (for GF & G+1 block only)
- 6. Fire Safety directives letter No : N/A
- 7. Date of inspection : 12/05/2022
- 8. Name of Inspecting Officer : A.D.O. R.K.Yadav
- 9. Name and designation of officers
From the building side : Sh. Shakuntla Panchal (Principal)
- 10. Year of Construction : GF Blk-1985, Admn. Blk-2011 & 2016-17
- 11. Applicant's letter No. : SKV-1/SP 2022/215 dated 27/04/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per FSC dt. 15.12.2014 & UBBL/NBC	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible 06 mtrs 4.5 mtrs N/A	06 mtrs 4.7 mtrs N/A	M/R MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02 No.'s in A, B & F blk & 03 no.'s in C blk & D blk	02 No.'s in A, B & F blk & 03 no.'s in C & D blk	M/R
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floor	1.5 m & .75 m	1.59 & 1.52 m in A Blk, 1.85 m & .75 in B blk, 1.5, 1.75 & 1.80 m in C blk, 1.55 m (03 no.'s) in D blk & 2X 1.50 m & 1X1.5 (02 no.'s) in F blk,	M/R
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	Required	One/Two	M/R
		1.5 m	2.07/1.75 m	M/R
	f. Door Size	1.0 m in A, B, C, D & F block & 2.00 m in E block (i.e. MP Hall)	1.0 m (double doors) in B & C blk, 1.10 m (double doors) in D blk, 1.00 & 1.10 m in F blk & 1.65 m (03 no.'s) in E blk	M/R in A, B, C, D & F blk & NMR in E blk (i.e. MP hall)
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Natural ventilation provided	M/R
5.	Fire Extinguishers			
	• Total numbers	36 no's	Provided	M/R
	• Types	ABC/CO ₂ type	Provided	M/R
	• IS marking	ISI marked	Provided	M/R

N/16



6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	Required in C, D & F blocks	Provided	M/R
	<ul style="list-style-type: none"> Length of hose reel hose 	30 mtrs	Provided	M/R
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	M/R
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hooters' Location 	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Ground Floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Number of hydrants per floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Head of Main pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Number of main pumps 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey pump head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Pump House Access 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	450 LPM in C, D & F blocks	Provided	M/R
	<ul style="list-style-type: none"> ➤ Head of the pump 	40 mtrs	Provided	M/R
	<ul style="list-style-type: none"> ➤ Power Supply 	Required	Provided	M/R
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	Required	Provided	M/R
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Draw-off connection 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Fire service inlet 	N/A	Provided	N/A
	<ul style="list-style-type: none"> ➤ Access to tank 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Overhead Tank capacity 	10,000 ltrs in C, D & F blocks	Provided	M/R
15.	Exit Signage	Required	Provided	M/R

15

N/17

Provision of Lifts.		No Lift		
M/R	• Pressurization of Lift Shaft	N/A	N/A	N/A
M/R	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.	N/A	N/A	N/A
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The FSC was issued vide letter no. F.6/DEPT/S/School/2014/SZ/1005 dated 08.08.2014 for three blocks.

Keeping in view of the above compliance of the minimum standards of fire prevention and fire safety measures under rule 37 of the Delhi Fire Service Rules 2010 it is recommended to renew Fire Safety Certificate.

R.K. Yadav
18/5/2022

Signature of Inspecting Officer
Name:- R.K.Yadav
Designation:- Asstt. Divisional Officer

Divisional Officer (South West)

19/5/22
19/5
23/5/2022
21/5/2022

21/5/2022