

4/20

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**


No. F6/DFS/MS/WZ/EH/2022/ BNQT./31

Dated: 23/06/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s. Clay-1 Sapphire located at A-10, Ground Floor, Kailash Park, Najafgarh Road, New Delhi-110015, comprised of Ground plus two upper floors was issued fire safety certificate vide letter No. F.6/DFS/MS/2019/WZ/796 dated 10.04.2019. The premises was re-inspected by the officer concerned of this department on 06/06/2022 in the presence of Sh. Jasmeet Singh (Owner) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class '**Assembly**' Group – **D (Ground Floor only)** with effect from 23/06/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions, under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 23/06/2022 at New Delhi.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

dc BH
20/4/2022

Copy to: -

1. The Owner/occupier, M/s. Clay-1 Sapphire, A-10, Ground Floor, Kailash Park, Najafgarh Road, New Delhi-110015.
2. The Joint Commissioner of Police, Licensing Unit, 1st Floor, Police Station Defence Colony, New Delhi
3. The DHO, Karol Bagh Zone, North DMC, Anand Parbat, New Delhi- 110005.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of unified building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate through MHA portal (<https://www.delhhlhic.gov.in>) along with a copy of this certificate, six months prior to its expiry.
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.Delhigovt.nic.in.
9. This FSC is valid for Ground Floor only.

INSPECTION REPORT

1. Name & address of the building: M/s. Clay-1 Sapphire, A-10, Ground Floor, Kailash Park, Najafgarh Road, New Delhi- 10015.
2. Type of Occupancy : Assembly
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/2019/WZ/796 dated 10.04.2019
5. Fire Safety directives Letter No. : N/A
6. Date of inspection : 11.06.2022
7. Name of the Inspecting Officer : Sarabjeet Singh ADO (MN)
8. Name and designation of Officer
From the building side : Sh. Jasmeet Singh, Owner
9. Year of Construction : 2015
10. Applicant's email date : Online MHA ID- 2022051610428 dated 16/05/2022

The said restaurant is running at ground floor in a building is comprised of ground plus two upper floors.

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements as per Rule 35 (6) of DFS Act- 2007	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	09 mts 05 mts NA	Provided Directly accessible NA	MR MR NA
2.	Number, width, Type & Arrangements of exits:			
	➤ Number of staircases			
	a. Upper floors	NA	Running at GF	NA
	b. Basements	NA	NA	NA
	➤ Width of staircases			
	c. Upper floors	NA	Running at GF	NA
	d. Basements	NA	NA	NA
	➤ Protection of exits			
	e. Fire check door	NA	NA	NA
	f. Pressurization	NA	NA	NA
	g. No of continuous staircase to terrace	NA	NA	NA
	h. Width Of Corridor	NA	NA	NA
	i. Door Size	2.0, 1.0 mts	Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke managements System:			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	NA Provided	NA MR

2-11

5.	Fire Extinguishers			
	➤ Total numbers	04 nos.	Provided	MR
	➤ Types	ABC & CO ₂	Provided	MR
	➤ IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	➤ Total numbers on each floor	01	Provided	MR
	➤ Length of hose reel hose	30 m	Provided	MR
	➤ Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system:			
	➤ Type of detectors	NA	NA	NA
	➤ Location of Main Panel	NA	NA	NA
	➤ Location of Repeater Panel	NA	NA	NA
	➤ Alternate source of power	NA	NA	NA
	➤ Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System:			
	➤ Basements	NA	NA	NA
	➤ Upper Floor	NA	Provided	NA
	➤ Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	➤ Size of riser/down- comer	100 mm	Provided	MR
	➤ Number of hydrants per floor	01	Provided	MR
	➤ Hose Box	01	Provided	MR
12.	Yard Hydrants			
	➤ Total number of hydrants	NA	NA	NA
	➤ Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	➤ Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	➤ Terrace level	NA	NA	NA
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 mts	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for firefighting:			
	➤ Underground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	NA	NA
	➤ Overhead Tank capacity	10,000 lts	Provided	MR
15	Exit Signage	Required	Provided	MR

8/

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC type fire extinguishers found provided near electric panel	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/2019/WZ/796 dated 10.04.2019, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

DFA is put up for approval & signature please.

~~(Signature)~~

~~(Signature)~~
14/06/2022

Signature of the Inspecting Officer
Name: - Sarabjeet Singh
Designation: - ADO (MN)

203/ADO/MN
14/6/2022

D.O. (WEST) SGT
DATED 16/6/2022

~~(Signature)~~
19/06/2022

~~(Signature)~~
19/6/2022

ADO/M.N

Sh. F. T is put up for your perusal & signature please !

~~(Signature)~~
20/6/2022