

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/SZ/2022/ *School/703*

Dated: *24/06/2022*

FIRE SAFETY CERTIFICATE

Certified that the building Prakash Public School Located at Sector - 7, Pocket - 2, Dwarka, New Delhi - 110045 comprised of Ground + 03 Upper Floors owned/occupied by **Prakash Public School** was issued FSC vide Letter No. F6/DFS/MS/School/2018/SZ/1292 Dated 04/06/2018. The premises was re inspected by the officer concerned of this department on 07/06/2022 in the presence of Sh. Bashu Vats (Admn. Officer) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular 3298 -3398 Dated 01/03/2011 and that the premises is fit for occupancy class-B "Educational" with effect from *24/06/2022* for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on *24/06/2022* at New Delhi by.


(Sunil Chaudhary)

Dy. Chief Fire Officer
Delhi Fire Service.

Copy to:

1. The Principal Prakash Public School Located at Sector - 7, Pocket - 2, Dwarka, New Delhi - 110045.
2. Directorate of Education Old Secretariat Delhi - 110054.

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/15
INSPECTION REPORT

1. Name & address of the building: Prakash Public School Located at Sector – 7, Pocket – 2, Dwarka, New Delhi - 110045.
2. Type of Occupancy : Educational Ground + 3 Upper Floor
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2018/SZ/1292 dated 04/06/18
5. Fire Safety directives L. No. : DOE Circular 3298 -3398 Dated 01/03/2011
6. Date of inspection : 07/06/2022
7. Name of the Inspecting Officer : Udai vir Singh ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Bashu Vats (Admn. Officer)
9. Year of Construction : 2007 & 2014
10. Applicant's letter No. : Email Dated 30-06-2022

No. of Students=210
No. of class rooms=22
Plot area=15500 sqft
Covered area=9411sqft

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/11	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 Nos.	02 Nos.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 mtr	1.5m & 1.5mtr	MR(Being old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02 Nos.	02 Nos.	MR
	e. Width Of Corridor	1.86 m to 2.36 m	1.86 m to 2.36 m	MR
	f. Door Size	1 mtr	1 mtr	MR(Old Case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c charge	Natural ventilation	MR

(Handwritten Signature)

4/16

15
16

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	02 nos. each floor ABC & CO ₂ ISI marked	09 Nos. Provided Provided	MR MR MR
6.	First - Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 Nos. 30m 5mm	01 Nos. Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	100 mm NA NA	100 mm NA NA	MR NA NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA NA 450 lpm 40 Mtr Required Required	NA NA NA NA NA NA NA NA NA NA NA 450 lpm 40 mtr DG Set Provided	NA NA NA NA NA NA NA NA NA NA NA MR MR MR MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	NA NA NA NA 10,000Ltr	NA NA NA NA 10,000Ltr	NA NA NA NA MR

N/17

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	ABC fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/2018/SZ/1292 Dated 04/06/2018 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name Uday Vir Singh
 Designation ADD/DWR

DO/Secy
 11/6/22 F.I.,
 Dyefo (SZ)
sh

ADD (PWK)

bit pt letter is put up for sig plz
Dyefo/SZ
sh
11/6/22
 M.S. cell