



FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/Mercantile/2022/ 275

Dated: 23/06/2022

FIRE SAFETY CERTIFICATE

Certified that the PVR Cinemas (Audi 1 to Audi 12), Located at 3rd & 4th floor Vegas mall, Plot No 6, Sector - 14, Dwarka, New Delhi, in a building comprised of four tier common basement Ground + five upper floor, was issued FSC vide Letter No F6/DFS/MS/Mercantile//2019/SZ/2036 dated 23/10/2019 The premises was re inspected by the team of officers concerned of this department on 03/06/2022 in the presence of Mr. Sunnil Kumar Bhatnagar and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class " Assembly Building" Group D with effect from 23/06/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 23/06/2022 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

Copy to:

1. The Joint Director, DDA, Vikas Sadan, INA, New Delhi.
2. The DM (South West) DDMA, District South West, Kapashera, New Delhi.
3. Mr. Sunil Kumar bhatnagar, PVR Cinemas (Audi 1 to Audi 12), Located at 3rd & 4th floor Vegas mall, Plot No 6, Sector - 14, Dwarka, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/43

INSPECTION REPORT

1. Name & address of the building: PVR Cinemas (Audi 1 to Audi 12), Located at 3rd & 4th floor Vegas mall, Plot No 6, Sector – 14, Dwarka, New Delhi
2. Type of Occupancy : Cinema (Assembly)
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/Mercantile//2019/SZ/2036 dated 23/10/2019
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2016/326 dated 16/12/2016
6. Date of inspection : 03-06-2022
7. Name of the Inspecting Officer : DO/SW & ADO (DWK)
8. Name and designation of Officer from the building side : Mr. Sunnil Kumar Bhatnagar
9. Year of Construction : 2019
10. Applicant's letter No. : Form J Dated 22/04/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/29	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	09 m	Provided	MR
	• Gate width	6 m	Provided	MR
	• Width of internal road	6 m & 9 to 12 mtr for high rise	Provided (old case)	MR(Being old case)
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	4 nos. common staircase & 02 nos. dedicated staircases	Provided	MR
	• Basements	12 nos. (common for mall)	Provided	MR
	b. Width of staircases			
	• Upper floors	02 mtr each	Provided	MR
	• Basements	02 mtr & 1.5 mtr	Provided	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	Required as per plan	Provided	MR
	e. Width Of Corridor	02 mtr	Provided	MR
	f. Door Size	02 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire Rating of shaft door	02 Hrs	Provided	MR
	• Water Curtain	Required in basements for mall	Provided	MR
	• Fire Dampers	Required	Provided	MR

4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	As per IS 2190/92	68 nos.	MR
	• Types	ABC, CO2 & WCO2	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	As per IS 884	2 Provided each Audi	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke / Beam	Provided	MR
	• Location of Main Panel	Ground floor	Ground floor	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Each audi & common areas	Provided	MR
8.	MOEFA	Each audi & common areas	Provided	MR
9.	Public Address System	Each audi & common areas	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required in mall	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants			
	• Size of riser/down- comer	150 mm	Provided	MR
	• Number of hydrants per floor	2 nos. each Audi	Provided	MR
	• Hose Box	2 nos. each Audi	Provided	MR
12.	Yard Hydrants(Common With Mall)			
	• Total number of hyds	As per IS 13039	16 nos in entire complex	MR
	• Hose Box	Required	16 nos in entire complex	MR

~145

MR
MR
MR
MR
MR

13	Pumping Arrangements (Common With Mall)			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put 	2850 lpm for entire building	Provided	MR
		120 m	Provided	MR
		02 nos for entire building	Provided	MR
		2X180 lpm + water curtain pump 2280 lpm for entire building	Provided	MR
	➤ Jockey pump head	120 m + water curtain 60 mtr	Provided	MR
	➤ Standby Pump out put	2850 lpm for entire building	Provided	MR
	➤ Standby Pump Head	120 mtr	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	900 lpm for entire building	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Provided	Provided	MR
	➤ Auto starting of pump	Provided	Provided	MR
14	Captive water Storage for fire fighting(Common With Mall)			
	• Under ground tank cpty	4,00,000 ltr for entire building	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20, 000 litres	Provided	MR
		Required	Provided	MR
15	Exit Signage	Required	Provided	
16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17	Standby power supply	Required	1400 KVA(2)	MR
18	Refuge Area			
	➤ Total area	550 sq. M for mall	Provided (Old case)	MR(Being Old case)
	➤ Location	5 th floor for mall	Provided	MR
19	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR

20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	NOVEC flooding system in HT/LT panels	MR
----	--	----------	---------------------------------------	----

w/46

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/Mercantile//2019/SZ/2036 dated 23/10/2019 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

[Handwritten signature]

Signature of the Inspecting Officer
 Name Sh. Ved Pal
 Designation D/S/O

[Handwritten signature]

Signature of the Inspecting Officer
 Name Uday Vir Singh
 Designation ABE/D/S/O

Dy. Secy (S/2)

[Handwritten signature]
 2/10

C.F.O - *[Handwritten signature]*
 10/6/2022

[Handwritten signature]
 10/06/22

[Handwritten signature]

ADO (Dwarka)

Site FP letter is put up for sign by

[Handwritten signature]
 Director

[Handwritten signature]
 19/6