

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/2022/misc/ 281

Dated: 24/06/2022

**FIRE SAFETY CERTIFICATE**

Certified that the Dynamics Fitness & Crossfit Gymnasium located at Basement AM-62, Maharishi Dayanand Marg, Shalimar Bagh, New Delhi- 110088, in a building comprised of basement, stilt, Ground plus three upper floors, was issued fire safety certificate vide letter No. F.6/DFS/MS/WZ/2019/1398 dated 09.07.2019. The premises was re-inspected by the officer concerned of this department on 16/06/2022 in the presence of Sh. Gaurav Jindal (Owner) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class '**Assembly' Group – D (Basement Floor only)** with effect from 24/06/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions, under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 24/06/2022 at New Delhi.

(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
West Zone

Copy to: -

1. Sh. Gaurav Jindal, Dynamics Fitness & Crossfit Gymnasium, Basement AM-62, Maharishi Dayanand Marg, Shalimar Bagh, New Delhi- 110088.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of unified building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate through MHA portal (<https://www.dehhlhic.gov.in>) along with a copy of this certificate, six months prior to its expiry.
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.Delhigovt.nic.in](http://www.dfs.Delhigovt.nic.in).
9. This FSC is valid for Basement Floor (Gym) only.

### INSPECTION REPORT

1. Name & address of the building: Dynamic Fitness & Crossfit Gymnasium located at Basement Floor, AM-62, Maharishi Dayanand Marg, Shalimar Bagh, New Delhi- 110088.
2. Type of Occupancy : Assembly
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/WZ/2019/1398 dated 09.07.2019
5. Fire Safety directives Letter No. : F6/DFS/MS/2018/4676 dated 09.11.2018
6. Date of inspection : 16.06.2022
7. Name of the Inspecting Officer : M.K. Chattopadhyay, DO (West)
8. Name and designation of Officer  
From the building side : Sh. Rohit, Manager
9. Year of Construction : 2018
10. Applicant's email date : E-mail dated 03.06.2022

The Gym is running in basement floor of a building comprised of basement, stilt, ground plus three upper floors.

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements as per Rule 35 (6) of DFS Act- 2007	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	24 mtrs Accessible NA	Provided Provided NA	MR MR NA
2.	Number, width, Type & Arrangements of exits:			
	➤ Number of staircases a. Upper floors b. Basements ➤ Width of staircases c. Upper floors d. Basements e. Protection of exits f. Fire check door g. Pressurization h. No of continuous staircase to terrace i. Width Of Corridor j. Door Size	NA 02 NA 2.0, 1.5 mts NA NA NA NA 2.0 & 1.0 m	Provided (02) Provided NA 2.35, 1.60 mts NA NA NA NA Provided	NA MR NA MR NA NA NA NA MR
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke managements System:			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	Exhaust fan provided NA	MR NA



5.	Fire Extinguishers			
	➤ Total numbers	12 nos.	Provided	MR
	➤ Types	ABC & CO <sub>2</sub>	Provided	MR
	➤ IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	➤ Total numbers on each floor	01	Provided	MR
	➤ Length of hose reel hose	30 m	Provided	MR
	➤ Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system:			
	➤ Type of detectors	NA	NA	NA
	➤ Location of Main Panel	NA	NA	NA
	➤ Location of Repeater Panel	NA	NA	NA
	➤ Alternate source of power	NA	NA	NA
	➤ Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System:			
	➤ Basements	Required	Provided	MR
	➤ Upper Floor	NA	NA	NA
	➤ Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	➤ Size of riser/down- comer	100 mm	Provided	MR
	➤ Number of hydrants per floor	01	Provided	MR
	➤ Hose Box	01	Provided	MR
12.	Yard Hydrants			
	➤ Total number of hydrants	NA	NA	NA
	➤ Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	➤ Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	NA	NA	NA
	➤ Terrace level			
	➤ Discharge of pump	900 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for firefighting:			
	➤ Underground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	➤ Overhead Tank capacity	20, 000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR


Handwritten signature or mark.

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA


The fire protection systems provided in the building were checked at the time of inspection.


In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/WZ/2019/1398 dated 09.07.2019, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

DFA is put up for approval & signature please.

  
17/6/2022

Signature of the Inspecting Officer  
Name: M.K. Chattopadhyay  
Designation: DO (West Division)


  
DFA (N2)


  
DFA (N2)


415/DO/WZ  
dt. 17/6/2022

~~DO/WZ~~

F.T. letter is put up for Sign. please.

  
DFA (N2)

  
DFA (N2)

  
22/06/2022

next cell