

483

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**


No. F6/DFS/MS/GH/NDZ/2022/ 296

Dated: 22/06/2022

**FIRE SAFETY CERTIFICATE**

Certified that the **Hotel lord Krishna Dx. Inn** located at **1171-75,6, Tooti Chowk, Main Bazar, Pahar Ganj, New Delhi** comprises of **Ground + 03 floor, Ground floor (reception + office), 1<sup>st</sup> floor (06 guest rooms), 2<sup>nd</sup> floor and 3<sup>rd</sup> floor (08 guest rooms at each floor), total 22 guest rooms** was earlier granted FSC by this department vide letter No.F6/DFS/MS/GH/NDZ/2019/748 dated 05/04/19. Now, the premises was re-inspected by the officer concerned of this department on 16/06/22 in the presence of Mr. Abbas Alam and found that the said guest house building having Ground floor (reception + office), 1st floor to 3rd floor (06 guest rooms at each floor), has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential, Sub-Division A-1 Ground + 03 floor, Ground floor (reception + office), 1<sup>st</sup> floor to 3<sup>rd</sup> floor (06 guest rooms at each floor), total 18 guest rooms only up to third floor** with effect from 22/6/2022 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 22/6/2022 at New Delhi by.

  
**(Dr. S.K. Tomar)**  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Commissioner MCD, Civic Centre, New Delhi: to ensure the occupancy as detailed above.
2. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi online id 2022040806229 dated 08.04.2022. Email.id <Krishna\_lord1@yahoo.com> dt. 13/06/22.
3. The Manager,  
Hotel lord Krishna Dx. Inn, 1171-75, 6, Tooti Chowk, Main Bazar, Pahar Ganj, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. This FSC shall stand null and void if number of lodgers are found more than 10 at any one floor.
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
10. Any flammable material for interior decoration is prohibited.

4133

**INSPECTION REPORT**

1. Name & address of the building      Hotel Lord Krishna Dx. Inn, 1171-75, 6,  
Tooti Chowk, Main Bazar, Pahar Ganj,  
New Delhi.
2. Type of Occupancy                              Residential Building  
Gr. + 03 Upper floors (total 18 Guest rooms)  
Gr. ( Reception + offices )  
1st floor to 3<sup>rd</sup> floor ( 06 guest rooms at each floor)
3. Type of case:-                                      Renewal
4. Details of previous FSC:-                      No. F6/DFS/MS/GH/NDZ/2019/748 dated  
05/04/19.
5. Fire safety directives No.-                      N/A
6. Date of inspection:-                              16/06/22.
7. Name of the inspecting officer:-              Sh. Ravinder Singh(ADO/CC)
8. Name & designation of officer  
from the building side:-                              Mr. Abbas Alam
9. Year of construction:-
10. Applicant's letter No.-

Online id no.2022040806229 dated 08/04/2022  
Email.id <Krishna\_lord1@yahoo.com> dt. 13/06/22.

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing fire safety arrangements	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	N/A	06 mtr.	N/A
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	<b>A. Number of staircases</b>			
	1. Upper floors	01 Nos.	01 Nos.	MR
	2. Basements	N/A	N/A	N/A
	<b>B. Width of staircase</b>			
	1. Upper floors	0.80 mtr.	1.25 mtr.	MR
	2. Basements	N/A	N/A	N/A
	<b>C. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>D. No. of continuous staircase to terrace</b>			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1.0 mtr.	1.0 mtr.	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 ACPH	Natural Ventilation/exhaust	MR

<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	10 Nos.	10 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	01	01	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors CO	Required	Provided	MR
	2) Location of main panel	Ground floor	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Each floor	Provided	MR
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	Required	Provided	MR
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	225 LPM	225 LPM	MR
	b) Head of pump	25 mtr.	25 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR


M/25

14.	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	2500 ltr.	2500 ltr.	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	<b>Stand by Power Supply</b>	Required	Provided	MR
18.	<b>Refuge Area</b>	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	<b>Fire Control Room</b>	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risk, if any:</b>			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection..

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No.F6/DFS/MS/GH/NDZ/2019/748 dated 05/04/19renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended up to third floor.

Signature of the Inspecting Officer



Name: - Ravinder Singh  
Designation: - ADO (CC)



*Dates*

*20/6/22*

*Dy. C.F.O. (NDZ)*

*OK/NDZ 20/6/22*

*ADO (CC)*

*As recommended, Approved for issue of permit and license in P*

*Dy. C.F.O. (NDZ)*

*OK/NDZ 21/6/22*

*21/6/22*