



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/School/WZ/2022/ 718

Dated: 28/06/2022

FIRE SAFETY CERTIFICATE

Certified that the **Lavi Public School** Located at **Plot No. 141, Main Narela Road, Village Ghevra, New Delhi-110081** comprised of Ground + 03 Upper Floors only & earlier the School building comprised of Ground + 02 Upper Floors was issued Fire Safety Certificate by this department Vide Letter No. **F6/DFS/MS/School/2018/1741 dated 26.07.2018**, owned/occupied by **Lavi Public School** have complied with the fire prevention and fire safety requirements in accordance with D.O.E Cr. No. 3298-3398 dated 01.03.2011 and Verified by the officer concerned of Fire Service on 13.06.2022 in the presence of Sh. Parveen Rana (Gen. Secretary) and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 28/6/2022 for a period of **three years**, subject to compliance of the conditions, printed below.

Issued on 28/6/2022 at New Delhi by.

(Atul Garg)
Director

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, Lavi Public School, Plot No. 141, Main Narela Road, Village Ghevra, New Delhi-110081.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

N/20

INSPECTION REPORT

1. Name and address of the building: **Lavi Public School (B.K. Rana Education and Welfare Society (Regd.)** Located at Plot No. 141, Main Narela Road, Village Ghevra, Delhi.
2. Type of Occupancy : Educational (G + 03 Upper Floor only)
3. Type of Case : Renewal/alteration (3rd floor add)
4. Details of previous NOC : F6/DFS/MS/School/2018/1741 Dated 26.07.2018
5. Fire Safety directives Letter No. : D.O.E. Cr. No. 3298-3398 dated 01.03.2011
6. Date of inspection : 13.06.2022
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
from the building side : Sh. Parveen Rana (Gen. Secretary)
9. Year of Construction : 2003 & 2020-2021
10. Applicant's letter No. : nil dated 17.05.2022

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr. No. 3298-3398 dated 01.03.2011 Requirements/ as per FSC dated 26.07.2018	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	03	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m	1.5 m x 2 & 1.2 m x 1	MR ✓
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1 m	Provided	MR
3.	Compartmentation		NA	
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	12 nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR

6.	First Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs.	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

N/22

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the substantial compliance of the minimum standards on fire prevention and fire safety requirements as per D.O.E. Cr. No. 3298-3398 dated 01.03.2011, grant of Fire Safety Certificate is recommended.

Accordingly DFA is put up for approval please.

[Signature]
Aman Kumar Lathar
ADO (JWP)

20/6/22

- ① Previous FSC was of the School for Ground plus two upper floors vide this dept letter No FB/DFE/MS/SCHOOL/2018/1741 dated 26/7/2018
- ② School Management have added third floor & falls under Delhi Fire Service Act 2007 & Rules 2010.
- ③ Fire prevention & fire safety requirement is recommended as DOE Circular No. 3298-3398 dated 01.03.2011.
- ④ No building plan for third floor is attached.

Submitted please -

[Signature]
DFA (N2)

[Signature]
22/6/2022

[Signature]
18/6/2022

[Signature]
22/6/2022

[Signature]
22/6/2022

[Signature]

[Signature]
24/6

ADD (JWP) P.T.O.

D.O. NO. 340
DATE: 18/6/2022