

C-43

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/NDZ/2022/ BNQT. 132

Dated : 28/6 /...../2022

**FIRE SAFETY CERTIFICATE**

Certified that the **Golden Moments**, at 870, East Park Road, Karol Bagh New Delhi-110005 is comprised of **Ground floor Only** having two party halls, office, kitchen and store was earlier granted FSC by this department vide letter No.F6/DFS/MS/BNQT/2019/NDZ/1296 dated 17/06/2019. Now, the premises was re-inspected by the officer concerned of this department on 21/06/22 in the presence of **Sh. Subodh Bawa** and found that the said banquet hall have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for **occupancy class – Group –D, Assembly at Ground floor only** with effect from 28/6/2022 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 28/6/2022 at New Delhi by.

  
27/6/22

**(Dr. S. K. Tomar)**

Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Commissioner , MCD , Civic Centre , New Delhi
2. The Joint Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi.  
Online id no.2022052711418 dated 03.06.2022.
3. The Manager,  
Golden Moments, 870, East Park Road, Karol Bagh, New Delhi-110005.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. The flammable material use for interior decoration, if any, shall strictly be prohibited.

4/16

**INSPECTION REPORT**

1.	Name & address of the building	<b>Golden Moments, <del>Party Palace</del>, 870, East Park Road, Karol Bagh, New Delhi-110005.</b>
2.	Type of occupancy:-	Assembly – Banquet at ground floor.
3.	Type of case:-	Renewal
4.	Details of previous FSC:-	F6/DFS/MS/BNQT/2019/NDZ/1296 dated 17/06/2019.
5.	Fire safety directives No.-	N/A
6.	Date of inspection:-	21.06.2022
7.	Name of the inspecting officer:-	Sh. Rajinder Atwal(DO/CD)
8.	Name & designation of officer From the building side:-	<u>Sh. Subodh Bawa</u>
9.	Year of construction:-	2011-12
10.	Applicant's letter No:-	Online id no.2022052711418 dated 03.06.2022.

Building is comprised of ground floor having party hall, kitchen, office and two store room at mezzanine floor.

Old case

S.No	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	09mtr	17mtr.	MR
	2) Gate width	4.5 mtrs	4.5 mtrs	MR
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	02 mtr. X 2 each	1.) 2.4 & 2.0 Mtrs 2.) 2.0 & 2.0 Mtrs	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A

A/17

4.	<b>Smoke Management System</b>			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 a/c per hour	Natural Ventilation/ Exhaust fan provided	MR
5.	<b>Fire Extinguishers</b>			
	1) Total numbers	10 Nos.	10 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	<b>First-Aid Hose Reel</b>			
	1) Total number at each floor	03 Nos.	03 Nos.	MR(G.F Only)
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	150 mm	150 mm	MR,
	2) Number of hydrants per floor	01 Nos	01 Nos	MR,
	3) Hose box	01 Nos	01 Nos	MR,
12.	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A

13.	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	900 LPM	900 LPM	MR (old case)
	b) Head of main pump	30 mtrs.	30 mtrs.	MR (old case)
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	Required	Provided	MR




N/18


	d) Auto starting of pump	N/A	N/A	N/A
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	Under ground tank	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	15,000 ltr.	15,000 ltr.	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
<b>17.</b>	<b>Stand by Power Supply</b>	Required	Provided	MR
<b>18.</b>	<b>Refuge Area</b>			
	Total area location	N/A	N/A	N/A
<b>19.</b>	<b>Fire Control Room</b>			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
<b>20.</b>	<b>Special Fire Protection System for Protection of special Risk, if any:</b>			
				N/A


The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/BNQT/2019/NDZ/1296 dated 17/06/2019, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended for approval.


Signature of the Inspecting Officer


  
22/6/22  
Name : Rajinder Atwal  
Designation : DO ( CD)



Dy. C.F.O. (NDZ)  
  
23/6/22

DO (CO)  
As approved, F.T letter is put up for  
signature please.

Dy. C.F.O. (NDZ)  
  
27/6/22

  
24/6/22

MS

uploaded

  
21/6/2022