

434



FORM 'H'
 FORM FOR ISSUING FIRE SAFETY CERTIFICATE
 [Refer sub - rule (1) of rule 35]
 GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
 HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
 NEW DELHI


No. F6/DFS/MS/2022/EH/185


Dated: 21/06/2022

FIRE SAFETY CERTIFICATE

Certified that the building of Mc Donalds Family Restaurant Located at **Ground Floor** Eros Metro Mall, Plot No 8, Sector - 14, Dwarka, New Delhi - 110075 in a building comprised of 03 tier basements, Ground + 3 Upper Floors was issued FSC vide Letter No F6/DFS/MS/EH/2018/SZ/2637 Dated 07/12/2018 The premises was re inspected by the officer concerned of this department on 14/06/2022 in the presence of Sh. Sumit Kumar and found the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class " Assembly" Group D with effect from 21/06/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on21/06/2022 at New Delhi by.


 (Sunil Chaudhary)
 Dy. Chief Fire Officer
 Delhi Fire Service


 1/2
 20/6/22

Copy to:

1. The Joint. Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi.
2. The Manager, Mc Donalds Family Restaurant Located at Ground Floor Eros Metro Mall, Plot No 8, Sector - 14, Dwarka, New Delhi - 110075

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement strictly shall be kept vacant as seen during inspection.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

N/18

1. Name & address of the building: Mc Donalds Family Restaurant Located at Ground Floor Eros Metro Mall, Plot No 8, Sector – 14, Dwarka, New Delhi – 110075.
2. Type of Occupancy : Class-D (Assembly)(**Running At Ground Floor in a building comprised of 03 tier basements, Ground + 03 Upper Floors**)
3. Type of Case : Renewal
4. Details of previous NOC :F6/DFS/MS/EH/2018/SZ/2637 Dated 07/12/2018
5. Fire Safety directives Letter No. : UBBL/NBC Requirements
6. Date of inspection : 14/06/2022
7. Name of the Inspecting Officer ; Sh. Udai vir Singh ADO (DWK)
8. Name and designation of Officer
from the building side : Mr. Sumit Kumar
9. Year of Construction : 2011
10. Applicant's Letter No : Email Dated-10/06/2022 **MHA Application No. 2022053011671**

S. No	Minimum standards on fire prevention and fire safety U/R 33	As per N/14	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	20 mtrs	Provided	MR
	• Gate width	4.5 m	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	Restaurant at ground floor	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.5 m	03 mtr	MR
	f. Door Size	02 m & 1m	Provided	MR(Being Old case)
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Exhaust fan provided	MR
	• Upper floors	NA	NA	NA

(Signature)

N/19

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	10 Nos. ABC, CO2 ISI marked	Provided ABC, CO2 Provided	MR MR MR
6.	First – Aid Hose Reel			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02 Nos 30 mtr 5 mm	Provided by mall Provided by mall Provided by mall	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke / heat Required NA Required Appropriate places	Provided Control room Provided DG set & battery backup Provided	MR MR NA MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided by mall	MR
10.	Automatic Sprinkler System Connected with main system of mall			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Required Required Required	Provided Provided Provided	MR MR MR
11.	Internal Hydrants: Connected with main system of mall			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	150 mm 04 nos. Required	Provided by mall Provided by mall Provided by mall	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	06 nos. Required	Provided by mall Provided by mall	MR MR
13.	Pumping Arrangements: Common with Mall			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA NA NA NA NA NA NA NA Required Required 900lpm 40 m Required Required	2850 lpm Provided By Mall 70 m Provided By Mall 2 Nos. Provided By Mall 2X180 lpm Provided By Mall 70 m Provided By Mall 2850 lpm Provided By Mall 75 m Provided By Mall Provided Provided Not Provided Not Provided Not Provided Not Provided	NA NA NA NA NA NA NA NA MR MR MR (Pump at ground level at higher side) MR (Pump at ground level at higher side) MR (Pump at ground level at higher side) MR (Pump at ground level at higher side)

MR
MR
R

N-20

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	1,00,000 litres	NA
	➤ Draw off connection	NA	Provided By Mall	NA
	➤ Fire service inlet	NA	Provided by mall	NA
	➤ Access to tank	NA	Provided by mall	NA
	• Overhead Tank capacity	20, 000 litres	Provided by mall	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts Restaurant at Ground Floor			
	➤ Pressurization of Lift Shaft	NA	Provided by mall	NA
	➤ Pressurization of lift lobby	NA	Provided by mall	NA
	➤ Communication in lift Car	NA	Provided by mall	NA
	➤ Fireman's Grounding Switch	NA	Provided by mall	NA
	➤ Lift Signage	NA	Provided by mall	NA
17.	Standby power supply	Required	DG set 600 KVA	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 fire extinguisher provided near electric panel.	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F6/DFS/MS/EH/2018/SZ/2637 Dated 07/12/2018 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name *Uday Vir Singh*
 Designation *ADP/DWR*

DOS/20
als 16/6/22

F.7

Dy. Insp.

17/6

ADP/DWR

Sir AT letter is put up for sign ple

Dy. Insp.

M.S.ULL' uploaded