

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No.F.6 DFS/MS/School/2022/SZ/ 698

Dated: 23/06 / 2022

**FIRE SAFETY CERTIFICATE**

Certified that **SDMC Primary School (Girls/Boys)** located at Kapashera No- 2/1, New Delhi 110037 (ID- 1757232) comprised of 02 interconnected Blocks (Ground plus One upper Floor & Ground plus two upper floors) was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2019/SZ/1084 Dated 21/05/2019. The said premises was re-inspected by officer concerned of this department on 17/06/2022 in presence of Mrs. Babita (Principal) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the school building is fit for occupancy class "**Educational Building**" Group – B with effect from 23/06 / 2022 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 23/06 / 2022 at New Delhi by

  
(SUNIL CHAWDHARY)  
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Principal, SDMC Primary School (Girls/Boys) located at Kapashera No- 2/1, New Delhi 110037 (ID- 1757232)
2. The Directorate of Education, South Zone, Civic Centre, Minto Road, New Delhi-110002.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This certificate cannot be treated as regularization of unauthorized construction, if any.
5. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."


N/21



## INSPECTION REPORT

1	Name & Address of the Building	SDMC Primary School, Kapashera No- 2/1, New Delhi 110037 (ID- 1757232)		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	02 interconnected Blocks, 1 <sup>st</sup> Block- Ground plus one upper floor & 2 <sup>nd</sup> Block- Ground plus two upper floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2019/SZ/1084 Dated 21/05/2019		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	17/06/2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mrs. Babita (Principal)		
10	Year of construction	2003 & 2016		
11	Applicant letter No.	Email of dated 02/06/2022		
S. No.	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>NBC/BBL Requirements</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
1	<b>Access to Building.</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	6 mtr 4 mtr -NA-	06 mtr 04 mtr -NA-	MR MR -NA-
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	1 <sup>st</sup> block-01 no. 2 <sup>nd</sup> block-02 no.	Old block-01 no. 2 <sup>nd</sup> block-02 no	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	<b>b) Width of Staircase</b>			
	➤ Upper floors	1 <sup>st</sup> Blk-1.5m / 0.75m 2 <sup>nd</sup> Blk-1.50m	1 <sup>st</sup> Blk-1.95m 2 <sup>nd</sup> Blk-1.50m each	MR
	➤ Basement floor	-NA-	-NA-	NA
	<b>c) Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	Required	Provided	MR
	<b>e) Width of corridor</b>	-NA-	-NA-	-NA-
	<b>f) Door size</b>	1 mtr	Provided	MR
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>Fire check door.</li> <li>Sealing of electrical shafts.</li> <li>Fire rating of shaft door.</li> <li>Water curtain</li> <li>Fire dampers.</li> </ul>	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
4	<b>Smoke Management system.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors</li> </ul>	30 ACPH 12 ACPH	-NA- -NA-	-NA- -NA-
5	<b>Fire Extinguishers.</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI Marking</li> </ul>	10 Nos ABC / CO2 ISI marked	10 Nos CO2 & ABC Provided	MR MR MR
6	<b>First Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor.</li> <li>Length of hose-reel hose.</li> <li>Nozzle Diameter</li> </ul>	2 <sup>nd</sup> block 30 mtr 5 mm	01 Nos. provided 30 mtr Provided	MR MR MR
7	<b>Automatic fire detection &amp; alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> </ul>	-NA- -NA-	-NA- -NA-	-NA- -NA-

M22



	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooter's location</li> </ul>	-NA-	-NA-	-NA-
8	<b>MOEFA</b>	-NA-	-NA-	-NA-
9	<b>Public Address System</b>	-NA-	-NA-	-NA-
10	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floors</li> <li>• Sprinkler above false ceiling</li> </ul>	-NA-	-NA-	-NA-
11	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Size of Riser/Down-comer</li> <li>• Number of Hydrant per floor</li> <li>• Hose box.</li> </ul>	-NA-	-NA-	-NA-
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants.</li> <li>• Hose box.</li> </ul>	-NA-	-NA-	-NA-
13	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li>• <b>Ground Level</b></li> </ul>			
	<ul style="list-style-type: none"> <li>➢ Discharge of main pump.</li> <li>➢ Head of main pump.</li> <li>➢ Number of main pumps.</li> <li>➢ Jockey Pump output.</li> <li>➢ Jockey Pump head.</li> <li>➢ Standby Pump output.</li> <li>➢ Standby Pump head.</li> <li>➢ Auto Starting/Manual Stopping.</li> <li>➢ Pump house access.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• <b>Terrace Level</b></li> </ul>			
	<ul style="list-style-type: none"> <li>➢ Discharge of pump.</li> <li>➢ Head of pump.</li> <li>➢ Power supply.</li> <li>➢ Auto starting of pump.</li> </ul>	450 LPM	450 LPM	MR
		40 mtr	40mtr	MR
		Required	Provided	MR
		Required	Provided	MR
14	<b>Captive water storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity.</li> <li>➢ Draw-off connection.</li> <li>➢ Fire Service Inlet.</li> <li>➢ Access to tank.</li> <li>• Overhead tank capacity.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		10,000 Ltrs	10,000 Ltrs	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of lift shaft.</li> <li>• Pressurization of lift lobby.</li> <li>• Communication in lift car.</li> <li>• Fireman's switch.</li> <li>• Lift signage.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17	<b>Standby Power Supply</b>	-NA-	-NA-	-NA-
18	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>• Total area</li> <li>• Location</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
19	<b>Fire Control Room.</b>			
	<ul style="list-style-type: none"> <li>• Detector system panel.</li> <li>• Flow switch panel.</li> <li>• PA system panel.</li> <li>• Battery backup.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

M/23



	• Building floor plan	-NA-	-NA-	-NA-
20	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>			-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F.6/DFS/MS/School/2019/SZ/1084 Dated 21/05/2019, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

14/22/6/22

Signature of the Inspecting Officer  
Name: Sh. Rajesh Kumar  
Designation: ADO (BCP)

~~DO (SB)~~

14/22/06/22

~~Deputy~~

F. 7,

ADO (B/C P)

As approved, F.T. letter is put up for your signature pl

14/23/6

~~24/5/22~~

M.S. cell