



4/18

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2022/School/690

Dated: 23/6/2022

FIRE SAFETY CERTIFICATE

Certified that the building Sonu Public School, Located at Raj Nagar-Part – II, Palam Colony, New Delhi – 110045 comprised of Ground + 02 Upper Floors owned/occupied by **Sonu Public School** was issued FSC vide Letter No. F.6/DFS/MS/School/2019/SZ/12 Dated 02/01/2019. The premises was re inspected by the officers concerned of this department on 10/06/2022 in the presence of Sh. Vk Sehgal (Manager) and found that the said building have deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 262-362 Dated 17/01/2005 and that the building is fit for occupancy class B “Educational building” with effect from 23/6/2022 for a period of three in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 23/6/2022 at New Delhi by.

(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service.

17/6/22

Copy to:

1. The principal, Sonu Public School, Located at Raj Nagar-Part – II, Palam Colony, New Delhi – 110045.
2. Directorate of Education Old Secretariat Delhi – 110054.

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Sonu Public School, Located at Raj Nagar-Part – II, Palam Colony, New Delhi – 110045.
2. Type of Occupancy : Educational G+2 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/2019/SZ/12 Dated 02/01/2019
5. Fire Safety directives Letter No: DOE Circular. 17/01/2005
6. Date of inspection : 10/06/2022
7. Name of the Inspecting Officer : Udai vir Singh ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. V.K Sehgal (Manager)
9. Year of Construction : 2006
10. Applicant's letter No. : Email Dated -02/06/2022

No. of Students=40
No. of class rooms=12
Plot area=198 sqmtr
Covered area=150 samtr

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/6	Provided at site	Remarks MR/NMR
1.	Access of building	06 m	Accessible for small fire unit	MR (Old case)
	• Road width	4.5mtrs	Directly accessible from road	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	02 Nos.	Provided	MR
	• Upper floors	NA	NA	NA
	• Basements			
	b. Width of staircases	1.5 mtr if less than 1.5 m additional staircase of 0.75 m is required	1.07 m & 0.86 m	MR (Old case)
	• Upper floors	NA	NA	NA
	• Basements			
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	01	Provided	MR
	d. No of continuous staircase to terrace	NA	1.16 m	NA
	e. Width Of Corridor	01 mtr	Provided	MR(Old Case)
	f. Door Size			
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	02 nos.each floor	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	Required	100 mm	MR
	• Number of hydrants per floor	Required	01	MR
	• Hose Box	Required	01	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	220 lpm	Provided	MR(Old case)
	➤ Head of the pump	40 mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR

n/14

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	2500 ltr	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F.6/DFS/MS/School/2019/SZ/12 Dated 02/01/2019 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Name *Uday Kumar Singh*

Designation *AO of DDO*

17/6/22

14/6/22

14/6/22

F.H.

Dyefo (SZ)

[Signature]

A O O / D W K

See AT letter is part of the S. of 10/12

Dyefo/SZ

M.S. 17/6/22