

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No. F6/DFS/MS/School/2022/ WZ 1705

Dated: 24/06/2022

FIRE SAFETY CERTIFICATE

Certified that the **D.K. Convent School** located at **B- Block, Gali No.110, Sant Nagar, Burari, Delhi-110084** comprised of **01 blocks- Ground plus 02 upper floors only** owned/occupied by **D.K. Convent School** was issued Fire Safety Certificated by this department vide letter **No.F6/DFS/MS/2018/School/WZ/1558** dated **04.07.2018** The premises was re-inspected by the officer concerned of this department on **17.06.2022** in presence of **Sh. Manish (Teacher)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class "**Group B Educational** with effect from 24/06/2022 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 24/6/2022 at New Delhi by:


 (Dharampal Bhardwaj)
 Dy.Chief Fire Officer
 Ph:-011-23414250

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Manager, D.K. Convent School located at B- Block, Gali No.110, Sant Nagar, Burari, Delhi-110084.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : D.K Convent School, B-Block, Gali No-110, Sant Nagar, Burari, Delhi-84.
2. Type of Occupancy : Educational
3. Composition of building : Ground plus 02 upper floors
4. Type of Case : Renewal
5. Details of previous NOC : F.6/DFS/MS/2018/School/WZ/1558 dated 04.07.2018
6. Fire Safety directives letter No : Nil
7. Date of inspection : 17.06.2022
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Sh. Manish (Teacher)
10. Year of Construction : 2004 & 2005
11. Applicant's letter No. : Letter No. Nil & DFS Dairy No.2291 dated 09.06.2022

Plot Area-200 sq yd		Covered Area:600 sq yd		class rooms -18+01nos,		students---520nos	
Minimum Standards on fire prevention and fire safety U/R 33		Director of Education letter		Provided at site		Remarks MR/NMR	
1	Access to building		6m		5.10m		MR(old case)
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Directly Accessible		Directly Accessible		MR	
		NA		NA		NA	
		NA		NA		NA	
2	Number, Width, Type & Arrangement of Exits						
	a. Number of staircases	01		02		MR	
		NA		NA		NA	
	b. Width of staircases	1.50m		1.20 & 1.07m (iron staircase)		MR(old case)	
		NA		NA		NA	
	c. Protection of exits	NA		NA		NA	
		NA		NA		NA	
		Required		Provided		MR	
	d. No. of continuous staircases to terrace	NA		NA		NA	
	e. Width of Corridor	1 m		1 m		MR	
	f. Door Size	NA		NA		NA	
	3	Compartmentation.					
<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 		NA		NA		NA	
		NA		NA		NA	
		NA		NA		NA	
		NA		NA		NA	
		NA		NA		NA	
NA		NA		NA			
4	Smoke Management System.						
	<ul style="list-style-type: none"> • Basements • Upper floors 	12 a/c per hour		NA		NA	
		12 a/c per hour		Natural Ventilated		MR	
5	Fire Extinguishers						
	<ul style="list-style-type: none"> • Total numbers • Types • ISI marking 	07nos		12nos		MR	
		ABC/Co2		ABC--12		MR	
		ISI Marked		Yes		MR	

6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA			
9	Public Address System.			
		NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450lpm	450lpm	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5,000 ltrs	5,000ltrs	MR(old case)


		Required	Provided	MR
	Exit Signage			
	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. 1558 dated 04.07.2018.

~~DO (NW)~~
 21/06/2022
 Dy CFB (WZ)

23/6/2022



 Signature of the Inspecting Officer
 Name:-C.L. Meena
 Designation:- ADO/RN

~~ADO/RN~~

As approved, F.i. letter is setup for your signature D.

Dy CFB (WZ)

24/6/2022


 24/6/2022

msg/ all