

473

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/SZ/2022/ School / 683

Dated: 22/6/2022

FIRE SAFETY CERTIFICATE

Certified that the building Delhi Public School Located at Sector – 03, Dwarka, New Delhi comprised of Ground + 03 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/School/2019/SZ/1138 Dated 28/05/2019. The premises was re inspected by the officers concerned of this department on 02/06/2022 in the presence of Sh. Jaspal Singh (Employee) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service 2010 and that the premises is fit for occupancy class “Educational” Group B with effect from 22/06/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 22/06/2022 at New Delhi by.


(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service.

Copy to: 1. The Principal, Delhi Public School Located at Sector – 03, Dwarka, New Delhi.
2. Directorate of Education Old Secretariat Delhi – 110054.

Following fire safety directives must be adhered to:-

- 1 **Addition/ alteration in the premises as sanctioned vide letter no F6/DFS/MS/BP/2018/198 dated 25/06/2018 is under progress same shall not be occupied without getting clearance from this department.**
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 3 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 4 The trained staff should be available round the clock.
- 5 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 6 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 7 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 8 Basement shall be used strictly as per building bye laws.
- 9 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: Delhi Public School Located at Sector – 03, Dwarka, New Delhi.
2. Type of Occupancy : Educational Ground + 3 Upper Floor
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2019/SZ/1138 Dated 28/05/2019
5. Fire Safety directives L.No. : F6/MS/DFS/BP/2000/1921 Dated 18/10/2000.
6. Date of inspection : 02/06/2022
7. Name of the Inspecting Officer : Udai vir Singh ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Jaspal Singh (Employee)
9. Year of Construction : 2002
10. Applicant's letter No. : DPSDW/206/18/Engg. Dated 11-05-2022

No. of Students=3549
No. of class rooms=85
Plot area=3900 M ²
Covered area=2370 M ²

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/17	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	04 Nos.	04 Nos.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 mtr each + ramp	Provided	MR(Being old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	04 Nos.	Provvided	MR
	e. Width Of Corridor	1.5 mtr	Provided	MR(Being old case)
	f. Door Size	1 mtr	Provided	MR(Being old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c charge	Natural ventilation	MR

Udai Singh

N/29

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	08 nos.each floor ABC & CO ₂ ISI marked	Provided ABC & CO ₂ Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	04 Nos. 30m 5mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	100 mm 04 nos. Required	100 mm Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA NA 450 lpm 40 Mtr Required Required	NA NA NA NA NA NA NA NA NA NA NA 2X450 lpm Provided Provided Provided	NA NA NA NA NA NA NA NA NA NA NA MR MR MR MR

N/23

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	50,000 ltr	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000Ltr	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	DG Set	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	CO2 fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/2019/SZ/1138 Dated 28/05/2019 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note:-

1. Addition/ alteration in the premises as sanctioned vide letter no F6/DFS/MS/BP/2018/198 dated 25/06/2018 is under progress same shall not be occupied without getting clearance from this department.

2.The FSC is recommended for old school building comprising ground plus three upper floors only.

Signature of the Inspecting Officer
 Name *Uday Kumar Singh*
 Designation *ADDO/DWK*

D/S/O *W/S* *15/6/22*

D/S/O (S2)

F.T.
14/6

A.S. *ADQ (DWK)*