



FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/2022/NDZ/ 731

Dated: 30/06/2022

FIRE SAFETY CERTIFICATE

Certified that the Sneh International School, Junior located at Jagriti Enclave, Vikas Marg Extn, Delhi-110092, comprised of Basement, Ground & Two Upper Floors owned / occupied by Sneh International School has already been issued Fire Safety Certificate Vide letter No.F6/DFS/MS/School/2018/NDZ/1809dated 03/08/2018. The premises was re-inspected by the officer concerned of Fire Service on 22.06.2022 in the presence of Sh. Bunty Kumar (Care Taker) and observed that all the Fire Prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class "Educational" (Group-B) with effect from 30/06/2022 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 30/06/2022 at New Delhi by.


30/6/22

(Dr. S.K.TOMAR)

DY. CHIEF FIRE OFFICER

Copy to :-

1. The President Sneh International School, Junior, Jagriti Enclave, Vikas Marg Extn, Delhi-110092

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.
8. Basement shall be used as per BBL-1983.

INSPECTION REPORT

1. Name & address of the building: Sneh International School, Junior, Jagriti Enclave, Vikas Marg Extn., Delhi-110092.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC No. : F6/DFS/MS/School/2018/NDZ/1809 dated 03/08/2018
5. Fire Safety directives Letter No.: NBC
6. Date of inspection : 22/06/2022
7. Name of the Inspecting Officer : DO (East)
8. Name and designation of Officer
from the building side : Sh. Bunty Kumar
9. Year of Construction : 2011
10. Applicant's letter No. : Nil dated 10/06/2022

Basement + Ground + 2 floors

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL / NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	6 mtr	MR
	• Gate width	4.5 mtr	4.5 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	01 nos.	02 nos.	MR
	• Basements	01 nos.	02 nos.	MR
	b. Width of staircases			
	• Upper floors	1.50 m	1.60 & 1.20m	MR ✓
	• Basements	1.50 m	1 no of staircase 1.30 m & 2 exits	MR ✓ Old acceptable
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	01 nos.	01 nos.	MR ✓
	e. Width Of Corridor	1.50 m	1.50 m	MR ✓
	f. Door Size	1.00 m	1.00 m	MR ✓
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	08	08	MR ✓
	• Types	ABC /CO ₂	Provided	MR
	• IS marking	ISI Marked	Provided	MR

AB

6.	First – Aid Hose Reels			
	• Total numbers on each floor	1 nos.	Provided	MR
	• Length of hose reel hose	30 Mtr.	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down- comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	15,000 Ltr.	15,000 Ltr	MR

[Handwritten signature]

N/18

		Required	Provided	MR
15.	Exit Signage			
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/2018/NDZ/1809 dated 03/08/2018 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Ashok
22/06/22

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : D.O. (East)

Dy. CFO (NDZ)

Sl. 1 peak

Ashok
23/6/22

403
23.6.22
29.6.22
30.6.22

DOCED

Spoken.

Ashok
27/06/2022

Dy. CFO (NDZ)

Ashok
29/6/22

DOCED

As Approved, F.T. is placed for sign. pl.

Dy. CFO (NDZ)

Ashok
30/6/22

Ashok
30/06/2022

ms