


FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/2022/ 295

Dated: 05/07/2022

FIRE SAFETY CERTIFICATE

Certified that the building **Community Facility (CF)** Located at Residential Cum Training complex for SPG , Plot No 21, Sector – 21, Dwarka, New Delhi comprised of ground plus Five upper floor owned/ occupied by **SPG Govt.** was granted Fire Safety Certificate from this department vide letter No. F.6/DFS/MS/2019/SZ/2260, dated 04/12/2019. The said building was re-inspected by the officer concerned of this department on 14/06/2022 in presence Mr. Pawan Yadav (SO 1) and found that the premises have deemed complied fire prevention & fire safety requirements in accordance with Rule 33 of the Delhi Fire Service and that the building is fit for mixed occupancy class A, H & D “ **(Residential, Storage & Assembly)** building” with effect from 05/07/2022 for a period of three years, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...05/07/2022... at New Delhi by.


(Atul Garg)
Director,
Delhi Fire Service.

Copy to:

1. Sh. Vimal Pawar (AIG SPG) Residential Cum Training complex for SPG , Plot No 21, Sector – 21, Dwarka, New Delhi
2. The Jt. Director (L&I) Bldg. DDA Building Section INA Vikas Sadan, New Delhi.

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

11/7
INSPECTION REPORT

1. Name & address of the building: Community Facility Located at Residential Cum Training complex for SPG , plot No 21, Sector – 21, Dwarka, New Delhi .
2. Type of Occupancy : Mixed occupancy (Residential, Storage & Assembly(G+5))
3. Type of Case : **Renewal**
4. Details of previous NOC : **F-6/DFS/MS/2019/SZ/2260 Dated 04/12/2019**
5. Fire Safety directives Letter No. : F-6/DFS/MS/BP/2017/227 Dated 28/07/2017
6. Date of inspection : 14/06/2022
7. Name of the Inspecting Officer : Udai vir Singh, ADO (DWK)
8. Name and designation of Officer
from the building side : Mr. Pawan Yadav (SO 1)
9. Year of Construction : 2019
10. Applicant's letter No. : Form J & K dated 03/06/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	As Per Directive	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 Mtr	Provided	MR
	• Gate width	5 Mtr	6m	MR(Being old case)
	• Width of internal road	6 Mtrs	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 Nos.	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m & 2 m	Provided	MR(Old Case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	02 Nos.	Provided	MR
	e. Width Of Corridor	2 mtr	Provided	MR(Being old case)
	f. Door Size	1.5 m & 2 m	Provided	MR(Being old case)
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA



2/8

4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Open able windows	MR
5.	Fire Extinguishers			
	• Total numbers	24 nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	Ground floor	Provided	MR
	• Location of Repeater Panel	Required	NA	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants:			
	• Size of riser/down- comer	150 mm	Provided	MR
	• Number of hydrants per floor	2 Nos.	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	Required	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	2250 lpm	Provided	MR
	➤ Head of main pump	70 mtr	Provided	MR
	➤ Number of main pumps	2	Provided	MR
	➤ Jockey pump out put	180lpm	Provided	MR
	➤ Jockey pump head	70mtr	Provided	MR
	➤ Standby Pump out put	2250lpm	Provided	MR
	➤ Standby Pump Head	70mtr	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	900 lpm	Provided	MR
	➤ Head of the pump	40Mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR

(Handwritten signature)

NA
MR

N/A

Captive water Storage for fire fighting:			
14.	• Under ground tank capacity	300000ltr	Provided MR
	➤ Draw off connection	Required	Provided MR
	➤ Fire service inlet	Required	Provided MR
	➤ Access to tank	Required	Provided MR
	• Overhead Tank capacity	25,000 ltrs	Provided MR
15.	Exit Signage	Required	Provided MR
16.	Provision of Lifts		
	➤ Pressurization of Lift Shaft	Required	Provided MR
	➤ Pressurization of lift lobby	NA	NA NA
	➤ Communication in lift Car	Required	Provided MR
	➤ Fireman's Grounding Switch	Required	Provided MR
	➤ Lift Signage	Required	Provided MR
17.	Standby power supply	Required	DG Set 600 KVA MR
18.	Refuge Area		
	➤ Total area	NA	NA NA
	➤ Location	NA	NA NA
19.	Fire control room		
	➤ Detector system panel	Required	Provided MR
	➤ Flow Switch Panel	Required	Provided MR
	➤ PA System Panel	Required	Provided MR
	➤ Battery backup	Required	Provided MR
	➤ Building Floor Plans	Required	Provided MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	Co2 Fire Extinguisher provided near electric panels MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F/6/DFS/MS/2019/SZ/2260 Dated 04/12/2019 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name *Uday Kumar Singh*
 Designation *22010004*

2018/22
27/6/22

Dy. Insp. (S)

E.P.O.
27/6/2022

Director (M)
27/6/22

2001/2022