

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/CNG/WZ/2022/301

Dated: 06/07/2022

FIRE SAFETY CERTIFICATE

Certified that the CNG facility at Rani Khera-II, Cluster Bus Depot, Transport Department, Phase-V, Rohini, Delhi, comprised of Ground Floor only owned / occupied by Indraprastha Gas Limited. The premises was inspected by officer concerned of this department on 03.06.2022 in the presence of Sh. Prashant Saini (Deputy Manager) and found that the premises have complied with fire prevention & fire safety requirement in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and the building/ premises fit for occupancy **Hazardous (Group-J)** with effect from 06/07/2022 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rule, 2010 subject to conditions printed below.

Issued on 06/07/2022 at New Delhi by


(Atul Garg)
DIRECTOR
Ph; 011-23414000

Copy to:

1. Chief General Manager (project), Indraprastha Gas Limited, IGL Bhawan, Plot no-4, Community Center, R.K. Puram, Sect-9, New Delhi-110022.
2. The Addl. Commissioner of Police (Lic), 1st Floor, Police Station, Defense Colony, Delhi

Conditions for the validity of fire safety certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

N/3

INSPECTION REPORT

1. Name & address of the building : CNG facility at Rani Khera-II, Cluster Bus Depot, Transport Department, Phase-V, Rohini, Delhi.
2. Type of Occupancy : Group J Hazardous Building (Single Story Building)
3. Type of Case : New Case
4. Details of Previous NOC : NA
5. Fire Safety directives letter No : F.6/DFS/MS/CNG/2018/1525 dated 12.04.2018
6. Date of inspection : 03.06.2022
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Mr. Prashant Saini (Deputy Manager)
9. Year of Construction :
10. Applicant's letter No. : OD No.217 dated 07.04.2022.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	12m NA NA	Provided NA NA	MR NA NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	NA NA	NA NA	NA NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	NA NA	NA NA	NA NA
	c. Protection of exits			
	Fire check door			
	<ul style="list-style-type: none"> • Pressurization 	NA NA	NA NA	NA NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0m	1.0m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	NA NA	NA NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	75 KG – 08 DCP 09 KG – 06 DCP 4.5 Kg – 03 CO2 SI marked	Provided DCP/co2 type Yes	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	NA NA NA	NA NA NA	NA NA NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel 	Gas/flame detector NA NA	Provided NA NA	MR NA NA

11/4

Special Fire Protection

8.	<ul style="list-style-type: none"> • Alternate source of power • Hooters' Location 	NA	NA	NA			
9.	MOEFA	NA	NA	NA			
10.	Public Address System	Required	Provided	MR			
10.	Automatic Sprinkler System	NA	NA	NA			
11.	<ul style="list-style-type: none"> • Basement • Ground & Upper Floors • Sprinkler above false ceiling 	NA	NA	NA			
	Internal Hydrants	NA	NA	NA			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	NA	NA	NA			
12.	Yard Hydrants	NA	NA	NA			
13.	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA			
	Pumping Arrangements	NA	NA	NA			
13.	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➢ Discharge of main Pump ➢ Head of Main pump ➢ Number of main pumps ➢ Jockey Pump out put ➢ Jockey pump head ➢ Standby Pump out put ➢ Standby Pump Head ➢ Auto Starting/Manual Stopping ➢ Pump House Access 	NA	NA	NA			
	14.	<ul style="list-style-type: none"> • Terrace level <ul style="list-style-type: none"> ➢ Discharge of pump ➢ Head of the pump ➢ Power Supply ➢ Auto Starting of pump 	NA	NA	NA		
		Captive Water Storage for fire fighting	NA	NA	NA		
		15.	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➢ Draw-off connection ➢ Fire service inlet ➢ Access to tank • Overhead Tank capacity 	NA	NA	NA	
			Exit Signage.	NA	NA	NA	
			Provision of Lifts.	NA	NA	NA	
			16.	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
		Standby power supply		NA	NA	NA	
		Refuge Area.		NA	NA	NA	
		19.		<ul style="list-style-type: none"> ➢ Total Area ➢ Location 	NA	NA	NA
				Fire Control Room	NA	NA	NA
		19.	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	NA	NA	NA	
				NA	NA	NA	
				NA	NA	NA	
	NA		NA	NA			
	NA		NA	NA			

N/S

Special Fire Protection System for Protection of special Risks, if any:

No smoking boards & emergency no. were found displayed in Hindi & English. No loose electric wiring seen premises & Co2 flooding system in compressor found provided. Portable extinguishers DCP holding system in cascades, Advance fire water mist cum form trolley.

MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Ajay
21/6/22

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

DO (NW)

Ajay
29/06/2022

Sy/CS (W)
29/6/2022

CFO

Vijay
29/6/2022

Director / *(Signature)*
20/06/22

ADP/Kan

FT letter is put up for kind perusal and signature please.

Director / *(Signature)*
21/6/22

Ajay
21/6/22