



FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No.F6/DFS/MS/SZ/School/2022/ 738

Dated: 6/7/2022

FIRE SAFETY CERTIFICATE

Certified that the building of G.B.M Public School located at Shivani Enclave, Phase - 1, Kakrola, New Delhi, comprised of G + 1UF owned/occupied by **G.B.M Public School** was issued Fire Safety Certificate vide this department vide letter no. F.6/DFS/MS/School/2019/SZ/899 Dated 26/04/2019. The premises was re inspected by the officer concerned of this department on 22/06/2022 in the presence of Sh. Mool chand (Manager) and found that premises have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular 3298-3398 Dated 01/03/2011 and that the building is fit for occupancy class B "Educational building" with effect from 6/7/22 for a period of three years.

Issued on6/7/22..... at New Delhi by.


(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service.

Copy to:

1. The Principal G.B.M Public School located at Shivani Enclave, Phase - 1, Kakrola, New Delhi
2. Directorate of Education Old Secretariat Delhi - 110054.

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N-21

INSPECTION REPORT

1. Name & address of the building: G.B.M Public Scool located at Shivani Enclave, Phase - 1, Kakrola, New Delhi.
2. Type of Occupancy : Educational (G + 1UF)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/2019/SZ/899 Dated 26/04/2019
5. Fire Safety directives Letter No. : Circular. No 3298-3398 Dated 01/03/2011
6. Date of inspection : 22/06/2022
7. Name of the Inspecting Officer : Udai vir singh ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Mool chand
9. Year of Construction : 2000 - 2001
10. Applicant's letter No. : GBMPS/Fire/5/2022/15 Dated - 26/05/2022

No of Students= 377
No of class rooms= 24
Plot area= 2274 sq yard
Covered area= 10500sq feet

S No	Minimum standards on fire prevention and fire safety U/R 33	As per Circular. No 3298-3398 Dated 01/03/2011	Provided at site	Remarks MR/NMR
1.	Access of building	06 mtrs	Provided	MR
	• Road width	4.5mtrs	Directly accessible from road	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	02 Nos.	Provided	MR
	• Upper floors	NA	NA	NA
	• Basements			
	b. Width of staircases			
	• Upper floors	1.5 mtr	Provided	MR(Being old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	1.75 m	NA
	f. Door Size	1mtr	85cm	MR(Being old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA

JS

21-23

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F.6/DFS/MS/School/2019/SZ/899 Dated 26/04/2019 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name Uday Vir Singh
 Designation ADD/O/W/4

20/5/20
 27/6/22

Dyefo/sz

ADD (D/W/4)

Fire FT letter is put up for sign ple

Dyefo/sz

M.S. cell

27/6/22