

4/12

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No. F6/DFS/MS/School/2022/ W2 | 721

Dated: 29 / 6 / 2022

**FIRE SAFETY CERTIFICATE**

Certified that the **Sarvodaya Bal Bharti Public School** located at **A- Block, Gali No.10, West Sant Nagar, Burari, Delhi-110084** comprised of **02 blocks- Ground floor & Ground plus 01 upper floor only** owned/ occupied by **Sarvodaya Bal Bharti Public School** was issued Fire Safety Certificated by this department vide letter **No.F6/DFS/MS/2018/1306 dated 05.06.2018** The premises was re-inspected by the officer concerned of this department on **17.06.2022** in presence of **Sh. Ashish Kr. Gupta (Assistant Manager)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class "**Group B Educational**" with effect from 29/6/2022 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 29/6/2022 at New Delhi by.

(Dharampal Bhardwaj)  
Dy.Chief Fire Officer  
Ph:-011-23414250  
*bte op*

Copy to : -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Assistance Manager, Sarvodaya Bal Bharti Public School located at A- Block, Gali No.10, West Sant Nagar, Burari, Delhi-110084.

**Conditions for the validity of Fire Safety Certificate:**

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doit/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization ( Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration ( Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

**INSPECTION REPORT**

1. Name & address of the building Sarvodaya Bal Bharti Public School, A-2 Block, Gali No. 10, West Sant Nagar, Burari, Delhi-110084
2. Type of Occupancy Educational
3. Composition of building 02 blocks ( G+01 Floors & Ground floor)
4. Type of Case Renewal
5. Details of previous NOC F6 DFS/MS 2018/306 Dated 05 06 2018
6. Fire Safety directives letter No Nil
7. Date of inspection 17 06 2022
8. Name of the Inspecting Officers ADO (RN)
9. Name and designation of officers from the building side Mr Ashish Kr Gupta (Assistance Manager )
10. Year of Construction 2005
11. Applicant's letter No Online E-mail Dated-09 06 2022

Plot Area- 500 sq m approx Covered Area 800 sq m approx class rooms - 19 nos students - 495nos

	Minimum Standards on fire prevention and fire safety U/R 33	Circular of Director of Education	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	6m	6m	MR
		Directly Accessible	Directly Accessible	MR
		NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	01	02	MR
		NA	NA	NA
	b. Width of staircases	1.50m	1.25m & 1.10m	MR(old case)
		NA	NA	NA
	c. Protection of exits	NA	NA	NA
		NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
		NA	NA	NA
	e. Width of Corridor	1 m	1m	MR
	f. Door Size			
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	12 a/c per hour	NA	NA
		12 a/c per hour	Natural Ventilated	MR
5	<b>Fire Extinguishers</b>			

	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI marking</li> </ul>	06nos	10nos	MR
		ABC/CO2	ABC — 10	MR
		ISI Marked	Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	01	01	MR
		30m	30m	MR
		5mm	5mm	MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>	220 lpm	220 lpm	MR
		40m	40m	MR
		Required	Provided	MR
		N/A	N/A	N/A

MR

MR

MR

N/10

14

**Captive Water Storage for fire fighting.**

• Underground tank capacity	NA	NA	NA
➤ Draw-off connection	NA	NA	NA
➤ Fire service inlet	NA	NA	NA
➤ Access to tank	NA	NA	NA
• Overhead Tank capacity	2500ltr	Provided	MR

15

**Exit Signage.**

Required	Provided	MR
----------	----------	----

16

**Provision of Lifts.**

• Pressurization of Lift Shaft	N/A	N/A	N/A
• Pressurization of Lift lobby	N/A	N/A	N/A
• Communication In lift Car	N/A	N/A	N/A
• Fireman's Grounding Switch	N/A	N/A	N/A
• Lift Signage	N/A	N/A	N/A

17

**Standby power supply**

N/A	N/A	N/A
-----	-----	-----

18

**Refuge Area.**

➤ Total Area	N/A	N/A	N/A
➤ Location	N/A	N/A	N/A

19

**Fire Control Room**

• Detector System Panel	N/A	N/A	N/A
• Flow Switch Panel	N/A	N/A	N/A
• PA System Panel	N/A	N/A	N/A
• Batter backup	N/A	N/A	N/A
• Building Floor Plans	N/A	N/A	N/A

20

**Special Fire Protection Systems for Protection of special Risks, if any**

N/A	N/A	N/A
-----	-----	-----

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. 1306 dated 05.06.2018.

DO (MR)

21/06/2022  
24/06/2022

24/6/2022

Signature of the Inspecting Officer  
Name:-C.L. Meena  
Designation:- ADO/RN

ADO/P.N

As approved, F.T. letter is put up for your  
Signature Pl.

27/06/2022

P.T.O...