

FORM 'J': FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/2022/NDZ/ 743

Dated: 7 / 7 /2022

FIRE SAFETY CERTIFICATE

Certified that the Seth Bhagwan Dass Sr. Sec. Public School located at A-30/14B/17, Main Road Maujpur, Delhi-110053, comprised of Ground, 1st Floor & 2nd Floor only owned / occupied by Seth Bhagwan Dass Sr. Sec. Public School has already been issued Fire Safety Certificate Vide letter No. F6/DFS/MS/School/2019/NDZ/1859 dated 26/09/2019. The premises was re-inspected by the officer concerned of Fire Service on 29.06.2022 in the presence of Sh. Pramod Goyal (Manager) and observed that all the Fire Prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class "Educational" (Group-B) with effect from 7 / 7 /2022 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 7/7/22 at New Delhi by.



(Dr. S.K.TOMAR)

DY. CHIEF FIRE OFFICER

Copy to :-



1. The Manager, Seth Bhagwan Dass Sr. Sec. Public School, A-30/14B/17, Main Road Maujpur, Delhi-110053.

Conditions for the validity of Fire Safety Certificate:

1. **Fire Safety Certificate is valid for Ground, 1st Floor & 2nd Floor only.**
2. **Four Rooms on terrace should not be used for school purpose in any case.**
3. All the means of escape / entry / exit shall be kept free from any obstruction.
4. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
5. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
6. All the staff members must know the correct method of operation of fire fighting system.
7. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
8. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
9. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Seth Bhagwan Dass Sr. Sec. Public School, A-30/14B/17, Main Road Maujpur, Delhi-110053.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC No. : F6/DFS/MS/School/2019/NDZ/1859 dated 26/09/2019
5. Fire Safety directives Letter No.: NBC
6. Date of inspection : 29/06/2022
7. Name of the Inspecting Officer : Ashok Kumar Jaiswal, D.O. (East)
8. Name and designation of Officer from the building side : Sh. Pramod Goyal (Manager)
9. Year of Construction : 1988
10. Applicant's letter No. : SBDS/2022/37 dated 08/06/2022

Ground, 1st Floor, 2nd floor & 4 Rooms on terrace.

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL / NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	10 mtr	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 nos.	03 nos.	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50 m	1.50m & 0.88m x 2	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	01 nos.	02 nos.	MR
	e. Width Of Corridor	1.50 m	1.50 m	MR
	f. Door Size	1.00 m	1.00 m	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	10	10	MR
	• Types	ABC /CO ₂	Provided	MR
	• IS marking	ISI Marked	Provided	MR



6.	First - Aid Hose Reels			
	• Total numbers on each floor	1 nos.	Provided	MR
	• Length of hose reel hose	30 Mtr.	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	5,000 Ltr.	10,000 Ltr	MR

OK

15.	Exit Signage	N/A	N/A	N/A
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note : - School Building comprised of Ground, 1st Floor, 2nd Floor & 4 Rooms on terrace. Management has given an undertaking that they will not use these 4 rooms on terrace for school purpose and sealed by them (Attached at C/79).

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/2019/NDZ/1859 dated 26/09/2019 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

AJaiswal
29/06/22

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : D.O. (East)



Dy. CFO (NDZ)

AJaiswal
30/6/22

~~DOCFD~~

As At

for sign. phase.

.. letter is placed

AJaiswal
06/07/2022

Dy. CFO (NDZ)

AJaiswal
6/7/22

ms