

1185  
937

  
**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110001**

No. F.6/DFS/MS/EH/2022/SZ/190

Dated 30/6/2022

**FIRE SAFETY CERTIFICATE**

Certified that **M/s M. G Bakers Pvt Ltd. (NIK Bakers)** located at **Ground Floor, M-25, Greater Kailash-2, New Delhi 110048** in the building comprised of Basement, Ground plus 02 upper floors owned/occupied by Mr. Nitin Mittal was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/EH/2019/SZ/2079 dated 29/10/2019. The restaurant premise was re-inspected by the officer concerned of this department on 17/06/2022 in the presence of Mr. Nitin Mittal and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building"** Restaurant as above with effect from 30/6/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30/6/2022 at New Delhi by

  
**(SUNIL CHAWDHARY)**  
**DY. CHIEF FIRE OFFICER (SZ)**

Copy to :-

1. The Dy. Health Officer, Public Health Department, South Zone, Green Park, Delhi 110016 (Ref. MHA Portal 2022050509529 dated 13/05/2022)
2. The Joint Commissioner of Police, Lic/Branch, PS Defence Colony, New Delhi-49
3. M/s M. G Bakers Pvt Ltd. (NIK Bakers) located at Ground Floor, M-25, Greater Kailash-Part -II, New Delhi 110048.

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2 8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

M/19



## INSPECTION REPORT

1	Name & Address of the Building	M/s M G Bakers Pvt Ltd. (NIK Bakers) located at M-25, Greater Kailash-2, New Delhi 110048		
2	Type of Occupancy	Group-D Assembly Building (Eating House)		
3	Building Comprised of	Basement Ground plus Two upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F 6/DFS/MS/EH/2019/SZ/2079 dated 29/10/2019		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	17/06/2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Nitin Mittal		
10	Year of construction	2006	Restt. Running at Ground floor only	
11	Applicant letter No.	MHA Portal 2022050509529 dated 13/05/2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	• Road width	6 m	Provided	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>		Ground floor	
	➤ Upper floors.	N/A	N/A	N/A
	➤ Basement floor.	N/A	N/A	N/A
	<b>b) Width of Staircase</b>			
	➤ Upper floors	N/A	N/A	N/A
	➤ Basement floor	N/A	N/A	N/A
	<b>c) Protection of exits</b>			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	<b>d) No. of continuous staircase to terrace</b>	Required	Provided	MR
	<b>e) Width of corridor</b>	N/A	N/A	N/A
	<b>f) Door size</b>	2m & 1.50 m	1.5m & 2 m	MR
3	<b>Compartmentation.</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management system.</b>			
	• Basement	NA	N/A	N/A
	• Upper floors	12 ACPH	Exhaust Fans Provided	MR
5	<b>Fire Extinguishers.</b>			
	• Total numbers	06 Nos	06 Nos	MR
	• Types	ABC/CO <sub>2</sub>	ABC-04 & CO <sub>2</sub> -02	MR
	• ISI Marking	ISI marked	Provided	MR
6	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	One	Provided	MR

	<ul style="list-style-type: none"> <li>Length of hose-reel hose</li> </ul>	30m	Provided	MR
	<ul style="list-style-type: none"> <li>Nozzle Diameter</li> </ul>	5mm	Provided	MR
7	<b>Automatic fire detection &amp; alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	N/A	Smoke type	N/A
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	N/A	Ground floor	N/A
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	N/A	NA	N/A
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	N/A	Provided	N/A
	<ul style="list-style-type: none"> <li>Hooter's location</li> </ul>	N/A	Near entry/exit	N/A
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System</b>	N/A	N/A	N/A
10	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Ground/ upper floors.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Size of Riser/Down-comer</li> </ul>	100 mm	Provided	MR
	<ul style="list-style-type: none"> <li>Number of Hydrant per floor</li> </ul>	One	Provided	MR
	<ul style="list-style-type: none"> <li>Hose box.</li> </ul>	One	Provided	MR
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hose box.</li> </ul>	N/A	N/A	N/A
13	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li><b>Ground Level</b></li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of main pump</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Head of main pump.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Number of main pumps.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Jockey Pump output.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Jockey Pump head.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Standby Pump output.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Standby Pump head.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Auto Starting/Manual Stopping.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Pump house access.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li><b>Terrace Level</b></li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of pump.</li> </ul>	450 LPM	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Head of pump.</li> </ul>	40m	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Power supply.</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Auto starting of pump.</li> </ul>	Required	Provided	MR
14	<b>Captive water storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Draw-off connection.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Fire Service Inlet.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Access to tank.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Overhead tank capacity.</li> </ul>	20,000 Ltrs	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pressurization of lift lobby.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Communication in lift car.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Fireman's switch</li> </ul>	N/A	N/A	N/A



N/15



MR  
MR

N/A

N/A

N/A

N/A

N/A

	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room.			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

The fire protection system provided in the building were randomly checked and found functional at the time of inspection

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F 6/DFS/MS/EH/2019/SZ/2079 dated 29/10/2019, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended

*Sh*  
22/6/2022

Signature of the Inspecting Officer  
Name: Sh. Rajesh Kumar  
Designation: ADO (BCP)

DO (SB)

*LIFT*  
22/06/22

*Defo (2)*  
*sh.*

*ADO (BCP)*

As approved, F.T. letter is pending for your signature pl.

*1 Rec*  
29/6/22

*24/6/22*

*[Signature]*

*M.S. [Signature]*

uploaded  
*[Signature]*  
01/07/2022