

CRS

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No. F6/DFS/MS/School/2022 / 754

Dated: 13 / 7 / 2022

FIRE SAFETY CERTIFICATE

Certified that the **Sanskar Bharti School** located at **Pusta Road, Swaroop Nagar, Delhi-110042** comprised of Ground + First floor (**school is running at ground floor only**) owned/ occupied by **Sanskar Bharti School** was issued Fire Safety Certificated vide this office letter no. **F6/DFS/MS/2019/School/606** dated **25.03.2019**. The premises was re-inspected by the officer concerned of this department on **02.07.2022** in the presence of **Sh. D.K Sharma (Manager)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy "**Group B Educational**" for **ground floor only** with effect from**13.7.2022**..... for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on**13.7.2022**..... at New Delhi by.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph:-011-23414250

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Manager, Sanskar Bharti School located at Pusta Road, Swaroop Nagar, Delhi-110042.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doiit/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Sanskar Bharti School at Pusta Road, Swaroop Nagar, Delhi-110042.
2. Type of Occupancy : Educational
3. Composition of building : Ground & first floor but school is running at ground floor only
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/2019/School/606 Dated:25.03.2019
6. Fire Safety directives letter No : Nil
7. Date of inspection : 02.07.2022
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Mr. D.K. Sharma (Manager)
10. Year of Construction : 2009-10
11. Applicant's letter No. : Online E-mail dated: 25.06.2022

Plot Area-453 yards		Covered Area:450 Yards.		Class rooms -03 nos		No. of Student - 76		
	Minimum Standards on fire prevention and fire safety U/R 33	Circular of Director of Education	Provided at site	Remarks MR/NMR				
1	Access to building							
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	06m	08m	MR				
		NA	NA	NA				
		NA	NA	NA				
2	Number, Width, Type & Arrangement of Exits							
	a. Number of staircases	NA	01	NA				
		NA	NA	NA				
	b. Width of staircases	NA	1.50m	NA				
		NA	NA	NA				
	c. Protection of exits	NA	NA	NA				
		NA	NA	NA				
		NA	NA	NA				
	d. No. of continuous staircases to terrace	NA	NA	NA				
	e. Width of Corridor	1m	1m	MR				
	f. Door Size							
	3	Compartmentation.						
		<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	NA	NA	NA			
			NA	NA	NA			
NA			NA	NA				
NA			NA	NA				
NA			NA	NA				
NA	NA	NA						
4	Smoke Management System.							
	<ul style="list-style-type: none"> Basements Upper floors 	NA	NA	NA				
		NA	NA	NA				
5	Fire Extinguishers							
	<ul style="list-style-type: none"> Total numbers 	02nos	03nos	MR				

	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	N/A	NA
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no.606 dated 25.03.2019.

DO (NW) — ON leave

Dy S/O (WZ)

[Handwritten signature]
S/O (WZ)

[Handwritten signature]
Signature of the Inspecting Officer
Name:- C.L. Meena
Designation:- ADO/RN

~~Asst P-N~~

Dy S/O (WZ)

WZ/ WZ

As approved, F.T. letter is kept for your signature be.

[Handwritten signature]
S/O (WZ)

[Handwritten signature]
11/07/2022