

C-23

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2022 / School / WZ / 758

Dated 15/7/22

FIRE SAFETY CERTIFICATE

Certified that the **M.C. Primary Model Girls School** located at **Siraspur, Delhi-110042** comprised of **03 Blocks (01-Block Ground+One upper floor & 02 Blocks Ground Floor Only)** owned/ occupied by **M.C. Primary Model Girls School** have complied with the fire prevention and fire safety requirements in accordance with DOE circular no. 3298-3398 dated 01.03.2011 and verified by the officers concerned of Fire Service on **05.07.2022** in the presence of **Smt. Sunita Rana (Principal)** and found that the building/ premises is fit for **occupancy Group B Educational** with effect from 15/7/22 for a period of **03 (Three) years** subject to compliance of the conditions mentioned below:

Issued on ..15..7..22.. at New Delhi by


(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. The Director , Education, Government of NCT of Delhi. Old Sect. Delhi-110054.
2. The Principal , M.C. Primary Model Girls School, Siraspur , Delhi-110042.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building : M.C. Primary Model Girls School , Siraspur , Delhi-110042.
2. Type of Occupancy : Educational
3. Building comprised : 03 Blocks (01Block-Ground+ One upper floor & 02 Blocks Ground Floor)
4. Type of Case : New Case
5. Details of Previous NOC : Nil
6. Fire Safety directives letter No : Dir of Edu. Cir 01/03/2011
7. Date of inspection : 05/07/2022
8. Name of Inspecting Officer : ADO R.K Sinha
9. Name and designation of officers
From the building side : Smt. Sunita Rana (Principal)
10. Year of Construction : 2011
11. Applicant's letter No. : E mail id , Dated-07/05/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6.0 m	6.0 m	MR
	• Gate width	4.5 m	4.5 m	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	NA	NA	NA
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases	NA	NA	NA
	• Upper Floor	1.50 m	1.80 m each	MR
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
		02	02	MR
	e. Width of Corridor	1.50 m	1.50 m	MR
	f. Door Size	1.20 m	1 m double door	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR



5.	Fire Extinguishers			
	• Total numbers	07	08	MR
	• Types	ABC	ABC	MR
	• IS marking	Yes	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	30 m	NA	NA
	• Nozzle diameter	5 mm	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System	NA	NA	NA
	• Basement	NA	NA	NA
	• Ground Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA

h

14.

MR	<ul style="list-style-type: none"> • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	-	-	-
MR		NA	NA	NA
N		NA	NA	NA
		NA	NA	NA
		-	-	-
		NA	NA	NA
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15.	Exit Signage.			
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply			
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:			
	NA	NA	NA	

Ph

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. Management has compiled all the shortcomings issued and communicated by this department vide letter no. F6/DFS/MS/School/2015/06 dated 02/01/2015.

Keeping in view of the satisfactory compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular no. 3298-3398 dated 01.03.2011 it is recommended to Grant Fire Safety Certificate.

~~Do (pts) on leave.~~

~~Dy cfo (w2)~~

~~[Signature]~~
8/7/22

~~cfo~~ ~~[Signature]~~
8/7/22

~~Director~~ ~~[Signature]~~
8/7/22

~~ADP/BN~~ F-T letter is put up for signing

~~[Signature]~~
ADP(BN)
12/7/22

~~Director (pts)~~ ~~[Signature]~~
12/7/22

12

~~[Signature]~~
ADP(BN)
6/7/22

Signature of Inspecting Officer

Name : Rajeev Kumar Sinha

Designation : ADO/BW