

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/Club/2022/SZ/ 315

Dated: 19/07/2022

FIRE SAFETY CERTIFICATE

Certified that **Defence Colony Welfare Association** Club located at C-600 Chatana Marg, Defence Colony, New Delhi-110024 comprised of ground plus One upper floor owned/occupied by **Defence Colony Welfare Association** was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/Club/2019/SZ/1317 dated 19/06/2019. The premises was re-inspected by officer concerned of this department on 18/07/2022 in the presence of Mr. Dushant Kumar and found that the said Club building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that building is fit for occupancy class "**Assembly Group "D" (Club Building)**" as above with effect from/...../2022 for period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 19/07/2022 at New Delhi by



(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)
DELHI FIRE SERVICE

Copy to: -

1. The Manager, Defence Colony Welfare Association Club located at C-600 Chatana Marg, Defence Colony, New Delhi-110024.
2. The Executive Engineer (Bldg) HQ, South Delhi Municipal Corporation, 9th Floor, Civic Centre Minto Road, New Delhi 110002.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. The basement shall be used as per the provisions of BBL /NBC Part- IV.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry

INSPECTION REPORT

1	Name & Address of the Building	Defence Colony Welfare Association Club at C-600 Charana Marg, Defence Colony, New Delhi-110024			
2	Type of Occupancy	Club Building (Assembly occupancy i.e. Eating House)			
3	Building Comprised of	Ground + 01 upper floors.			
4	Type of Case	Renewal			
5	Details of Previous NOC	F6/DHS/MS/Club/2019/SZ/1317 dated 19/06/2019			
6	Fire Safety Directives Letter No	Nil			
7	Date of Inspection	18-07-2022			
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)			
9	Name & Designation of Officers from the building side	Mr. Dushant Kumar			
10	Year of construction	1976			
11	Applicant letter No.	Gmail dated 14-07-2022			
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R/33	requirements	Provided at Site	Remarks	MR/MMR
1.	Access to Building.				
	• Road width	12 mtr	12 mtr	MR	MR
	• Gate width	5 mtr	5 mtr	MR	MR
	• Width of internal road	-NA-	-NA-	-NA-	-NA-
2.	Number, width, type & arrangement of exits.				
	a) Number of Staircase				
	➤ Upper floors.	03 Nos	Provided	MR	MR
	➤ Basement floor.	-NA-	-NA-	-NA-	-NA-
	b) Width of Staircase				
	➤ Upper floors	1.25m	1.17m, 1.05m & 0.59m	MR	MR
	➤ Basement floor	-NA-	-NA-	-NA-	-NA-
	c) Protection of exits				
	➤ Fire check door	-NA-	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	01 Nos	MR	MR
	e) Width of corridor	-NA-	-NA-	-NA-	-NA-
	f) Door size	1m	Provided	MR	MR
3.	Compartmentation.				
	• Fire check door.	-NA-	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	Required	Provided	MR	MR
	• Fire rating of shaft door.	-NA-	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-	-NA-
4.	Smoke Management system.				
	• Basement	-NA-	-NA-	-NA-	-NA-
	• Upper floors	12 ACPH	Exhaust fan provided	MR	MR
5.	Fire Extinguishers.				
	• Total numbers	Required	25 Nos	MR	MR
	• Types	ABC/CO2	ABC & CO2	MR	MR
	• ISI Marking	ISI marked	Provided	MR	MR
6.	First Aid Hose Reels.				
	• Total numbers on each floor.	01 No each	Provided	MR	MR
	• Length of hose-reel hose	30m	Provided	MR	MR
	• Nozzle Diameter	5mm	Provided	MR	MR

N/3^{AD}

7.	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	-NA-	-NA-	-NA-
		Required	Provided	MR
		-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	Required	100 mm	MR
		Required	One	MR
		Required	One	MR
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	Required	04 Provided	MR
		Required	04 Provided	MR
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump house access. Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		900 & 180 LPM	Provided	MR
		35m each	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		Required	Provided	MR
		-NA-	-NA-	-NA-
		5,000 Lts	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17.	Standby Power Supply	Required	Provided (DG Set)	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
19.	Fire Control Room.			

N/31

	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The Fire protection systems provided in the building / premises were test checked at random and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/Club/2019/SZ/1317 dated 19/06/2019, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

Handwritten signature and date: 14/7/22

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

Dy. CFO (SZ)

Handwritten signature and initials: f.g.

Handwritten text: ADO BCP

Handwritten text: ADO/BCP

Handwritten text: As approved, F.T. letter is put up for your signature pl

Handwritten signature and date: 14/19/07/22

Handwritten signature and text: Dy CFO/SZ

Handwritten signature

Handwritten signature: M.S. [Signature]