

C-19

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F6/DFS/MS/2022/School/ W2/765


Dated: 18/7/2022

FIRE SAFETY CERTIFICATE

Certified that the **Nigam Pratibha Kanya Vidyalaya (I.D No. 1253004)** located at **I- Block, Jahangir Puri, Delhi-110033** comprised of **02 blocks- ground and first floors only** owned/ occupied by the **Nigam Pratibha Kanya Vidyalaya** have complied with the fire prevention and safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on **08.07.2022** in the presence of **Sh. Naresh Kumar (Principal)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class "**Group B Educational**" with effect from 18/7/2022 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 18/7/2022 at New Delhi


(Atul Garg)
Director

Ph:-011-23414000


Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Nigam Pratibha Kanya Vidyalaya located at I- Block, Jahangir Puri, Delhi-110033.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building	: Nigam Pratibha Kanya Vidyalaya I-Block, Jahangirpuri, Delhi-110033
2. Type of Occupancy	: Educational
3. Type of Case	: New Case
4. Composition of building	: 02 blocks (Ground & first floor only)
5. Details of previous NOC	: Nil
6. Fire Safety directives letter No	: Nil
7. Date of inspection	: 08.07.2022
8. Name of the Inspecting Officers	: ADO (RN)
9. Name and designation of officers from the building side	: Sh. Naresh Kumar (Principal)
10. Year of Construction	: 2004-2014
11. Applicant's letter No.	: Letter No. Nil dated: 18.06.2022 & DFS Dairy No 2604 dated: 20.08.2022

Plot Area- 6600Sq. yard Covered Area: 3400Sq yard No of class rooms 34 nos No. of students 1005nos.

	Minimum Standards on fire prevention and fire safety U/R 33	Director of education dt 01.03.2011 <i>Requirements</i>	Provided at site	Remarks MR/MR
1	Access to building			
	• Road width	06m	06m	MR
	• Gate width	Directly accessible	Directly accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	04	05	MR
	• Upper Floors	NA	NA	NA
	• Basements			
	b. Width of staircases			
	• Upper Floors	1.5m	A-block 1.70, 1.80, 1.88m B-block 1.45 & 1.12m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 m	1m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	12 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5	Fire Extinguishers			
	• Total numbers	12Nos	12nos	MR
	• Types	ABC/Co2	ABC-12	MR

	<ul style="list-style-type: none"> • ISI marking 	ISI Marked	Provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA			
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

	<ul style="list-style-type: none"> Overhead Tank capacity 	NA	NA	NA
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Batter backup Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection. The management has complied all the shortcomings issued and communicated by this department vide letter of even no. 2807 dated 11.12.2014.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education Circular, it is recommended to grant of fire safety certificate.

DO (NW)

[Signature]
11/07/2022

[Signature]
13/7/2022

[Signature]
13/7/2022

CFO

[Signature]
13/7/2022

Director

[Signature]
14/07/22

[Signature]

[Signature]
11/07/2022

Signature of the Inspecting Officer
Name :- C.L. Meena
Designation:- ADO/RN

Conf.....

P.T.O.