

C-60

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**  
**NEW DELHI- 110001**

No.F6/DFS/MS/School/2022/SZ/ 742

Dated: 06/7/2022

**FIRE SAFETY CERTIFICATE**

Certified that the Sat Saheb Public School running at ground plus two upper floors in a building comprised of ground plus three upper floors located at 101, C-Block, Som Bazar, Nanhey Park, Uttam Nagar, New Delhi-110059, owned/occupied by Sat Saheb Public School was issued Fire Safety Certificate by this department vide letter No F.6/DFS/MS/school/2018/SZ/1581 dated-06/07/2018. The school building was re-inspected by the officer concerned of this department on dated 21/06/2022 in the presence of Smt. Vidhi Dabas and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 35 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on..... 06/7/2022 ..... at New Delhi.



(Sunil Chawdhary)

**Dy. Chief Fire Officer**  
Delhi Fire Service



Copy to:-

1. The Principal,  
Sat Saheb Public School, 101, C-Block,  
Som Bazar, Nanhey Park, Uttam Nagar, New Delhi-110059.
2. Director of Education,  
GNCT of NCT of Delhi, Old Secretariat,  
Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

**INSPECTION REPORT**

- 1. Name & address of the building : Sat Saheb Public School, 101, C-Block, Som Bazar, Nanhey Park, Uttam Nagar, New Delhi-110059.
- 2. Building is comprised of : G + 3 but school running at ground plus two upper floors
- 3. Type of Occupancy : Educational
- 4. Type of Case : Renewal
- 5. Details of Previous NOC : F-6/D/S/MS/School/2018/SZ/1581 dated 06/07/2018
- 6. Fire Safety directives letter No : N/A
- 7. Date of inspection : 21/06/2022
- 8. Name of Inspecting Officer : A.D.O. R.K. Yadav
- 9. Name and designation of officers : Smt. Vidhi Dabas (Principal)  
From the building side
- 10. Year of Construction : Before 2006
- 11. Applicant's letter No : Nil dated 27/05/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Accessible 4.5 m N/A	4.5 m Directly accessible from road N/A	M/R, being old case M/R N/A
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	02 No.'s N/A	03 No.'s N/A	M/R N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	1.50 m N/A	1.50 m N/A	M/R N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	Required	Provided	MR
		1.50 m.	1.50/1.0 m	MR, being old case
	e. Width of Corridor			
	f. Door Size	1.0 m	.90/1.0 m	MR, being old case
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	Required	Natural ventilation provided	M/R
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	10 no.'s ABC/CO <sub>2</sub> type ISI marked	Provided Provided Provided	MR MR MR



NISG

16. Provision of Lifts.		No Lift		
<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Battery backup</li> <li>• Building Floor Plans</li> </ul>		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC was issued vide letter no. F 6/DFS/MS/school/2018/SZ/1581 dated-06/07/2018 renewal under the Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

*R. Keel*  
24/6/2022

Signature of Inspecting Officer  
Name:-R.K.Yadav  
Designation:-Asstt. Divisional Officer

D.O. (South West)

*ADP*  
22/6/22

*F.F.*

*Dy. Insp. (S2)*

*ADP (S2)*

AT letter is put up for signature plea

*Dy. Insp. (S2)*

Please speak to

*Keel*  
25/6/2022

*ADP (S2)*