



FORM 'H'

FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[Refer sub - rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/SZ/2022/BNQT/33

Dated: 04/07/2022

**FIRE SAFETY CERTIFICATE**

Certified that the. **Shri Govindam (A Unit of Gokul Garden Banquets Pvt. Ltd)** Located at 1<sup>st</sup> & 2<sup>nd</sup> Floors, WZ 306 – O – ELD - 67 , Khasra No. 72/6/1, Data Ram Marg, Chotiyal Palam Village, New Delhi – 110045 in a building comprised of Basement + Ground + 3 Upper Floors owned/ occupied by **Gokul garden Banquets Pvt. Ltd** have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 10/06/2022 in the presence of Sh. Rajeev Solanki (Director) and found that the said building that the premises is fit for occupancy class “ Assembly” Group D (At 1<sup>st</sup> & 2<sup>nd</sup> Floors only) with effect from 04/07/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 04/07/2022 at New Delhi by.

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to:

1. The Joint Commissioner Police, Licensing, 1<sup>st</sup> Floor, PS, Defence Colony, N Delhi.
2. The Dy. Health Officer, South Delhi Municipal Corporation, Najafgarh Zone, Dhansa Stand Najafgarh New Delhi.
3. Sh. Rajeev Solanki (Director) **Shri Govindam (A Unit of Gokul Garden Banquets Pvt. Ltd)** Located at 1<sup>st</sup> & 2<sup>nd</sup> Floors, WZ 306 – O – ELD - 67 , Khasra No. 72/6/1, Data Ram Marg, Chotiyal Palam Village, New Delhi.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

INSPECTION REPORT

N/10

1. Name & address of the building: **Shri Govindam (A Unit of Gokul garden Banquets Pvt. Ltd)** Located at **1<sup>st</sup> & 2<sup>nd</sup> Floors**, WZ 306 – O – ELD - 67 , Khasra No. 72/6/1, Data Ram Marg, Chotiyal Palam Village, New Delhi – 110045
2. Type of Occupancy : **Assembly** (At 1<sup>st</sup> & 2<sup>nd</sup> Floors) building comprised of Basement + Ground + 3 Upper Floors
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 10/06/2022
7. Name of the Inspecting Officer : DO/SW & ADO (DWK)
8. Name and designation of Officer
  - a. from the building side : Sh. Rajeev Solanki (Director)
9. Year of Construction : 2011
10. Applicant's letter No. : 2022052210810 dated 30/11/2021 & Email dated 30/05/2022

| S No | Minimum standards on fire prevention and fire safety U/R 33 | NBC Requirement | Provided at site | Remarks MR/NMR |
|------|---|-----------------|------------------|----------------|
| 1.   | Access of building  |                 |                  |                |
|      | • Road width  | 9 m             | Provided         | MR             |
|      | • Gate width  | 5 m             | On Road          | MR             |
|      | • Width of internal road                                    | NA              | NA               | NA             |
| 2.   | Number, width, Type & Arrangements of exits                 |                 |                  |                |
|      | a. Number of staircases                                     |                 |                  |                |
|      | • Upper floors  | 2               | Provided         | MR             |
|      | • Basements   | 2               | Provided         | MR             |
|      | b. Width of staircases                                      |                 |                  |                |
|      | • Upper floors  | 2m,1.5m         | Provided         | MR             |
|      | • Basements   | 2m,1.5m         | Provided         | MR             |
|      | c. Protection of exits                                      |                 |                  |                |
|      | • Fire check door   | Required        | Provided         | MR             |
|      | • Pressurization  | NA              | NA               | NA             |
|      | d. No of continuous staircase to terrace                    | Required        | Provided         | MR             |
|      | e. Width Of Corridor  | NA              | NA               | NA             |
|      | f. Door Size  | 2m,1.5m         | Provided         | MR             |



N/11

|     |   |                      |                             |     |
|-----|---|----------------------|-----------------------------|-----|
| 3.  | Compartmentation  |                      |                             |     |
|     | <ul style="list-style-type: none"> <li>• Fire check door</li> </ul>               | Required at Basement | Provided                    | MR  |
|     | <ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>  | NA                   | NA                          | NA  |
|     | <ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>     | NA                   | NA                          | NA  |
|     | <ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>                 | NA                   | NA                          | NA  |
|     | <ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>                  | NA                   | NA                          | NA  |
| 4.  | Smoke managements System  |                      |                             |     |
|     | <ul style="list-style-type: none"> <li>• Basements</li> </ul>                     | Required             | Provided                    | MR  |
|     | <ul style="list-style-type: none"> <li>• Upper floors</li> </ul>                  | Required             | Provided                    | MR  |
| 5.  | Fire Extinguishers  |                      |                             |     |
|     | <ul style="list-style-type: none"> <li>• Total numbers</li> </ul>                 | 15 nos.              | Provided                    | MR  |
|     | <ul style="list-style-type: none"> <li>• Types</li> </ul>                         | ABC & CO2            | Provided                    | MR  |
|     | <ul style="list-style-type: none"> <li>• IS marking</li> </ul>                    | ISI marked           | Provided                    | MR  |
| 6.  | First – Aid Hose Reels  |                      |                             |     |
|     | <ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>   | 02                   | Provided                    | MR  |
|     | <ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>      | 30 m                 | Provided                    | MR  |
|     | <ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>               | 5 mm                 | Provided                    | MR  |
| 7.  | Automatic fire detection and alarming system                                      |                      |                             |     |
|     | <ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>             | Required             | Provided                    | MR  |
|     | <ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>        | Required             | Provided                    | MR  |
|     | <ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>    | Required             | Provided                    | MR  |
|     | <ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>     | Required             | Provided                    | MR  |
|     | <ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>             | Required             | Provided                    | MR  |
| 8.  | MOEFA   | Required             | Provided                    | MR  |
| 9.  | Public Address System   | Required             | Provided                    | MR  |
| 10. | Automatic Sprinkler System  |                      |                             |     |
|     | <ul style="list-style-type: none"> <li>• Basements</li> </ul>                     | Required             | Provided but non functional | NMR |
|     | <ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>                   | NA                   | NA                          | NA  |
|     | <ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul> | NA                   | NA                          | NA  |
| 11. | Internal Hydrants   |                      |                             |     |
|     | <ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>      | 150 mm               | Provided                    | MR  |
|     | <ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> </ul>  | 2                    | Provided                    | MR  |
|     | <ul style="list-style-type: none"> <li>• Hose Box</li> </ul>                      | 2                    | Provided                    | MR  |
| 12. | Yard Hydrants   |                      |                             |     |
|     | <ul style="list-style-type: none"> <li>• Total number of hydrants</li> </ul>      | NA                   | NA                          | NA  |
|     | <ul style="list-style-type: none"> <li>• Hose Box</li> </ul>                      | NA                   | NA                          | NA  |

*(Handwritten signature)*

*(Handwritten mark)*



|   |             |           |    |
|---|-------------|-----------|----|
| 13. Pumping Arrangements                    |             |           |    |
| • Ground Level                              | 2280lpm     | Provided  | MR |
| • Discharge of main pump                    | 70m         | Provided  | MR |
| ➤ Head of main pump                         | 1           | Provided  | MR |
| ➤ Number of main pumps                      | 180lpm      | Provided  | MR |
| ➤ Jockey pump out put                       | 70m         | Provided  | MR |
| ➤ Jockey pump head                          | 2280lpm     | Provided  | MR |
| ➤ Standby Pump out put                      | NA          | Provided  | MR |
| ➤ Standby Pump Head                         | Required    | Provided  | MR |
| ➤ Auto Staring/Manual stopping              | Required    | Provided  | MR |
| ➤ Pump House Access                         |             |           |    |
| • Terrace level                             |             |           |    |
| ➤ Discharge of pump                         | 900 lpm     | Provided  | MR |
| ➤ Head of the pump                          | 40 m        | Provided  | MR |
| ➤ Power supply                              | Required    | Provided  | MR |
| ➤ Auto starting of pump                     | Required    | Provided  | MR |
| 14. Captive water Storage for fire fighting |             |           |    |
| • Under ground tank capacity                | 150000 L    | Provided  | MR |
| ➤ Draw of connection                        | Required    | Provided  | MR |
| ➤ Fire service inlet                        | Required    | Provided  | MR |
| ➤ Access to tank                            | Required    | Provided  | MR |
| • Overhead Tank capacity                    | 10,000 ltrs | 10000 ltr | MR |
| 15. Exit Signage                            | Required    | Provided  | MR |
| 16. Provision of Lifts                      |             |           |    |
| ➤ Pressurization of Lift Shaft              | NA          | NA        | NA |
| ➤ Pressurization of lift lobby              | NA          | NA        | NA |
| ➤ Communication in lift Car                 | Required    | Provided  | MR |
| ➤ Fireman's Grounding Switch                | Required    | Provided  | MR |
| ➤ Lift Signage                              | Required    | Provided  | MR |
| 17. Standby power supply                    | Required    | Provided  | MR |
| 18. Refuge Area                             |             |           |    |
| ➤ Total area                                | NA          | NA        | NA |
| ➤ Location                                  | NA          | NA        | NA |
| 19. Fire control room                       |             |           |    |
| ➤ Detector system panel                     | NA          | NA        | NA |
| ➤ Flow Switch Panel                         | NA          | NA        | NA |
| ➤ PA System Panel                           | NA          | NA        | NA |
| ➤ Battery backup                            | NA          | NA        | NA |
| ➤ Building Floor Plans                      |             |           |    |

N/13

|     |  |    |    |    |
|-----|--|----|----|----|
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NA | NA | NA |
|-----|--|----|----|----|

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules 2010.

*[Signature]*  
13/6/22

Sign. of the Inspecting Officer  
Name Sh. Veal Pal  
Designation DO (SW)

*[Signature]*  
10/6/22

Sign. of the Inspecting Officer  
Name Uday Vir Singh  
Designation ASO (SW)

Dy CFO (S2)

*[Signature]*  
15/6

CFO - 16/6/2022

Director, when is the for gathering  
*[Signature]*  
17/6

CFO 17/6/2022

Dy CFO (S2) Reproduced letter  
DO (SW) dtd 12/2/21  
ASO (SW) *[Signature]*

ADD (Machan)