



No. F6/DFS/MS/CNG/2022/WZ/ 323

Dated: 22/07/2022

FIRE SAFETY CERTIFICATE

Certified that the CNG Hybrid Station at Keshopur, adjacent to Keshopur DTC Depot, Delhi Comprised of Ground Floor only (01 Nos. dispenser only) owned/occupied by M/s. Indraprastha Gas Limited, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 18.06.2022 in the presence of Sh. Sanchit, (Dy. Manager) and that the building/Premises is fit for occupancy "Hazardous Building" Group - J (CNG Pump) as above with effect from 22/07/2022 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010 below.

Issued on 22/07/22 at New Delhi by

(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. Sh. Ajay Khatri, DGM (Fire & Safety), IGL Bawan, Plot no. 4, Community Centre, Sector-9, R.K. Puram, New Delhi-110022.

Conditions for the validity of Fire Safety Certificate:-

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of authorized construction or alteration (Clause of 1.4.3 of UBBL-2016), if any.
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & Address of the Building	CNG Hybrid Station at Keshopur, adjacent to Keshopur DTC Depot, Delhi		
2	Type of Occupancy	Hazardous "Group- J"		
3	Type of Case	New (comprised of ground floor only & & having 01 Compressor & 01 Dispenser at ground floor)		
4	Details of Previous NOC	Nil		
5	Fire Safety Directives Letter No	F6/DFS/MS/CNG/2019/756 dated 06.02.2019		
6	Date of Inspection	28.06.2022		
7	Name of the Inspecting Officers	Aman Kumar Lathar, ADO (JWP)		
8	Name & Designation of Officers from the building side	Sh. Sanchit (Dy. Manager)		
9	Year of construction	2020-21		
10	Applicant letter No.	IGL/F&S/2022/15/116/1 dated 26.05.2022		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	NFPA/CCOE/OISD etc. requirements	Provided at Site	Remarks NR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> 06 m 05 m -N/A- 	<ul style="list-style-type: none"> 45 m Direct accessible from road -N/A- 	<ul style="list-style-type: none"> MR MR -N/A-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	<ul style="list-style-type: none"> ➤ Upper floors. ➤ Basement floor. 	<ul style="list-style-type: none"> -N/A- -N/A- 	<ul style="list-style-type: none"> -N/A- -N/A- 	<ul style="list-style-type: none"> -N/A- -N/A-
	b) Width of Staircase			
	<ul style="list-style-type: none"> ➤ Upper floors ➤ Basement floor 	<ul style="list-style-type: none"> -N/A- -N/A- 	<ul style="list-style-type: none"> -N/A- -N/A- 	<ul style="list-style-type: none"> -N/A- -N/A-
	c) Protection of exits			
	<ul style="list-style-type: none"> ➤ Fire check door ➤ Pressurization 	<ul style="list-style-type: none"> -N/A- -N/A- 	<ul style="list-style-type: none"> -N/A- -N/A- 	<ul style="list-style-type: none"> -N/A- -N/A-
	d) No. of continuous staircase to terrace	-N/A-	-N/A-	-N/A-
	e) Width of corridor	-N/A-	-N/A-	-N/A-
	f) Door size	-N/A-	-N/A-	-N/A-
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door. • Sealing of electrical shafts. • Fire rating of shaft door. • Water curtain • Fire dampers. 	<ul style="list-style-type: none"> -N/A- -N/A- -N/A- -N/A- -N/A- 	<ul style="list-style-type: none"> -N/A- -N/A- -N/A- -N/A- -N/A- 	<ul style="list-style-type: none"> -N/A- -N/A- -N/A- -N/A- -N/A-
4.	Smoke Management system.			
	<ul style="list-style-type: none"> • Basement • Upper floors 	<ul style="list-style-type: none"> -N/A- -N/A- 	<ul style="list-style-type: none"> -N/A- -N/A- 	<ul style="list-style-type: none"> -N/A- -N/A-
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI Marking 	<ul style="list-style-type: none"> Required DCP & CO₂ ISI marked 	<ul style="list-style-type: none"> Provided DCP 9kg - 04 & CO₂ 4.5 kg -02 Provided 	<ul style="list-style-type: none"> MR MR MR

6.	First Aid Hose Reels.			
	• Total numbers on each floor	-N/A-	-N/A-	-N/A-
	• Length of hose-reel hose.	-N/A-	-N/A-	-N/A-
	• Nozzle Diameter	-N/A-	-N/A-	-N/A-
7	Automatic fire detection & alarming system.			
	• Detector	-N/A-	-N/A-	-N/A-
	• Location of Main Panel	-N/A-	-N/A-	-N/A-
	• Location of Repeater Panel	-N/A-	-N/A-	-N/A-
	• Alternate source of power	-N/A-	-N/A-	-N/A-
	• Hooter's location	-N/A-	-N/A-	-N/A-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-N/A-	-N/A-	-N/A-
10.	Automatic Sprinkler System			
	• Basement.	-N/A-	-N/A-	-N/A-
	• Upper floors	-N/A-	-N/A-	-N/A-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	• Size of Riser / Down-comer	-N/A-	-N/A-	-N/A-
	• Number of Hydrant per floor	-N/A-	-N/A-	-N/A-
	• Hose box.	-N/A-	-N/A-	-N/A-
12.	Yard Hydrants.			
	• Total number of hydrants.	-N/A-	-N/A-	-N/A-
	• Hose box.	-N/A-	-N/A-	-N/A-
13.	Pumping arrangements.			
	• Ground Level			
	Discharge of main pump.	-N/A-*	-N/A-	-N/A-
	➤ Head of main pump.	-N/A-	-N/A-	-N/A-
	➤ Number of main pumps.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump output.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump head.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump output.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump head.	-N/A-	-N/A-	-N/A-
	➤ Auto Starting/Manual stopping.	-N/A-	-N/A-	-N/A-
	➤ Pump house access.	-N/A-	-N/A-	-N/A-
	• Terrace Level			
	➤ Discharge of pump.	-N/A-	-N/A-	-N/A-
	➤ Head of pump.	-N/A-	-N/A-	-N/A-
	➤ Power supply.	-N/A-	-N/A-	-N/A-
	➤ Auto starting of pump.	-N/A-	-N/A-	-N/A-
14.	Captive water storage for firefighting.			
	• Underground tank capacity.	-N/A-	-N/A-	-N/A-
	➤ Draw-off connection.	-N/A-	-N/A-	-N/A-
	➤ Fire Service Inlet.	-N/A-	-N/A-	-N/A-
	➤ Access to tank.	-N/A-	-N/A-	-N/A-
	• Overhead tank capacity.	-N/A-	-N/A-	-N/A-
15.	No Smoking Signage	Required	Provided in Hindi & English	MR

30/10/20
2/20

16. Provision of Lifts.				
	• Pressurization of lift shaft.	-N/A-	-N/A-	-N/A-
	• Pressurization of lift lobby.	-N/A-	-N/A-	-N/A-
	• Communication in lift car.	-N/A-	-N/A-	-N/A-
	• Fireman's switch.	-N/A-	-N/A-	-N/A-
	• Lift signage.	-N/A-	-N/A-	-N/A-
17	Standby Power Supply	-N/A-	Provided (DG Set)	-N/A-
18. Refuge Area				
	• Total area	-N/A-	-N/A-	-N/A-
	• Location	-N/A-	-N/A-	-N/A-
19. Fire Control Room.				
	• Detector System Panel.	-N/A-	-N/A-	-N/A-
	• Flow Switch Panel.	-N/A-	-N/A-	-N/A-
	• PA system Panel.	N/A-	N/A-	N/A-
	• Battery backup	-N/A-	-N/A-	-N/A-
	• Building floor plan	-N/A-	-N/A-	-N/A-
20.	Special Fire Protection System for the Protection of special Risk, if any.	Fire water mist cum foam trolley-01 No., two hand held explosive meter	Provided	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards of fire prevention and fire safety requirements as per fire safety guidelines issued vide letter no. F6/DFS/MS/CNG/2019/756 dated 06.02.2019, it is recommended to issue Fire Safety Certificate.

Note: CNG compressor is placed elsewhere outside the CNG pump plot area.

Accordingly DFA is put up for approval and signature please.

With 11
02/10/22
 Aman Kumar Lathar
 ADO (JWP)

DDP on leave

DDFO (W2)

[Signature]
18/7/22

CFO

[Signature]
13/7/2022

Director
[Signature]
14/07/22

Director
[Signature]
19/07/22

Sir,
F.I. letter is put-up for your signature M.

With 11
15/7/22
AM (JWP)