

421

75  
आज़ादी का  
अमृत महोत्सव

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[See sub-rule (1) of rule 35]  
**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F.6/DFS/MS/BNQT/2022/NDZ/ 35

Dated: 15 / 7 / 2022

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Khursheeda Palace (Banquet Hall) located at C-150, Kh. No. 142/2, 101/1 & 128/1, Near Sheshewali Masjid Ghonda, Delhi-110053 in a building comprised of Ground Floor, 1<sup>st</sup> Floor & 2<sup>nd</sup> Floor only but Banquet Hall is running on ground & 1<sup>st</sup> Floor owned / occupied by M/s Khursheeda Palace was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/NDZ/2019/726 dated 05/04/2019. The premises was re-inspected by the officer concerned of Fire Service on 07/07/2022 in the presence of Sh. Mohd. Jameel Khan and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class Assembly (Banquet Hall) with effect from 15 / 07 / 2022 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 15 / 07 / 2022 at New Delhi by

  
(S.K. Dua)

**Dy. CHIEF FIRE OFFICER.**

Copy to :-

1. Mr. Mohd. Jameel Khan, M/s Khursheeda Palace (Banquet Hall), C-150, Kh. No. 142/2, 101/1 & 128/1, Near Sheshewali Masjid Ghonda, Delhi-110053.
2. Joint Commissioner of Police(Lic.), 1<sup>st</sup> Floor, PS Defence Colony, New Delhi-110049.

**Conditions for the validity of Fire Safety Certificate:**

1. **Fire Safety Certificate is valid for Ground & 1st Floor only.**
2. All the means of escape / entry / exit shall be kept free from any obstruction.
3. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
4. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
5. All the staff members must know the correct method of operation of fire fighting system.
6. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in).

# INSPECTION REPORT 2/13

1. Name & address of the building: M/s Khursheda Palace (Banquet Hall), C-150, Kh. No. 142/2, 101/1 & 128/1, Near Sheshewali Masjid Ghonda, Delhi-110053.
2. Building Comprised of : Ground Floor, 1<sup>st</sup> Floor & 2<sup>nd</sup> Floor but Banquet Hall is running on Ground & 1<sup>st</sup> Floor only)
3. Type of Occupancy : Assembly (Banquet Hall)
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/NDZ/2019/726 dated 05/04/2019
6. Fire Safety directives Letter No. : NBC (Part-IV)
7. Date of inspection : 07/07/2022
8. Name of the Inspecting Officer : A.K. Jaiswal, D.O. (East)
9. Name and designation of Officer from the building side : Mohd. Jameel Khan
10. Year of Construction : 2000

**11.** Applicant's letter No. : MHA Portal No. 2022062413469 dated 24/06/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 m	7 m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR ✓
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	2m	2m, 0.85m & 0.85m	MR ✓
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	2m	2m	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	4	4	M/R ✓
	• Types	ABC/CO <sub>2</sub>	Provided	M/R
	• ISI marking	Required	Provided	M/R

*(Signature)*

M/14				
6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR ✓
	• Length of hose reel hose	30 Mtr.	Provided	MR ✓
	• Nozzle diameter	5 mm	Provided	MR ✓
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Ground Floor	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down- comer	100mm	Provided	MR ✓
	• Number of hydrants per floor	1	Provided	MR
	• Hose Box	1	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA ✓
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 ltr	15,000 ltr	MR ✓

M15

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. MCB and Conduit Metal Wiring has also been provided.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/NDZ/2019/726 dated 05/04/2019 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Note: 1<sup>st</sup> Floor is being used for residence of labour / staff.

*Ashok Kumar Jaiswal*  
08/07/2022

Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal  
Designation : D.O. (East Division)

~~Dy. CFO (NDZ)~~

F.T. please.

*Air P*  
12/07/22

~~DO (ED)~~

Sir,

As Approved, F.T. letter is placed for sign-pl.

~~Dy. CFO (NDZ)~~

*Air P*  
15/07/22

*Ashok Kumar Jaiswal*  
14/07/2022

F.P. wing

uploaded  
14/07/2022