

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001


No.F6/DFS/MS/School/NDZ/2022/ 773

Dated:- 22/07/2022

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Kanya/Bal Vidyalaya no. 3 (Evening & Morning Shift) located at Mandawali, Delhi-92 building comprised of 02 blocks A & B, Ground + 03 upper floors, 02 blocks C & D, Ground + 01 upper floor owned/occupied by Sarvodaya Kanya Vidyalaya was granted FSC by this department vide letter No. F6/DFS/MS/School/2017/NDZ/991 dated 10/07/2017 (02 blocks A & B, Ground + 03 upper floors). The premises was re-inspected by the officers concerned of this department on 05/07/2022 in the presence of the Mr. Dharmender Kumar (Estate Manager) and found that the said school have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class "B" 'Educational Building' with effect from 22/07/2022 for a period of three years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 22/07/2022 at New Delhi by


(Anil Garg)
Director

Delhi Fire Service

MW

Copy to:-

1. The Director of Education,
Old Sectt. Delhi - 110054.
2. The Principal,
Sarvodaya Kanya Vidyalaya no. 3, Mandawali, Delhi-92.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

N/21

INSPECTION REPORT

1. Name & address of the building Sarvodaya Kanya/Bal Vidyalaya no. 3 (Evening & Morning Shift) at Mandawali, Delhi-92
2. Type of occupancy:- Educational Building
02 blocks A & B, Ground + 03 upper floors,
02 blocks C & D, Ground + 01 upper floor
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/School/2017/NDZ/991 dated
10/07/2017 (02 blocks A & B, Gr. + 03 upper floors)
5. Fire safety directives No.- NBC Part-IV
6. Date of inspection:- 05/07/2022
7. Name of the inspecting officer:- Sh. Manoj Kumar Sharma (ADO/LN)
8. Name & designation of officer
From the building side:- Sh. Dharmender Kumar (Estate Manager)
9. Year of construction:- 2002 & 2016
10. Applicant's letter No:- email dated 09/06/2022

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	10 mtr.	MR
	2) Gate width	NA	4.5 mtr.	MR
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	A-Block-3 nos. B-Block-2 nos. C-Block-3 nos. D-Block-2 nos.	A-Block-3 nos. B-Block-2 nos. C-Block-3 nos. D-Block-2 nos.	MR
	2. Basements	NA	NA	NA
	B. Width of staircase			
	1. Upper floors	A-Block- 1.5 m B-Block- 1.5 m C-Block- 1.5 m D-Block- 1.5 m	A-Block-1.5 m each B-Block- 1.5 m each C-Block- 1.5 m each D-Block- 1.5 m each	MR
	2. Basements	NA	NA	NA
	C. Protection of exits			
	1. Fire check door	NA	NA	NA
	2. Pressurization	NA	NA	NA
	D. No. of continuous staircase to terrace	02 nos.	02 nos.	MR
	E. Width of corridor	1.5 mtr.	1.7 mtr.	MR
	F. Door size	1.0 mtr.	1.0 mtr.	MR
3.	Compartmentation			
	1) Fire check door	NA	NA	NA
	2) Sealing of electrical shafts	NA	NA	NA
	3) Fire rating of shaft door	NA	NA	NA
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	30 Nos.	69 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	ISI marked	ISI marked	MR

6.	First-Aid Hose Reel			
	1) Total number of each block floor	02 nos.	02 nos.	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	1) Basement	NA	NA	NA
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	NA	NA	NA
	2) Number of hydrants per floor	NA	NA	NA
	3) Hose box	NA	NA	NA
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump output	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump (each block)	450 LPM	02 no. of 450 LPM, (each block)	MR
	b) Head of pump	40 m	40 m	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity (each block)	10,000 ltr	10,000 ltr	MR
15.	Exit Signage.	Required	Provided	MR

16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter F6/DFS/MS/School/2017/NDZ/991 dated 10/07/2017, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.

Handwritten signature

Signature of the Inspecting Officer
Name :- M.K. Sharma
Designation :- ADO (LN)

~~DO (E)~~

DFA phase.

By ~~CFO (NDZ)~~

Handwritten signature
11/07/2022

- It seems a case of addition/alteration.
Pl. Clarify.

Handwritten signature
12/07

~~DO (E)~~

Handwritten signature
14/07/2022

ADD/LN. Sir, observations communicated
have been completed now.

Hence case can be considered pl